



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

May 10, 2016
Subject: New Cold Storage Building
& Concrete Floor in BLD 35813
State WIN: 022211.00
Location: **Fairfield**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Does the existing build need to be lifted or leveled so slab goes under the walls?

Response: The existing building is a pole barn. No leveling will need to be done.

Consider this change and information prior to submitting your bid on **May 18, 2016**.

Sincerely,

A handwritten signature in blue ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER