STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

June 29, 2016
Subject: Deck Replacement &
Substructure Rehabilitation
State WIN: 022269.00
Location: **Andover**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Will the department accept substituting MC6 x 15.3 in place of the MC6 x 16.3 specified on the contract drawings? The MC6 x 16.3 is not readily available and must be purchased in large quantities (40 ton).

Response: Yes.

Consider this change and information prior to submitting your bid on **July 6, 2016**.

Sincerely,

FOR

George M. A. Macdougall P.E.
Contracts & Specifications Engineer