



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

June 24, 2016
Subject: Replacement of Existing
Wearing Surfaces
State WIN: 022313.00
Location: **Richmond**
Amendment No. 2

Dear Sir/Ms:

The following questions have been received:

Question: Will sawcutting be required per 502.13F, or will a tined finish be acceptable?

Response: A tined surface is expected.

Question: Please provide details for the elastomeric concrete headers.

Response: The elastomeric headers shall be 18" wide on the slab side of the joints. The depth shall match that of the wearing surface.

Consider this change and information prior to submitting your bid on June 29, 2016.

Sincerely,

A handwritten signature in blue ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER