STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

March 4, 2016
Subject: Overlay with Drainage & Safety Improvements
State WIN: 022546.00
Location: **Westbrook**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Would slipform curb be an acceptable alternative to type 3 bituminous curb?

Response: For this project, concrete slip form is not acceptable. As specified in the Construction Notes; item 609.31 is being used to repair existing bituminous curb that may be impacted by catch basin adjustments.

Consider this change and information prior to submitting your bid on **March 23, 2016**

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer

PRINTED ON RECYCLED PAPER

THE MAINE DEPARTMENT OF TRANSPORTATION IS AN AFFIRMATIVE ACTION - EQUAL OPPORTUNITY EMPLOYER
PHONE: (207) 624-3000 TTY USERS CALL MAINE RELAY 711 FAX: (207) 624-3001