



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

March 15, 2016  
Subject: Milling/Overlay with  
Drainage & Safety Improvements  
State WIN: 022579.00  
Location: **Sullivan & Gouldsboro  
Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

Question: There are no stations for guardrail adjust. How many runs? What kind of post steel or wood.

Response: There are (10) runs of guardrail that need adjustment all of which have steel posts. The locations are as listed;

Sta.	to	Sta.	Side
24+50		28+25	Rt.
142+72		128+85	Rt.
275+75		278+25	Rt.
314+75		320+25	Rt.
323+65		328+90	Rt.
392+88		396+50	Rt.
26+15		28+15	Lt.
123+35		126+10	Lt.
313+50		319+00	Lt.
422+95		426+45	Lt.

Consider this change and information prior to submitting your bid on **March 23, 2016.**

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER