



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

April 25, 2016
Subject: Milling/Overlay with
Drainage & Safety Improvements
State WIN: 022644.00
Location: **Bangor & Brewer**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Can the DOT allow SaniTite HP (Dual & Triple Wall Polypropylene Pipe per AASHTO M330) to be utilized for the 15", 24", and 36" Class III RCP that is specified on the Project? Class III RCP and Polypropylene are both approved under Option III.

Response: No the Department will not accept any substitutes for RCP.

Consider this change and information prior to submitting your bid on **April 27, 2016**.

Sincerely,

A handwritten signature in blue ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER