



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

February 9, 2016
Subject: Mechanical System
Upgrade
State WIN: PH014489.00
Location: **Penobscot Narrows
Bridge
Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

Question: In a preliminary research of the equipment that is specified for this job, I have found that the equipment listed in Section 000102, Project Information, Part 1.3.B Contract Scope is no longer being offered by Liebert.

On the website www.emersonnetworkpower.com it states: "The Liebert Challenger 3000 has been discontinued and replaced by the Liebert PDX and Liebert PCW compact perimeter cooling systems."

Are you able to verify this by the Pre-Bid meeting that is scheduled for tomorrow morning?

Response: The Liebert PDX and Liebert PCW Compact Perimeter Cooling System is an approved equal.

Consider this change and information prior to submitting your bid on **February 17, 2016**.

Sincerely,

you

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER