



STATE OF MAINE
DEPARTMENT OF PROFESSIONAL
AND FINANCIAL REGULATION
OFFICE OF PROFESSIONAL & OCCUPATIONAL REGULATION
ELECTRICIANS EXAMINING BOARD
35 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0035

Paul R. LePage
GOVERNOR

Anne L. Head
DIRECTOR

Special Written Permission Issued by the Senior State Electrical Inspector (September 2014)
Re: 2014 NEC, Section 680.25

The Senior Electrical Inspector for the Maine Electricians' Examining Board hereby exercises the written special permission contemplated in Section 90.4 of the National Electrical Code®, effective retroactively to the date of formal adoption of the 2014 NEC® by the Maine Electricians' Examining Board.

Re: 680.25

At issue is the new requirement for an *insulated* equipment grounding conductor for feeders that supply branch circuits for pool equipment. This special permission will continue to permit the use of an existing feeder, with an un-insulated equipment grounding conductor, in or on existing one- and two-family dwellings.

“Existing” shall mean any *NEC*-compliant installation that was installed prior to the effective date of the 2014 *NEC* in Maine.

This special permission shall remain effective until adoption of the 2017 *NEC* by the Maine Electricians' Examining Board.



PRINTED ON RECYCLED PAPER

PHONE: (207)624-8457

FAX: (207)624-8636

MAINE RELAY 711 (TTY)
OFFICES LOCATED AT: 76 NORTHERN AVENUE,
GARDINER, MAINE