

Assessment for: Golden Eagle Restaurant, ME0004696
Location: Madison, Maine
Date: September 1, 2009

Summary of the Data used in our Assessment

Well type: Bedrock well
Well identification number: 4696102
Well description: Bedrock well, drilled 260 ft
Overburden thickness (feet): 90 ft
Positive bacteria test result(s): Yes
Nitrate test result(s) greater than 5 ppm: No
Septic system(s) within 300 feet of the well: Yes
Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well
Overburden thickness (feet): 90 ft

*Existing risk of contamination
based on well type & site geology:*

Low risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): Yes
Nitrate test(s) greater than 5 ppm: No
Septic system(s) within 300 feet of the well: Yes
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

High risk

Future Risk for Acute Contamination

Ranking:

Status of land control: *The owner does not own or control the land within 300 feet of the well head radius.*

Future risk of acute contamination:

High risk