

**Spill Prevention and Control Plan
Stetson Wind Project**

T8R3 and T8R4 NBPP, Maine

October 17, 2007

Introduction

This is a Spill Prevention and Discharge Control Plan prepared for construction activities at the Stetson Wind Project in T8R3 and T8R4 NBPP, Maine.

Contingency Measures

- A. Preventative Measures
 - 1. Refueling will be done in designated areas at each site. No refueling will occur within 100 feet of a wetland or stream. Caution will be taken to prevent overflow of fuel. Absorbent pads will be on hand while refueling is taking place.
- B. Emergency Measures
 - 1. A 20-gallon spill lab pack will be provided on-site.
 - 2. An excavator will be on-site and hand tools will be available to clean up any spills.
 - 3. Absorbent pads will be available on-site, and the lab pack is equipped with a containment boom.
 - 4. A 55-gallon drum will be available on-site to place any used absorbent pads.

Spill and Discharge Control Actions

- A. In case of spill, contractor will notify DEP Spill Control and the Owner's Representative immediately.
- B. The site crew will be prepared to take immediate measures to contain the spill to within the site boundaries.
- C. Measures will be taken to stop the source of the spill.
- D. If the spill is discharged into the soil, absorbent pads will be used to absorb as much of the spill as possible. The material will be excavated and disposed of in accordance with EPA and State regulations.
- E. If the spill discharges into the water, the containment boom will be used to contain and absorb the spill. The absorbent material will be disposed of in accordance with applicable EPA and State regulations.
- F. If the spill is deemed reportable by Federal Regulations Title 40 CFR 302 and Title 40 CFR 117, and/or human health or the environment is threatened, Sargent Corporation will immediately contact the agencies list in Appendix A.
- G. If materials cannot be decontaminated on-site and clean-up is required to eliminate traces of the substance spilled or reduce it to an acceptable level, Sargent Corporation will be prepared to remove such material. The materials will be properly containerized and disposed of as soon as possible.
- H. If required, Sargent Corporation will perform any sampling and testing necessary to confirm the area contaminated has been cleaned to an acceptable level. Sampling and analysis will be performed in accordance with Federal and State requirements.
- I. Sargent Corporation will file a written report with the Owners/Owners Representative and the appropriate agencies immediately after clean-up is complete.
- J. Emergency contact representatives and numbers are on attached Appendix A.

APPENDIX A

EMERGENCY CONTACT LIST

Maine DEP Oil Spills	1-800-482-0777
Maine DEP Local Contact	941-4570
Danforth Fire Department	448-2255
Sargent Corporation Site Supervisor (Chris Lynch)	(Cell) 944-0616
Sargent Corporation Ops. Manager (Jim Conley)	(Cell) 944-7130
	(Office) 827-4435
Sargent Corporation Proj. Mgr. (John Sturgeon)	(Cell) 944-0169
	(Office) 827-4435
UPC (Owners Rep.) David Cowan	(Office) 541-1940
	(Cell) 712-8271