

Assessment for: Spinneys, ID ME0005773  
Location: Phippsburg, Maine  
Date: May 8, 2003

### **Summary of the Data used in our Assessment**

Well type: Dug Well  
Well identification number: 5773301  
Well description: Dug Well 27'/well Pnts  
Overburden thickness (feet): Unknown  
Positive bacteria test result(s): Yes  
Nitrate test result(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlots/manure piles(s) within 300 feet of the well: No

### **Risk Based on Well Type and Site Geology**

*Ranking:*

Well type: Dug Well  
Overburden thickness (feet): Unknown

*Existing risk of contamination  
based on well type & site geology:*

**High risk**

### **Existing Risk of Acute Contamination**

*Ranking:*

Positive coliform test(s): Yes  
Nitrate test(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

*Existing risk of acute contamination:*

**High risk**

### **Future Risk for Acute Contamination**

*Ranking:*

Status of land control: The status of land ownership is unknown or it has been determined that the proprietor does not own or control all the land within 300 feet of this water supply source.

*Future risk of acute contamination:*

**Moderate risk**