

Assessment for: Sanford Water District, ME0091410
Location: Sanford, Maine
Date: July 8, 2009

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Gravel Pit
Well identification number: 91410210
Well description: Gravel Pit Well 29 Ft
Overburden thickness (feet): 24.3 Ft
Wellhead protection radius around the well: 2500 Ft
Reported distance of land control around the well: 150 Ft
Wellhead Protection Ordinance in effect: Yes

Risk Based on Well Type and Site Geology

Ranking:

Well type: Gravel Pit
Overburden thickness (feet): 24.3 Ft

Existing risk of contamination based on well type & site geology:

Moderate Risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test: No
Nitrate test greater than 5 ppm: No
Septic system within 300 feet of the well: No

Existing risk of acute contamination:

Low Risk

Future Risk of Acute Contamination

Future Ranking:

No legal land control or control status is unknown or
legal control is less than a 150-foot radius around the well: No
Legal control of at least a 150-foot radius of property around the well: Yes
Legal control of at least a 300-foot radius of property around the well: No

Future risk of acute contamination:

Moderate Risk

Existing Risk of Chronic Contamination

Ranking:

Detection of Chronic Chemical Contaminant: No
Name(s) of Chronic Chemical Contaminant(s) Detected: None
Total No. Potential Sources of Contamination within WHPA: 4
Distance to nearest "Significant Potential Source of Contamination": 150 Ft
Name of nearest "Significant Potential Source of Contamination": Road

Existing risk of chronic contamination:

Moderate Risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: No
Legal control of 2500 Phase II/V Waiver Radius: No

Future risk of chronic contamination:

High Risk