

Assessment for: Sullivan Town Office; ID ME0095021  
Location: Sullivan, Maine  
Date: June 13, 2012

### **Summary of the Data used in our Assessment**

Well type: Bedrock well  
Well identification number: 95021101  
Well description: Bedrock well; Buried; depth and yield not known  
Overburden thickness (feet): 0 ft  
Positive bacteria test result(s): No  
Nitrate test result(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: No  
Animal feedlots/manure piles(s) within 300 feet of the well: No

### **Risk Based on Well Type and Site Geology**

*Ranking:*

Well type: Bedrock well; buried  
Overburden thickness (feet): 0 ft

*Existing risk of contamination  
based on well type & site geology:*

***Moderate risk***

### **Existing Risk of Acute Contamination**

*Ranking:*

Positive coliform test(s): No  
Nitrate test(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: No  
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

*Existing risk of acute contamination:*

***Low risk***

### **Future Risk for Acute Contamination**

*Ranking:*

Status of land control: The owner owns and/or controls app 150 ft of the WHPR of 300 ft

*Future risk of acute contamination:*

***Moderate risk***