

Assessment for: Sunday River-Sunrise Condo; ID ME0092010
Location: Newry, Maine
Date: June 9, 2011

Summary of the Data used in our Assessment

Well type: Bedrock well
Well identification number: 92010102
Well description: Bedrock well, 587 ft deep
Overburden thickness (feet): not known
Positive bacteria test result(s): No
Nitrate test result(s) greater than 5 ppm: No
Septic system(s) within 300 feet of the well: No
Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well
Overburden thickness (feet): not known

*Existing risk of contamination
based on well type & site geology:*

Moderate Risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): No
Nitrate test(s) greater than 5 ppm: No
Septic system(s) within 300 feet of the well: No
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

Low risk

Future Risk for Acute Contamination

Ranking:

Status of land control: The owner owns and/or controls 200 ft of the well head protection radius.

Future risk of acute contamination:

Moderate risk