

Addendum #2

Project: Cumberland County Courthouse Courtroom 12 Acoustic Improvements


Bid Administrator: Ryan Bell, Facilities Engineer

Bid Date: 4/28/2021 at 2PM

The contract documents dated March 30th, 2021 are modified as follows:

The Bid Date will be changed to 5/5/2021 at 2PM.

The following drawing will replace the existing trim detail on the ceiling panels.



Existing blocking will need to be modified to be able to accommodate manufacturers recommendation for 1" of space necessary for the panels to slide into the clips. An extra 1/2" of space allows for some fluctuation in the panel width.

The ceiling panels will have metal edges instead of the specified hardened resin.