

**Maine Department of Inland Fisheries and Wildlife
Division of Hatcheries**

EMBDEN REARING STATION PIPELINE REPLACEMENT

Addendum #1

BGS Project No: 3289

Date: 5/17/2022

Bids Due: 5/26/2022, 2 PM

1. A non-mandatory pre-bid meeting was held on 5/16/2022 at 10 AM.
 - a. Attendance:
 - i. Richard Parker IFW
 - ii. Todd Langevin IFW
 - iii. Gene Arsenault IFW
 - iv. PJ Bedard Bedard Excavation
2. Question #1
 - a. **Question:** Please clarify exact specifications and size of pipe to be used for the project.
 - b. **Answer:** Add to specification 40 05 00, 3.6 Piping Schedules, A.2.1.a: After Materials: Polyethylene "IPS DR 21"
3. Question #2
 - a. **Question:** The excavation will more than likely consume the majority of the existing roadway. Where shall the excavated material go and access along the ditch be maintained
 - b. **Answer:** IFW will have existing pipeline located and clear trees and brush to create a 20' wide corridor along the side of the pipeline prior to construction. Contractor may use this corridor as they choose for material storage and/or construction access road.
4. Contractors will be responsible for monitoring the BGS website for further addendums. Addendums will not be emailed directly. <https://www.maine.gov/dafs/bgs/business-opportunities#invitationforbid>

End of Addendum #1