

**Maine Department of Inland Fisheries and Wildlife
Division of Hatcheries**

EMBDEN REARING STATION PIPELINE REPLACEMENT


Addendum #2

BGS Project No: 3289

Date: 5/23/2022

Bids Due: 5/26/2022, 2 PM

1. Please clarify pipe bedding specifications.
 - a. See Detail Below



**TYPICAL HDPE PIPE TRENCH
BEDDING DETAILS**



Bedding Material- Class 1B Well-graded crushed stone

2. Please clarify road replacement specifications
 - a. When proceeding through the asphalt, follow pavement detail 4 using a 12" compacted base at 95% under the dense graded aggregate surface.

End of Addendum #2