Date: 01-31-24

Re: Addendum No. 8 to the Bidding Documents for Security and Access Control Upgrades at The Riverview Psychiatric Center

This ADDENDUM is issued to modify, explain or correct the Drawings and Specifications, and is hereby made a part of the Contract Documents.

NOTICE TO ALL BIDDERS: Please read the entire ADDENDUM for references to all aspects of the Work. This ADDENDUM shall be binding upon the Contractor and he shall furnish and install labor and materials indicated to be furnished and installed by him herein even though such Work is not graphically mentioned in the Drawings and Specifications.

I. GENERAL

A. The cut off for receipt of questions from bidders shall be 2:00 PM on February 01, 2024.

II. CHANGES TO THE SPECIFICATIONS:

- A. Section 001113-Notice to Contractors: Change the Bid Date in Paragraph 1. From 2:00 PM on February 02, 2024 To 2:00 PM on February 09, 2024.
- B. Section 26100-Electrical General Requirements Part 1, 1.2, add paragraph C: 120volt power circuits for head end equipment, servers, switches, control room equipment, control room workstations, items in equipment rooms, all intercom and video surveillance, etc shall be wired to standby power and UPS backup. Other items requiring 120volt power shall be fed by standby power circuits at a minimum.
- C. Section 283000 Duress Alarm, Paragraph 2.1, H, Section 282000 Video Surveillance, Paragraph 2.1, I Section 281000 Access Control, Paragraph 2.1, I Delete paragraph in each spec in its entirety and add in its place:

The contractor shall have an established 24-hour emergency service organization. A dedicated telephone number shall be provided to the owner for requesting emergency service. A maximum of <u>TWO</u>-hour, electronic service technician on site, response time shall be guaranteed by the contractor.

D. Section 283000 Duress Alarm, Paragraph 2.2, G, add:6. Provide 200 Heavy Duty Tags(HDT) as part of the scope of this project.

III. CHANGES TO THE DRAWINGS:

NONE