


**State of Maine – Boating Facilities Program  
Aroostook State Park Boat Launch Replacement  
Presque Isle, ME 04769**

**Addendum #1**



**ISSUE DATE:  
7/10/2024**

**State of Maine – Boating Facilities Program**  
**Aroostook State Park Boat Launch Replacement**  
**Presque Isle, ME 04769**

THE FOLLOWING INFORMATION SHALL BE CONSIDERED TO BE A PART OF THE PROJECT. THE ATTACHED INFORMATION SHALL EITHER SUPPLEMENT, AMEND, OR REPLACE THE INFORMATION SHOWN ON THE DRAWINGS; BE SURE TO ACKNOWLEDGE RECEIPT OF THIS DOCUMENT ON THE BID FORM.

The following items/questions have been asked or commented on:

1. “The precast concrete curb acting as a border for the boat ramp. What does the curb consist of and is it provided by owner along with the ramp sections?”

The curb ramp is to be equal to MDOT precast curb. The owner does not provide the curbing.

2. “The concrete abutment the dock sections attach to. Is that to be formed as foundation walls with a cap or one solid mass of concrete?”

The abutment will be used as an anchor and will be one unit with anchors, top, etc. as noted on the plans. A typical foundation system is acceptable. Also acceptable is a concrete septic tank of the same or larger size used as a form, rebar cage added, anchors added, etc. and then filled solid with concrete.

**- END OF ADDENDUM #1-**