



ADDENDUM NO. 02 – September 27, 2022

**RE: Roof Replacement and Associated Work
 At the Stone Building
 67 Independence Drive, Augusta, ME
 GALE JN: 839100 P01 T06
 BGS Project Number: 3381**

FROM: Gale Associates, Inc.
 5 Moulton Street
 Portland, ME 04101

TO: ALL PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated September 2, 2022, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. This Addendum consists of one (1) page, including attachments.

ITEM 1. Natural Slate Shingles (Alternate #1 Scope of Work)

Reference: Specification Section 07 32 29 – “Synthetic Slate Shingles and Flashing”

Modification: Modify Item A in Section 07 32 29 – 2.4 to revise natural slate shingle size for Alternate #1 scope of work and slate color as follows:

3. Size: Slate to be 24 inches long by 12 inches wide.

8. Color: Slate color to be North Country Black as manufactured by New England Slate, Dover/Cupa Black by Vermont Slate, or approved equal. Final color to be selected by Owner.

END OF ADDENDUM TWO