



Central Maine Community College

Outdoor Pavilion

1250 Turner St., Auburn, Maine

Addendum No. 01

Date: May 20, 2022

To: Prospective Bidders

Re: Addendum to the Issued for Bid package

This Addendum forms a part of the Contract Documents and modifies the original Issued for Bid package dated May 02, 2020.

This Addendum consists of two pages and the Pre-Bid Attendees List.

HEC+A

Matthew C. McClenahan

Matthew C. McClenahan
Director of Design Services

PRE-BID QUESTIONS & ANSWERS

1. Q: Who is responsible for concrete testing and payment as there is not an allowance for it.

A: The GC will be responsible for coordinating the testing with their scheduled concrete pour(s) while the Owner will be responsible for actual payment, either through a written Change Order to the project or by direct payment to the Testing company.

2. Q: The existing drawings call for a concealed fastener siding system to match the existing cafeteria, but the cafeteria has an exposed fastener system. Please clarify intent.

A: The intent is for a concealed fastener system. Please follow the Bid Documents.

3. Q: A2/A103 you show slab meeting TOW with a joint, if you want the water to run off the slab wouldn't it be better to show a TOW wall height lower than the TOS with rebar connecting wall to slab.

A: For bidding purposes, please follow the Bid Documents as shown.

END

