

Reuse or reproduction of the ontents of this document is n permitted without written ermission of CHA Architectur

RENOVATIONS Academy, Curtis Hall Castine, Maine 0442 **CURTIS HALL** Maine Maritime, Pleasant Street,

QUADRANT KEY PLAN

No. Date Description Revision Schedule

NOT FOR


JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING 1/22/2023

TITLE
PHASE 4 FIRST FLOOR
PLUMBING SUPPLY
DEMOLITION & NEW
PLANS

PP104.1



Reuse or reproduction of the contents of this document is n permitted without written permission of CHA Architectur

RENOVATIONS

Academy, Curtis Hall , Castine, Maine 0442 **CURTIS HALL** Maine Maritime, Pleasant Street,

QUADRANT KEY PLAN

No. Date Description Revision Schedule

NOT FOR

JOB NO. 076982


ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

1/22/2023

TITLE
PHASE 4 SECOND
FLOOR PLUMBING
DEMOLITION & NEW
PLANS

P104.2



Reuse or reproduction of the contents of this document is n permitted without written permission of CHA Architectur

RENOVATIONS

Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 0442' **CURTIS HALL**

QUADRANT KEY PLAN

No. Date Description Revision Schedule

NOT FOR

JOB NO. 076982

ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

1/22/2023

TITLE
PHASE 4 THIRD FLOOR
PLUMBING DEMOLITION
& NEW PLANS

SHEET

P104.3



PHASE 4 FOURTH FLOOR PLUMBING PLAN

COPYRIGHT CHA Architecture

Reuse or reproduction of the ontents of this document is n permitted without written ermission of CHA Architectur

RENOVATIONS Academy, Curtis Hall Castine, Maine 0442

CURTIS HALL

Maine Maritime A Pleasant Street,

QUADRANT KEY PLAN

No. Date Description Revision Schedule

NOT FOR

JOB NO. 076982


ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING


1/22/2023


TITLE
PHASE 4 FOURTH
FLOOR PLUMBING
DEMOLITION & NEW
PLANS

P104.4










Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421


Revision Schedule


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING


TITLE PHASE 1 - PLUMBING PART PLANS


P401


























PLUMBING PUMP SCHEDULE ELECTRICAL FLOW HEAD (FT) CONN SIZES MAKE & MODEL SERVICE
 MOTOR HP
 AMPS
 V/PH/HZ
 NOTES

 1/6
 10.0
 1201/60
 1.2

 1/6
 10.0
 1201/60
 1.2

 1/6
 10.0
 1201/60
 1.2

 RCP-I
 DHW RECIRC PH164
 ENOVATIVE AUTOHOT 150-SERIES
 3-SPEED WET ROTOR PUMP
 10
 30
 3/4" X 3/4"

 RCP-2
 DHW RECIRC PH263
 ENOVATIVE AUTOHOT 150-SERIES
 3-SPEED WET ROTOR PUMP
 10
 30
 3/4" X 3/4"
 I NOTES:

1. SEE SPEC SECTION 22 11 16.

2. PROVIDE 120V, 10A RECEPTACLE FOR DC-150 PUMP CONTROLLER, RCP GRUNDFOS UPS-26-15-SF PUMP IS POWERED FROM THE CONTROLLER.

INSTANTANEOUS DHW HEATER SCHEDULE																
TAG	MFR.	MODEL	GPM	TEMP RISE (DEG-F)	STEAM INLET PRESSURE (PSIG)	STEAM INLET SIZE	COND. SIZE	INTAKE	VENT	WIDTH (INCHES)	HEIGHT (INCHES)	DEPTH (INCHES)	DCW CONNECTION SIZE	DHW CONNECTION SIZE	DHWR CONNECTION SIZE	NOTES
HEX-D1	ARMSTRONG	FLO-RITE TEMP FRT8120DWPR	37.0	90	15	4"	2"		3/4"	34	46	97	2"	211	411	
HEX-D2	ARMSTRONG	FLO=RITE TEMP FR18120DWPR	37.0	90	15	4"	2"		3/4"	34	46	97	1	'	' '	
NOTES																
1. TWO H	EAT EXCHANGER	S TOTAL, FACTORY PIPED TOGETHER UNDER	RLISTED	MODEL N	UMBER IN SIDE-BY	SIDE CONF	GURAT I ON	L.								

	THERMOSTATIC MIXING VALVE											
TAG	SYSTEM	MFR.	MODEL	PD (PSI)		PEAK GPM FLOW	INLET	OUTLET	ELECT VOLT / PH	ELECT AMPS	NOTES	
TMV-1	DHW	POWERS INTELLISTATION JR	LFIS200VL-SYS200RTN	5	1.0	125	2-1/2"	2-1/2"	120/1	20 VA	1	
NOTES:												
1. PRE-PIPED SYSTEM WITH BUILT-IN INLET AND OUTLET SHUTOFF VALVES.												

PLUMBING FIXTURE SCHEDULE										
TAG	DESCRIPTION		BRANC	H SIZES		NOTES				
IAG	DESCRIPTION	CW	HW	VENT	WASTE	NOTES				
P-1A	WATER CLOSET	1"		2"	3"	ADA COMPL I ANT				
P-2A	LAVATORY	3/8"	3/8"	1-1/2"	1-1/2"	ADA COMPL I ANT				
TP-1	TRAP PRIMER	1/2"								

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is not permitted without written permission of CHA Architecture.

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall 1 Pleasant Street, Castine, Maine 04421

No. Date Description Revision Schedule

NOT FOR CONSTRUCTION

JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING 11/22/2023

TITLE PLUMBING SCHEDULES

SHEET

P600

DESCRIPTION


TAG

TAG

WC WATER CLOSET
UR URINAL
LAV LAVATORY
SH SHOWER
FD URINAL
HB HOSE BIBB
WHYD WALL HYDRANT

FD FLOOR DRAIN

EXISTING PLUMBING FIXTURE SCHEDULE (PROVIDED FOR REFERENCE, VERIFY SIZES IN FIELD)



PHASE 1 GROUND FLOOR MECHANICAL PLAN

A3

PHASE 1 GROUND FLOOR MECHANICAL DEMOLITION PLAN

COPYRIGHT CHA Architecture

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No. Date Description

Revision Schedule

NOT FOR CONSTRUCTION

JOB NO. 076982


ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 1 GROUND
FLOOR MECHANICAL
PLANS

SHEET

M101.G



CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No Date Description Revision Schedule

NOT FOR CONSTRUCTION


JOB NO. 076982


ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING


TITLE
PHASE 1
INTERMEDIATE FLOOR
MECHANICAL PLANS

M101.0


















Maine Maritime Academy, Curtis Hall 1 Pleasant Street, Castine, Maine 04421

NOT FOR CONSTRUCTION

TITLE
PHASE 2 FIRST FLOOR
MECHANICAL
DUCTWORK PLANS

MH102.1





CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

Revision Schedule

NOT FOR CONSTRUCTION

JOB NO. 076982

ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 2 FIRST FLOOR MECHANICAL PIPING PLANS

PLAN NORTH

TRUE NORTH

MP102.



CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 2 SECOND
FLOOR MECHANICAL
PLANS

SHEET

Ν


PLAN NORTH

TRUE NORTH

M102.2

UNLESS OTHERWISE NOTED, ALL EXISTING MECHANICAL PIPING WITHIN THE BUILDING INCLUDING HWS, HWR, LPS, LPR, MPS, & MPPR IST DO BE REMOVED, HWS & HWR PIPING IST DB EREPLACED WITH NEW, REFER TO DEMOLITION PLANS FOR APPROXIMATE PIPING LAYOUT, EXISTING HOT WATER EQUIPMENT SHALL REMAIN FOR RE-USE, EXCEPT WHERE NOTED FOR REPLACEMENT, PROVIDE NEW CONTROL VALVES AND CONNECT NEW PIPING TO EXISTING EQUIPMENT.

THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUR ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION. SEE A2 / MEPOZO FOR AN EXAMIPE STRATECY TO MAINTAIN SERVICE TO OCCUPIED AREAS, INTERVIPTIONS IN SERVICE TO OCCUPIED AREAS SHAI



CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No. Date Description Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 2 THIRD FLOOR MECHANICAL PLANS

SHEET

M102.3

UNLESS OTHERWISE NOTED, ALL EXISTING MECHANICAL PIPING WITHIN THE BUILDING INCLUDING HWS, HWR, LPS, LPR, MPS, & MPPR IST DO BE REMOVED, HWS & HWR PIPING IST DB EREPLACED WITH NEW, REFER TO DEMOLITION PLANS FOR APPROXIMATE PIPING LAYOUT, EXISTING HOT WATER EQUIPMENT SHALL REMAIN FOR RE-USE, EXCEPT WHERE NOTED FOR REPLACEMENT, PROVIDE NEW CONTROL VALVES AND CONNECT NEW PIPING TO EXISTING EQUIPMENT.


THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUR ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION. SEE A2 / MEPOZO FOR AN EXAMIPE STRATECY TO MAINTAIN SERVICE TO OCCUPIED AREAS, INTERVIPTIONS IN SERVICE TO OCCUPIED AREAS SHAI

Ν

E KEPT TO A MINIMUM AND SHALL BE STRICTLY COORDINATED WITH MAINE MARITIME ACADEM' EE SHEET MEP000 FOR ADDITIONAL INFORMATION AND PHASING NOTES.

PLAN NORTH

TRUE NORTH



CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 2 FOURTH
FLOOR MECHANICAL
PLANS

Ν


PLAN NORTH

TRUE NORTH

SHEET M102.4

UNLESS OTHERWISE NOTED, ALL EXISTING MECHANICAL PIPING WITHIN THE BUILDING INCLUDING HWS, HWR. LPS, LPR, MPS, & MPP IS TO BE REMOVED, HWS & HWR PIPING IS TO BE REPLACED WITH NEW, REFER TO DEMOLITION PLANS FOR APPROXIMATE PIPING LAYOUT, EXISTING HOT WATER EQUIPMENT SHALL REMAIN FOR RE-USE, EXCEPT WHERE NOTED FOR REPLACEMENT, PROVIDE NEW CONTROL VALVES AND CONNECT NEW PIPING TO EXISTING EQUIPMENT.

THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUR ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION. SEE A2 / MEPOZO FOR AN EXAMIPE STRATECY TO MAINTAIN SERVICE TO OCCUPIED AREAS, INTERVIPTIONS IN SERVICE TO OCCUPIED AREAS SHAI




Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 2 ROOF LEVEL MECHANICAL PLANS

M102.5



Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

NOT FOR CONSTRUCTION

TITLE
PHASE 3 FIRST FLOOR
MECHANICAL
DUCTWORK PLANS

MH103.1



Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421


No Date Description

NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 3 FIRST FLOOR
MECHANICAL PIPING
PLANS

MP103.1



Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No. Date Description Revision Schedule

NOT FOR CONSTRUCTION


JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 3 SECOND
FLOOR MECHANICAL
PLANS

M103.2



Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No Date Description Revision Schedule

NOT FOR CONSTRUCTION


JOB NO. 076982

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 3 THIRD FLOOR MECHANICAL PLANS

SHEET

M103.3



Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No Date Description Revision Schedule

NOT FOR CONSTRUCTION

JOB NO. 076982


ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 3 FOURTH FLOOR MECHANICAL PLANS

SHEET

M103.4





CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No. Date Description Revision Schedule

NOT FOR CONSTRUCTION

JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 4 GROUND
FLOOR MECHANICAL
PLANS


SHEET

Ν

PLAN NORTH

TRUE NORTH

M104.G



Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421


No. Date Description

NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 4 FIRST FLOOR
MECHANICAL
DUCTWORK PLANS

MH104.1



Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421


No. Date Description

NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 4 FIRST FLOOR MECHANICAL PIPING PLANS

MP104.



CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING


TITLE
PHASE 4 SECOND
FLOOR MECHANICAL
PLANS

TRUE NORTH

SHEET M104.2

THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUP ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MANITAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION, SEE A2 / MEPOZO FOR AN EXAMPLE STRATECY TO MANITAIN SERVICE TO OCCUPIED A PRES, INTERVILLYIONS IN SERVICE TO OCCUPIED A REAS SHAI BE KEPT TO A MINIMUM AND SHALL BE STRACTLY COORDINATED WITH MAKE MARTIME ACADEMY SEE SHEET MEROOP OFR ADDITIONAL INFORMATION AND PHASING NOTES.

Ν PLAN NORTH





CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 4 THIRD FLOOR MECHANICAL PLANS

SHEET M104.3

TRUE NORTH


GENERAL MECHANICAL NOTE:

UNLESS OTHERWISE NOTED, ALL EXISTING MECHANICAL PIPING WITHIN THE BUILDING INCLUDING HWS, HWR, LPS, LPR, MPS, & MPPR IST DO BE REMOVED, HWS & HWR PIPING IST DB EREPLACED WITH NEW, REFER TO DEMOLITION PLANS FOR APPROXIMATE PIPING LAYOUT, EXISTING HOT WATER EQUIPMENT SHALL REMAIN FOR RE-USE, EXCEPT WHERE NOTED FOR REPLACEMENT, PROVIDE NEW CONTROL VALVES AND CONNECT NEW PIPING TO EXISTING EQUIPMENT.

THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUP ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MANITAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION, SEE A2 / MEPOZO FOR AN EXAMPLE STRATECY TO MANITAIN SERVICE TO OCCUPIED A PRES, INTERVILLYIONS IN SERVICE TO OCCUPIED A REAS SHAI BE KEPT TO A MINIMUM AND SHALL BE STRACTLY COORDINATED WITH MAKE MARTIME ACADEMY SEE SHEET MEROOP OFR ADDITIONAL INFORMATION AND PHASING NOTES.

Ν

PLAN NORTH





CURTIS HALL RENOVATIONS

Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421



No. Date Description Revision Schedule

NOT FOR CONSTRUCTION

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE
PHASE 4 FOURTH
FLOOR MECHANICAL
PLANS

SHEET

TRUE NORTH


M104.4


UNLESS OTHERWISE NOTED, ALL EXISTING MECHANICAL PIPING WITHIN THE BUILDING INICLUDING HIVS, HWR. LPS, LPR, MPS, & MPR IS TO BE REMOVED, HWS & HWR PIPING IS TO BE REPLACED WITH INEW, REFER TO DEMOLITION PLANS FOR APPROXIMATE PIPING LAYOUT, EXISTING HOT WATER EQUIPMENT SHALL REMAIN FOR RE-USE, EXCEPT WHERE NOTED FOR REPLACEMENT, PROVIDE NEW CONTROL VALVES AND CONNECT NEW PIPING TO EXISTING EQUIPMENT.


THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUP ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVILLY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MANITAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVILLY UNDER CONSTRUCTION, SEE A2 / MEPOZO FOR AN EXAMPLE STRATECY TO MANITAIN SERVICE TO OCCUPIED A PRES, INTERVILLYIONS IN SERVICE TO OCCUPIED A REAS SHAI BE KEPT TO A MINIMUM AND SHALL BE STRACTLY COORDINATED WITH MAKE MARTIME ACADEMY SEE SHEET MEROOP OFR ADDITIONAL INFORMATION AND PHASING NOTES.


Ν

PLAN NORTH









NOTE: THESE SYSTEM SCHEMATICS ARE PART OF ALTERNATE #4. REFER TO SCHEDULES AND PLANS.

COPYRIGHT CHA Architecture

RENOVATIONS

Academy, Curtis Hall Castine, Maine 04421 HALL Maine Maritime Pleasant Street, **CURTIS**

No. Date Description Revision Schedule

NOT FOR

JOB NO.

ISSUE


100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING 11/22/2023


TITLE MECHANICAL DETAILS


SHEET

M501 M

NOTE: THESE SYSTEM SCHEMATICS ARE PART OF ALTERNATE #4. REFER TO SCHEDULES AND PLANS.







				DEDICATED OF	JTSIDE AIR SYSTEM (DC	AS) SCHEDIII E				
GENERAL	TAG	DOAS-0-1	DOAS-R-11	DOAS-R-12	DOAS-R-21	DOAS-R-22	DOAS-R-31	DOAS-R-32	DOAS-R-41	DOAS-R-42
CENTER	SERVES	FLRS 0-1 DORMS, PHASE 1	FLRS 2-4 DORMS, PHASE 1	FLRS 2-4 DORMS, PHASE 1	FLRS 2-4 DORMS, PHASE 2			FLRS 2-4 DORMS, PHASE 3	FLRS 2-4 DORMS, PHASE 4	FLRS 2-4 DORMS, PHASE 4
	LOCATION	GRADE (0)	ROOFTOP (R)							
	TYPE	Polymer Wheel								
	MFR	TRANE - HORIZON								
	MODEL	OADG	OADG	OABD	OADG	OABD	OADG	OABD	OADG	OABD
FILTER SECTION	FILTERS (OA)	MERV 13								
	FILTERS SIZE (IN)	16 x 20 x 2	16 x 20 x 2	20 x 24 x 2	16 x 20 x 2	20 x 24 x 2	16 x 20 x 2	20 x 24 x 2	16 x 20 x 2	20 x 24 x 2
	FILTERS (RA)	MERV 8								
OUTSIDE AIR FAN	FILTERS SIZE (IN) TYPE	20 x 20 x 2 DDP w/ Shaft Grounding	20 x 20 x 2 DDP w/ Shaft Grounding	20 x 24 x 2 DDP w/ Shaft Grounding	20 x 20 x 2 DDP w/ Shaft Grounding	20 x 24 x 2 DDP w/ Shaft Grounding	20 x 20 x 2 DDP w/ Shaft Grounding	20 x 24 x 2 DDP w/ Shaft Grounding	20 x 20 x 2 DDP w/ Shaft Grounding	20 x 24 x 2 DDP w/ Shaft Grounding
OU ISIDE AIR FAN	AIRFLOW (cfm)	2,750	3,650	1,400	3,650	1,400	3,650	1,400	3,650	1,400
	ESP, in.wc.	1,5inwc	1,5inwc	1.5inwc	1,5inwc	1,5inwc	1,5inwc	1.5inwc	1,5inwc	1,5inwc
	MOTOR SPEEDS	VARIABLE								
	FAN HP / kW	2 HP	3 HP	1 HP						
EXHAUST AIR FAN	TYPE	DDP w/ Shaft Grounding								
	AIRFLOW (cfm)	2,750	3,650	1,400	3,650	1,400	3,650	1,400	3,650	1,400
	ESP, in.wc.	1.5inwc								
	MOTOR SPEEDS	VARIABLE								
OVERALL DIMENSIONS	FAN HP / kW LENGTH	2 HP 161"	3 HP 176"	1 HP 161"						
OVERALL DIMENSIONS	WIDTH	52"	95"	161" 52"	95"	161" 52"	95"	161" 52"	95"	161" 52"
	HEIGHT	55"	68"	55"	68"	55"	68"	55"	68"	55"
	OPERATING WEIGHT, lbs.	4.000	4,000	2,100	4.000	2.100	4,000	2,100	4.000	2.100
HEAT RECOVERY CORE	SUMMER OA DB/WB	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74
	WINTER OA DB	-10	-10	-10	-10	-10	-10	-10	-10	-10
	SUMMER SA DB/WB	77.5 / 65.3	77.9 / 65.8	77.2 / 65.2	77.9 / 65.8	77.2 / 65.2	77.9 / 65.8	77.2 / 65.2	77.9 / 65.8	77.2 / 65.2
	WINTER SA DB	51.3	47.7	54	47.7	54	47.7	54	47.7	54
	SENSIBLE EFFECTIVENESS	79.0%	75.0%	81.0%	75.0%	81.0%	75.0%	81.0%	75.0%	81.0%
	SUMMER TOTAL EFF.	77.0%	72.0%	78.0%	72.0%	78.0%	72.0%	78.0%	72.0%	78.0%
	WINTER TOTAL EFF.	77.0%	73.0%	81.0%	73.0%	81.0%	73.0%	81.0%	73.0%	81.0%
	FROST CONTROL CORE BYPASS	WHEEL BYPASS INTERNAL DAMPER								
REFRIGERATION	REFRIGERANT	R410								
KEI KIOEKATION	CONDENSER FAN	Variable with VFD								
	SCROLL COMPRESSORS	Digital Scroll								
	HGRH	YES, 70F LAT								
HEATING COIL	HYDRONIC COIL TAG	INTEGRAL TO UNIT								
	EAT, deg-F.	51.3	47.7	54	47.7	54	47.7	54	47.7	54
	LAT, deg-F.	75	75	75	75	75	75	75	75	75
	TMBTUH	71.0	108.5	32.0	108.5	32.0	108.5	32.0	108.5	32.0
	MIN COIL AREA, sf.	9.4	9.4	3.1	9.4	3.1	9.4	3.1	9.4	3.1
	MAX AIR PD. in. wc. COIL FACE VELOCITY	0.06inwc 293	0.1 389	0.13inwc 458	0.1 389	0.13inwc 458	0.1 389	0.13inwc 458	0.1 389	0.13inwc 458
	FLUID	40% P.G.								
	EWT (F)	180	180	180	180	180	180	180	180	180
	LWT (F)	150	150	150	150	150	150	150	150	150
	FLOW RATE (GPM)	4.7	7.2	2.1	7.2	2.1	7.2	2.1	7.2	2.1
	WPD (FTHD)	0.4	0.7	0.3	0.7	0.3	0.7	0.3	0.7	0.3
DX COOLING COIL	ENT AIR WB (F)	65.3	65.8	65.2	65.8	65.2	65.8	65.2	65.8	65.2
	EAT (F)	77.4	77.9	77.2	77.9	77.2	77.9	77.2	77.9	77.2
	LAT (F)	50.4	49.7	48.8	49.7	48.8	49.7	48.8	49.7	48.8
	DEW POINT (F)	49.2	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6
	TMBTUH	129.7	189.4	70.6	189.4	70.6	189.4	70.6	189.4	70.6
	MRC (lbs H20/hr.) NOMINAL TONS	95.8 10.0	134.2 15.0	51.5 6.0	134.2 15.0	51.5 6.0	134.2 15.0	51.5 6.0	134.2 15.0	51.5 6.0
	MIN COIL AREA, sf.	10.0	10.4	6.5	10.4	6.5	10.4	6.5	10.4	6.5
	MAX AIR PD. in. wc.	0.29inwc	0.48inwc	0.11inwc	0.48inwc	0.11inwc	0.48inwc	0.11inwc	0.48inwc	0.11inwc
	COIL FACE VELOCITY	263	350	213	350	213	350	213	350	213
UNIT EFFICIENCY	MRE (lb/kWh)	9.08	8,65	8.64	8.65	8.64	8,65	8.64	8.65	8.64
	ISMRE270 (See Note 1)	7.32	6,66	6,85	6,66	6,85	6,66	6.85	6.66	6.85
	ISMRE270 Calculation DP (F)	49.2	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6
ELECTRICAL DATA	V-PH-HZ	208-3-60	208-3-60	208-3-60	208-3-60	208-3-60	208-3-60	208-3-60	208-3-60	208-3-60
	UNIT MCA	64.1	82.8	39.2	82.8	39.2	82.8	39.2	82.8	39.2
	MOPD SMOKE DETECTORS	80 CA & BA	100	50 CA * PA	100	50	100	50 CA # PA	100	50
	SMOKE DETECTORS	SA & RA								

NOTES:
1. ISMRE270
AHRI 920-2020 Integrated Seasonal Moisture Removal Efficiency: ISMRE270 calculated at the scheduled specified dew point; see schedule 920 Standard Rating Condition A = 950F DBT, 780F WBT

920 Standard Rating Condition B = 80oF DBT, 73oF WBT

920 Standard Rating Condition C = 70oF DBT, 66oF WBT 920 Standard Rating Condition D = 63oF DBT, 59oF WBT

ISMRE270 A 0.14) + (B * 0.34) + (C * 0.39) + (D * 0.13)

A = MRE70.A @ 95F Entering Condenser Air & 95F DBT/78F WBT Entering the DOAS, maintaining the scheduled Dew Point within +-0.3F & reheat between 70-75

B = MRE70.B @ 80F Entering Condenser Air & 80F DBT/73F WBT Entering the DOAS, maintaining the scheduled Dew Point within +-0.3F & reheat between 70-75

C = MRE70,C @ 70F Entering Condenser Air & 70F DBT/66F WBT Entering the DOAS, maintaining the scheduled Dew Point within +-0.3F & reheat between 70-75

D = MRE70,D @ 63F Entering Condenser Air & 63F DBT/59F WBT Entering the DOAS, maintaining the scheduled Dew Point within +-0.3F & reheat between 70-75

A **REFORM** **CONDENS** **CONDENS**

2. At part-load, defined as OA conditions below a 70F WBT, each DOAS shall deliver between 70-75°F DBT at 45.0F, +/-0.3 supply-air dew point. To validate this performance; Provide computer selection output on manufacturer's offical selection software to confirm each DOAS will deliver between 70-75°F DBT at 45.0F, +/-0.3 supply-air dew point at 0...

3. Provide unit mounted disconnect with single point power for all components.

Unit weight and dimensions do not include curb.
 All DOAS units to have horizontal supply and return duct connecitons.

6. Evaporator, HGR and Condenser Coils shall have factory-applied epoxy polymer e-coating that meets ASTM B117 minimum 6000 hrs salt spray testing requirements.
7. Provide Unit controller, fully programmable, BACnet ready, with color touch screen graphical display. Control points shall be coordinated with BAS supplier.

8. Double wall 2" R13 construction; unit base shall also have Double wall 2" R13 construction.

9. Provide modulating Hot Gas Reheat with 6" gap between the evaporator coil and HGR Coil to prevent re-evaporation back into the airstream, provide space/access for the DX Coil LAT sensor 10. Entire cabinet exterior shall be prepainted.

11. Supply and Exhaust fan piezo rings and transducer shall factory mounted and wired to the unit controller to display CFM.

12. Each condenser fan motor powered by variable frequency drive for active head pressure control

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

CURTIS HALL RENOVATIONS

Maine Maritime Academy, Curtis Hall Pleasant Street, Castine, Maine 04421

No. Date Description

NOT FOR CONSTRUCTION

Revision Schedule

JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING 11/22/2023

TITLE MECHANICAL SCHEDULES

SHEET

M600

					ENERGY RECO	VERY VENTILATOR (ER	V) SCHEDULE					
GENERAL	TAG	ERV-1-11	ERV-1-21	ERV-1-22	ERV-1-31	ERV-1-32	ERV-1-33	ERV-0-41	ERV-0-42	ERV-0-43	ERV-1-41	ERV-1-42
	SERVES	FLR 1 CHAPEL, PHASE 1	FLR 1 BOH, PHASE 2	FLR 1 LOUNGE, PHASE 2	FLR 1 ADMIN, PHASE 3	FLR 1 ADMIN, PHASE 3	FLR 1 SECURITY, PHASE 3	BILGE, PHASE 4	BOOKSTORE, PHASE 4	FLR 1 APT, PHASE 4	FLR 1 SALON, PHASE 4	FLR 1 ADMIN, PHASE 4
	LOCATION	FIRST FLR (1)	FIRST FLR (1)	FIRST FLR (1)	FIRST FLR (1)	FIRST FLR (1)	FIRST FLR (1)	GROUND FLOOR (0)	GROUND FLOOR (0)	GROUND FLOOR (0)	FIRST FLR (1)	FIRST FLR (1)
	TYPE	Enthalpy Core	Enthalpy Core	Enthalpy Core	Enthalpy Core	Enthalpy Core	Enthalpy Core	Enthalpy Core	Enthalpy Wheel	Enthalpy Core	Enthalpy Core	Enthalpy Core
	MFR	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES	ALDES
	MODEL	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N	CW2000i	E650L-Fi-EC-N	E650L-Fi-EC-N	E650L-Fi-EC-N
FILTER SECTION	FILTERS (OA)	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13	MERV 13
	FILTERS SIZE (IN)	_	_	_	_	_	_	_	20 x 20 x 2	_	_	_
	FILTERS (RA)	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8	MERV 8
	FILTERS SIZE (IN)	_	_	_	_	_	_	_	20 x 20 x 2	_	_	_
OUTSIDE AIR FAN	TYPE	ECM	ECM	ECM	ECM	ECM	ECM	ECM	ODP, BI	ECM	ECM	ECM
	AIRFLOW (cfm)	200	300	225	425	225	250	450	1,450	450	440	225
	ESP, in.wc.	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.75inwc	0.50inwc	0.50inwc	0.50inwc
	MOTOR SPEEDS	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VFD	VARIABLE	VARIABLE	VARIABLE
	FAN HP / kW	_	-	_	_	_	_	_	(1) 1HP	_	_	_
XHAUST AIR FAN	TYPE	ECM	ECM	ECM	ECM	ECM	ECM	ECM	ODP, BI	ECM	ECM	ECM
	AIRFLOW (cfm)	200	300	225	425	225	250	450	1,450	450	440	225
	ESP, in.wc.	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.50inwc	0.75inwc	0.50inwc	0.50inwc	0.50inwc
	MOTOR SPEEDS	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VARIABLE	VFD	VARIABLE	VARIABLE	VARIABLE
	FAN HP / kW	_	-	_	_	_	_	_	(1) 1HP	_	_	_
OVERALL DIMENSIONS	LENGTH	41.75"	41.75"	41.75"	41.75"	41.75"	41.75"	41.75"	131.8"	41.75"	41.75"	41.75"
	WIDTH	32.125"	32.125"	32.125"	32.125"	32.125"	32.125"	32.125"	58.4"	32.125"	32.125"	32.125"
	HEIGHT	23,875"	23,875"	23,875"	23,875"	23,875"	23,875"	23,875"	71,2"	23,875"	23,875"	23,875"
	OPERATING WEIGHT, lbs.	150	150	150	150	150	150	150	3,200	150	150	150
HEAT RECOVERY CORE	SUMMER OA DB/WB	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74	87 / 74
	WINTER OA DB	-10	-10	-10	-10	-10	-10	-10	-10	-10	-10	-10
	SUMMER SA DB/WB	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69	79 / 69
	WINTER SA DB	45	45	45	45	45	45	45	45	45	45	45
	SENSIBLE EFFECTIVENESS	75.0%	70.0%	74.0%	63.0%	74.0%	73.0%	62.0%	80% (Total)	62.0%	61.0%	74.0%
	SUMMER TOTAL EFF.	62.0%	56.0%	60.0%	50.0%	60.0%	58.0%	48.0%	82% (Sensible)	48.0%	47.0%	60.0%
	WINTER TOTAL EFF.	73.0%	68.0%	71.0%	60.0%	71.0%	70.0%	58.0%	77% (Latent)	58.0%	57.0%	71.0%
	FROST CONTROL	EXHAUST	EXHAUST	EXHAUST	EXHAUST	EXHAUST	EXHAUST	EXHAUST	RECIRC DAMPER	EXHAUST	EXHAUST	EXHAUST
	CORE BYPASS	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER	INTERNAL DAMPER
HEATING COIL	HYDRONIC COIL TAG	HC-1-11	HC-1-21	HC-1-22	HC-1-31	HC-1-32	HC-1-33	HC-0-41	HC-0-42	HC-0-43	HC-1-41	HC-1-42
ELECTRICAL DATA	V-PH-HZ	208-1-60	208-1-60	208-1-60	208-1-60	208-1-60	208-1-60	208-1-60	208-3-60	208-1-60	208-1-60	208-1-60
	UNIT MCA	3.4	3.4	3.4	3.4	3.4	3.4	3.4	23.2	3.4	3.4	3.4
	MOPD / MOCP	15	15	15	15	15	15	15	25	15	15	15
	SMOKE DETECTORS	NONE	NONE	NONE	NONE	NONE	NONE	NONE	SA & RA	NONE	NONE	NONE

NOTES:

1. UNITS PROVIDED WITH FACTORY VFD'S, PACKAGED CONTROLS AND DISCONNECT SWITCH.

2. WEIGHT AND DIMENSIONS DO NOT INCLUDE CURB INFORMATION.

			HEA	AT EXCHANG	ER SCH	HEDULE	- STEAM	M TO W	ATER CO	ONVERTE	R				
									HEATED F	LUID					
TAG	MFR-MODEL	LOCATION	SERVICE	STEAM INLET PRESS PSIG	STEAM LBS/HR	GPM	% PROP GLYCOL	E.W.T. DEG F	L.W.T. DEG F	P.D. (FT HD)	TUBE VEL (FPS)	МВН	PASSES	SHELL DIA	OVERALL LENGTH
HEX-H1	TACO E16206-S	BLR RM MEZZ	HWS/R	15	1,759	210	0	160	180	0.12	1.7	2,100,000	2	16"	36"
HEX-H2	TACO E16206-S	BLR RM MEZZ	HWS/R	15	1,759	210	0	160	180	0.12	1.7	2,100,000	2	16"	36"
HEX-G	TACO E12206-S	BLR RM MEZZ	GWS/R	15	817	65	40	150	180	0.06	1.04	975,000	2	12"	36"

						FAN S	CHED	ULE							
										ELECT	RICAL REQUIREM	ENTS			
TAG	SERVES	MFR.	MODEL	TYPE	DRIVE	CFM	ESP	MCA	HP	MOTOR TYPE	SPEED CONTROL	DISC. SWITCH	VOLTS / PH / HZ	(LBS.)	NOTES
DEF-R-1	DRYER EXHAUST, PHASE 1	ENERVEX	BEF-450x	BOX VENTILATOR	DIRECT	1,200	2,0"	8,9	2,3	ECM	STACK PRESSURE	D [V 26	208/3/60	143	1, 2
DEF-R-2	DRYER EXHAUST, PHASE 2	ENERVEX	BEF-450x	BOX VENTILATOR	DIRECT	1,200	2.0"	8.9	2.3	ECM	STACK PRESSURE	DIV 26	208/3/60	143	1, 2
DEF-R-3	DRYER EXHAUST, PHASE 3	ENERVEX	BEF-450x	BOX VENTILATOR	DIRECT	1,200	2.0"	8.9	2.3	ECM	STACK PRESSURE	DIV 26	208/3/60	143	1, 2
DEF-R-4	DRYER EXHAUST, PHASE 4	ENERVEX	BEF-450x	BOX VENTILATOR	DIRECT	1,200	2.0"	8.9	2.3	ECM	STACK PRESSURE	DIV 26	208/3/60	143	1, 2

NOTE:

1. FAN POWER FED FROM EBC-31 MODULATING CONTROLLER (0-10V).

2. PROVIDE OFFSET STACK HIGH PLUME DISCHARGE FOR DRYER EXHAUST APPLICATION.

										FLU	JID = 40% I	P.G.	
TAG	SERVES	AIRFLOW CFM	LENGTH IN.	HEIGHT IN.	FACE VEL FPM	EDB °F	LDB °F	MBH	MAX APD	GPM	EWT °F	LWT °F	WPI
HC-1-11	ERV-1-11	200	10	8	360	45	75	6.5	0.1"	0.4	180	150	3'
HC-1-21	ERV-1-21	300	12	8	450	45	75	9.7	0.1"	0,6	180	150	3'
HC-1-22	ERV-1-22	225	10	8	405	45	75	7,3	0,1"	0,5	180	150	3'
HC-1-31	ERV-1-31	425	14	10	437	45	75	13.8	0.1"	0.9	180	150	3'
HC-1-32	ERV-1-32	225	10	8	405	45	75	7.3	0.1"	0.5	180	150	3'
HC-1-33	ERV-1-33	250	10	8	450	45	75	8.1	0.1"	0.5	180	150	3'
HC-0-41	ERV-0-41	450	14	10	463	45	75	14.6	0.1"	1.0	180	150	31
HC-0-42	ERV-0-42	1,400	24	18	467	45	75	45.4	0.1"	3.0	180	150	3'
HC-0-43	ERV-0-43	450	14	10	463	45	75	14.6	0.1"	1.0	180	150	3'
HC-1-41	ERV-1-41	475	14	10	489	45	75	15.4	0.1"	1.0	180	150	3'
HC-1-42	ERV-1-42	225	10	8	405	45	75	7,3	0.1"	0,5	180	150	31
	TOTALS	4.625						149.9		10.0			

			EXH	IAUST C	APTURE S	CHEDUI	.E							
TAG	TYPE	MANUFACTURER	MODEL	SERVES	WIDTH (L-R)	DEPTH	HE I GHT	CFM	SP.	DUCT CONN.	ELEC.	AMPS	WEIGHT	NOTES
H-1	RECIRCULATING FIRE PROTECTION RANGE HOOD	DENLAR	D1036-F-NFPA	RANGE	36"	19,38"	14,8"	500		FRONT - RECIRCULATING	120/1/60	3,7	57 LBS.	1,2,3,4

NOTES:

1. INTEGRATED FIRE SUPPRESSION SYSTEM
2. MANUAL PULL STATION NT W: 25FT CABLE
3. NFPA 101 COMPILANCE
4. PROVIDE W: CLOCK-BOX PRO, ADA SWITCHES, ELECTRICAL DISCONNECT, HORN & STROBE

				HYD	RONIC PL	JMP S	CHED	JLE									
						PE	RFORMAN	CE			ELECTI	RICAL		ELECT	RICAL COORD	NOTANI	
TAG	SYSTEM	MFR.	MODEL	TYPE	PUMPED FLU I D	GPM TOTAL	GPM / PUMP	HEAD	BHP	MOTOR HP	RPM	MCA / MOCP	VOLTS/PH (60 Hz.)	STARTER TYPE	STARTER FURN. BY	DISC. SWITCH FURN BY	NOTES
							140		3.86	7.5	3013						
P-H1	HWS/R	GRUNDFOS	HYDRO MPC-E-3CRE-32-2-2	PACKAGED TRIPLEX INTEGRAL VARIABLE SPEED	WATER	280	140	79.36	3.86	7.5	3013	78.7 / 90	208/3	INTEGRAL	DIV 23	DIV 23	1
							140		3,86	7.5	3013						
P-G1	GWS/R	GRUNDFOS	HYDRO MPC E-2CRE-15-2	PACKAGED DUPLEX INTEGRAL VARIABLE SPEED	40% P.G.	65	65	74.57	1.76	5	2933	37.6 / 45	208/3	INTEGRAL	DIV 23	DIV 23	_
1-01	GVIGIN	GKUNDI OS	PACINGED DUFFEX INTEGRAL VARIABLE SFEED	40.61.0.	"	65	14,31	1,76	5	2933	37.07 43	200/3	INTEGRAL	DIV 23	DIV 23		

NOTES:

1. PACKAGED PUMP SYSTEM, SINGLE POINT POWER AT CONTROL PANEL, SIZE AND SET UP FOR 50-50-50, TWO PUMPS RUN + ONE STANDBY.

2. PACKAGED PUMP SYSTEM, SINGLE POINT POWER AT CONTROL PANEL, SIZE AND SET UP FOR 100-100, ONE PUMP RUNS + ONE STANDBY.

			HYDRO	NIC FINNED TUBE	RADIA	TION SC	HEDL	JLE						
TAG	STERLING MODEL	DESCRIPTION	ENCLOSURE HE I GHT	MOUNTING HEIGHT, TOP OF ENCLOSURE	DEPTH FROM WALL	No. OF TIERS	FLOW (GPM)	EAT (°F)	AWT (*F)	BTU / FT	ELEMENT	FIN SIZE (HxW)	FINS / FT	NOTES
FT-1	VERSA-LINE JVB-SS19	COMMERCIAL, DOUBLE SLOPE TOP	19-1/2"	TIGHT TO CEILING	5-5/16"	1	1.0	65	170	970	3/4" COPPER / ALUM	3-5/8"x4-1/4"	50	
FT-2	VERSA-LINE JVB-S14	COMMERCIAL, SLOPE TOP	14"	18"	5-5/16"	1	1.0	65	170	1,120	3/4" COPPER / ALUM	3-5/8"x4-1/4"	50	
FT-3	VERSA-LINE BARE-"A"	COMMERCIAL, BARE ELEMENT	N/A	N/A	N/A	1	4.0	65	170	700	3/4" COPPER / ALUM	3-1/4"x3-1/4"	50	

NOTES: 1. PROVIDE RETURNS WITHIN ENCLOSURE WHERE APPLICABLE.

						LO	UVER / V	VALL (CAP SCH	EDULE							
									DIMENS	ONS				BEGINNING POINT OF			
TAG	MAKE - MODEL	TYPE	AIR SYSTEMS	DUTY (INTAKE / EXHAUST)	MAX CFM	OPENING HEIGHT (IN.)	OPENING WIDTH (IN.)	DUCT DIAM. (IN.)	MIN. FREE AREA (SF)	GROSS VELOCITY (FT/MIN)	NET VELOCITY (FT/MIN)	% FREE AREA	BLADE DEPTH	WATER PENETRATION AT 0.01 OZ/SF	MAX P.D. I.N.W.C.	SCREEN	NOTE
L-1	AWV LE-53	LOUVER	ERV-0-11	EXHAUST	2,750	60	24		3.85	275	714	39%	4"	873 FPM	0.01	SEE 233113	
L-2	AWV LE-53	LOUVER	ERV-0-42 & 043	EXHAUST	1,850	48	24		3.04	231	609	38%	4"	873 FPM	0,01	SEE 233113	
WC-1	ALDES 22312	WALL HOOD	ERVs	INTAKE	475	12	15	12	0.78	380	609	62%				SEE 233113	
WC-2	ALDES 22312	WALL HOOD	ERVs	EXHAUST	475	12	15	12	0,78	380	609	62%				SEE 233113	

					GL\	COL FEED	SYSTEM			
TAG	AG NEPTUNE MODEL	CAPACITY	HWS SYSTEM PUMP	DISCH PRESSURE	PUMP HP	BECEN/EB CAL	INLET / DISCH SIZE		ELECTR I CA	L COORDINATION
IAG		SF-EDR	GPM	DISCH PRESSURE	FOWE HE	RECEIVER GAL	INCET / DISCH SIZE	STARTER FURN. BY	V-PH-HZ	DISC. SWITCH FURN BY
GF-1	G50-2A	6000	1,5	100	2 @ 1/2	50	1/2"	PACKAGED WITH UNIT	120/1/60	8FT POWER CORD W/PLUG FURN, W/UNIT

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is not permitted without written permission of CHA Architecture.

CURTIS HALL RENOVATIONS
Maine Maritime Academy, Curtis Hall
1 Pleasant Street, Castine, Maine 04421

No. Date Description Revision Schedule

NOT FOR CONSTRUCTION

ISSUE 100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE MECHANICAL SCHEDULES

SHEET

M601

		LE REFRIGERAN			CAPACITY		RECTED CAP	
TAG	RM #	ROOM NAME	HP SIZE	COOLING	HEATING	COOLING TOTAL	COOLING SENSIBLE	HEATIN MINIMU
HP4 1-11 HP4 1-12	470 469	BDRM BDRM	B	6,000 6.000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP4 1-13	468	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 1-14	467	BDRM	D	12,000	13,500	8,700	6,700 4,650	7,950
HP4 1-15	466 465	BDRM BDRM	В	8,000 6,000	9,000 6,700	5,750 4,250	3,550	5,300 4,450
IP4 1-17	464	BDRM	В	6,000	6,700	4,250	3,550	4,450
IP4 1-18	463	BDRM	С	8,000	9,000	5,750	4,650	5,300
CU4 1-1	400	estimated CU total loads	_	2.000	0.000	41,450	33,750	40,800
HP4 1-21	462 461	BDRM BDRM	C B	8,000 6.000	9,000	5,750 4.250	4,650 3.550	5,300 4.450
HP4 1-23	460	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 1-24		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 1-25	454 453	BDRM BDRM	C	8,000 8,000	9,000	5,750 5,750	4,650 4,650	5,300 5,300
IP4 1-27	450	BDRM	c	8,000	9,000	5,750	4,650	5,300
HP4 1-28	449	BDRM	D	12,000	13,500	8,700	6,700	7,950
CU4 1-2		estimated CU total loads				44,450	35,950	42,500
HP4 1-31	451 452	BDRM BDRM	C D	8,000 12.000	9,000	5,750 8,700	4,650 6,700	5,300 7.950
IP4 1-33	455	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP4 1-34	456	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP4 1-35	457	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 1-36	458 472	BDRM BDRM	C	8,000 8,000	9,000	5,750 5,750	4,650 4,650	5,300 5,300
HP4 1-38	471	BDRM	A	4,000	4,500	2.800	2.400	2,600
CU4 1-3		estimated CU total loads		.,	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	44,500	35,900	41,500
HP4 2-11	446	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 2-12	445 444	BDRM	B	6,000	6,700	4,250 4,250	3,550 3,550	4,450
HP4 2-13	444	BDRM BDRM	D D	6,000 12.000	6,700 13,500	4,250 8,700	3,550 6,700	4,450 7,950
HP4 2-15	442	BDRM	C	8,000	9,000	5,750	4,650	5,300
IP4 2-16	441	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 2-17	440	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 2-18	439	BDRM estimated CU total loads	С	8,000	9,000	5,750 41.450	4,650 33,750	5,300 40.800
HP4 2-21	438	BDRM	С	8,000	9,000	5,750	4,650	5,300
IP4 2-22	437	BDRM	В	6,000	6,700	4,250	3,550	4,450
IP4 2-23	436	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 2-24 HP4 2-25	435		В	6,000 8,000	6,700 9.000	4,250 5,750	3,550 4,650	4,450
HP4 2-26	429	BDRM	C	8,000	9,000	5,750 5.750	4,650	5,300 5.300
IP4 2-27	426	BDRM	С	8,000	9,000	5,750	4,650	5,300
IP4 2-28	425	BDRM	D	12,000	13,500	8,700	6,700	7,950
DU4 2-2 HP4 2-31	427	estimated CU total loads	С	0.000	9.000	44,450 5,750	35,950 4,650	42,500 5.300
1P4 2-31	428	BDRM BDRM	D	8,000 12,000	13,500	8,700	6,700	7,950
HP4 2-33	431	BDRM	c	8,000	9,000	5,750	4,650	5,300
HP4 2-34	432	BDRM	С	8,000	9,000	5,750	4,650	5,300
1P4 2-35	433	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 2-36 HP4 2-37	434	BDRM BDRM	C	8,000 8.000	9,000	5,750 5.750	4,650 4.650	5,300 5.300
IP4 2-38	448	BDRM	A	4,000	4,500	2,800	2,400	2,600
CU4 2-3		estimated CU total loads				44,500	35,900	41,500
HP4 3-11 HP4 3-12	422 421	BDRM BDRM	B	6,000 6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP4 3-13	420	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 3-14	419	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP4 3-15	418		С	8,000	9,000	5,750	4,650	5,300
HP4 3-16 HP4 3-17	417	BDRM BDRM	B B	6,000	6,700	4,250 4,250	3,550 3,550	4,450 4.450
1P4 3-17	415	BDRM	C	6,000 8,000	6,700 9,000	5,750	4.650	5,300
CU4 3-1		estimated CU total loads		0,000	0,000	41,450	33,750	40,800
HP4 3-21	414	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP4 3-22	413	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 3-23	412 411	BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
IP4 3-25	406		C	8,000	9,000	5,750	4,650	5,300
HP4 3-26	405	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP4 3-27	402	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP4 3-28	401	BDRM estimated CU total loads	D	12,000	13,500	8,700 44.450	6,700 35,950	7,950 42.500
HP4 3-31	403	BDRM	С	8,000	9,000	5,750	4,650	5,300
IP4 3-32	404	BDRM	D	12,000	13,500	8,700	6,700	7,950
IP4 3-33		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP4 3-34	408	BDRM BDRM	C B	8,000 6,000	9,000 6,700	5,750 4,250	4,650 3,550	5,300 4.450
IP4 3-35		BDRM	C	8,000	9,000	5,750	4,650	5,300
IP4 3-37	423	BDRM	С	8,000	9,000	5,750	4,650	5,300
IP4 3-38	424	BDRM	Α	4,000	4,500	2,800	2,400	2,600
DU4 3-3 IP4 4-11	492	estimated CU total loads BDRM	С	8.000	9,000	44,500 5,750	35,900 4,650	41,500 5,300
1P4 4-11	492	BDRM	В	6,000	6,700	4,250	3,550	5,300 4,450
IP4 4-13	490	BDRM	В	6,000	6,700	4,250	3,550	4,450
IP4 4-16	489		В	6,000	6,700	4,250	3,550	4,450
IP4 4-17	488	BDRM BDRM	В	6,000 8,000	6,700	4,250 5,750	3,550 4,650	4,450 5,300
IP4 4-18	487	BDRM estimated CU total loads	С	0,000	9,000	5,750 28,500	4,650 23,500	5,300 28,400
IP4 4-21	486	BDRM	С	8,000	9,000	5,750	4,650	5,300
IP4 4-22	485	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP4 4-23	484		В	6,000	6,700	4,250	3,550	4,450
HP4 4-24	483	BDRM BDRM	B C	6,000 8.000	6,700 9.000	4,250 5.750	3,550 4,650	4,450 5.300
1P4 4-25		BDRM	c	8,000	9,000	5,750	4,650	5,300
HP4 4-27	474	BDRM	С	8,000	9,000	5,750	4,650	5,300
1P4 4-28	473		D	12,000	13,500	8,700	6,700	7,950
DU4 4-2 HP4 4-31	475	estimated CU total loads BDRM	С	8,000	9,000	44,450 5,750	35,950 4,650	42,500 5,300
1P4 4-31 1P4 4-32	475	BDRM	D	12,000	13,500	5,750 8,700	6,700	7,950
HP4 4-33	480	BDRM	c	8,000	9,000	5,750	4,650	5,300
HP4 4-34	479		С	8,000	9,000	5,750	4,650	5,300
HP4 4-35	481	BDRM BDRM	В	6,000	6,700	4,250	3,550 4.650	4,450
HP4 4-36	482 494	BDRM	C	8,000 8,000	9,000 9,000	5,750 5,750	4,650 4,650	5,300 5,300
IP4 4-38	493		A	4,000	4,500	2,800	2,400	2,600
		estimated CU total loads				44.500	35,900	41,500

	VAF	RIAB	LE REFRIGERA	NT FL	OW (VRF) I	NDOOR UN	IT SIZE SC	HEDULE - 3	rd FLR
L_	AG	RM #	ROOM NAME	HP SIZE	NOMINAL COOLING	CAPACITY HEATING	COOLING	COOLING	ACITY HEATING
							TOTAL	SENSIBLE	MINIMUM
	1-11		BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550	4,450 4.450
HP3		368	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		367	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP3		366 365	BDRM BDRM	C B	8,000 6.000	9,000	5,750 4,250	4,650 3.550	5,300 4.450
	1-17		BDRM	В	6,000	6,700	4,250	3,550	4,450
	1-18	363	BDRM	С	8,000	9,000	5,750	4,650	5,300
CU3		362	estimated CU total loads BDRM	С	8.000	9.000	41,450 5,750	33,750 4.650	40,800 5,300
HP3		361	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		360	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		359 354	BDRM	В	6,000	6,700	4,250	3,550	4,450 5,300
	1-25	353	BDRM BDRM	C	8,000 8,000	9,000	5,750 5.750	4,650 4,650	5,300
	1-27	350	BDRM	c	8,000	9,000	5,750	4,650	5,300
HP3		349	BDRM	D	12,000	13,500	8,700	6,700	7,950
CU3		351	estimated CU total loads BDRM	С	8.000	9.000	44,450 5.750	35,950 4,650	42,500 5,300
HP3		352	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP3		355	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3	1-34	356 357	BDRM BDRM	C B	8,000 6,000	9,000	5,750 4,250	4,650 3.550	5,300 4,450
HP3		358	BDRM	C	8.000	6,700 9.000	5,750	4.650	5,300
HP3		372	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3		371	BDRM estimated CU total loads	A	4,000	4,500	2,800 44.500	2,400 35.900	2,600 41.500
HP3		346	BDRM	В	6.000	6,700	44,500	35,900	41,500
HP3	2-12	345	BDRM	В	6,000	6,700	4,250	3,550	4,450
	2-13	344	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		343 342	BDRM BDRM	D	12,000 8,000	13,500 9,000	8,700 5,750	6,700 4,650	7,950 5,300
HP3		341	BDRM	В	6,000	6,700	4,250	3,550	4,450
	2-17	340	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		339	BDRM estimated CU total loads	С	8,000	9,000	5,750 41,450	4,650 33.750	5,300 40.800
HP3		338	BDRM	С	8,000	9,000	41,450 5,750	33,750 4,650	40,800 5,300
HP3	2-22	337	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		336	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3	2-24	335	BDRM BDRM	B C	6,000 8.000	6,700 9.000	4,250 5.750	3,550 4.650	4,450 5.300
	2-26	329	BDRM	C	8,000	9,000	5,750	4,650	5,300
	2-27		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3		325	BDRM estimated CU total loads	D	12,000	13,500	8,700 44,450	6,700 35.950	7,950 42.500
HP3		327	BDRM	С	8,000	9,000	5.750	4.650	5.300
НР3		328	BDRM	D	12,000	13,500	8,700	6,700	7,950
	2-33	331	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3		332	BDRM BDRM	C B	8,000 6.000	9,000 6,700	5,750 4,250	4,650 3.550	5,300 4.450
HP3		334	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP3		347	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3		348	BDRM estimated CU total loads	A	4,000	4,500	2,800 44,500	2,400 35.900	2,600 41,500
HP3		322	BDRM	В	6,000	6,700	4,250	3,550	4,450
	3-12	321	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3	3-13	320	BDRM BDRM	B D	6,000	6,700 13.500	4,250 8.700	3,550 6.700	4,450 7.950
HP3		318	BDRM	C	8.000	9.000	5.750	4.650	5.300
HP3		317	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		316	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		315	BDRM estimated CU total loads	С	8,000	9,000	5,750 41,450	4,650 33,750	5,300 40,800
HP3	3-21	314	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3		313	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3		312	BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4.450
HP3		306	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP3		305	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3	3-27	302	BDRM BDRM	C D	8,000 12,000	9,000	5,750 8,700	4,650 6,700	5,300 7,950
CUS		301	estimated CU total loads	-	12,000	13,500	44,450	35,950	42.500
HP3		303	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3			BDRM BDRM	D C	12,000 8.000	13,500 9.000	8,700 5,750	6,700 4,650	7,950 5,300
	3-33		BDRM	C	8,000	9,000	5,750	4,650 4.650	5,300
HP3	3-35	309	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP3	3-36	310	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3	3-37		BDRM BDRM	C A	8,000 4,000	9,000 4,500	5,750 2,800	4,650 2,400	5,300 2,600
CU3	3-3	524	estimated CU total loads		7,000	7,000	44,500	35,900	41,500
HP3	4-11		BDRM	С	8,000	9,000	5,750	4,650	5,300
	4 - 12		BDRM BDRM	B	6,000	6,700	4,250 4,250	3,550 3,550	4,450 4,450
	4-13		BDRM	В	6,000	6,700 6,700	4,250 4,250	3,550	4,450
HP3	4-17	388	BDRM	В	6,000	6,700	4,250	3,550	4,450
	4-18	387	BDRM	С	8,000	9,000	5,750	4,650	5,300
	4-1	386	estimated CU total loads BDRM	С	8,000	9,000	28,500 5,750	23,500 4,650	28,400 5,300
	4-22		BDRM	В	6,000	6,700	4,250	3,550	4,450
	4-23	384	BDRM	В	6,000	6,700	4,250	3,550	4,450
	4-24	383 377	BDRM BDRM	B C	6,000 8,000	6,700 9,000	4,250 5,750	3,550 4,650	4,450 5,300
HP3	4-26		BDRM	C	8,000	9,000	5,750	4,650	5,300
HP3 HP3		374	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP3 HP3 HP3		070	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP3 HP3 HP3 HP3	4-28	3/3	estimated CU total loads	С	8.000	9,000	44,450 5,750	35,950 4,650	42,500 5,300
HP3 HP3 HP3 HP3 CU3	4-28 4-2		BDRM			13.500	8.700	6.700	7.950
HP3 HP3 HP3 HP3 CU3 HP3	4-28 4-2 4-31 4-32	375 376	BDRM BDRM	D	12,000				
HP3 HP3 HP3 HP3 CU3 HP3 HP3	4-28 4-2 4-31 4-32 4-33	375 376 380	BDRM BDRM	D C	8,000	9,000	5,750	4,650	5,300
HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3	4-28 4-2 4-31 4-32 4-33 4-34	375 376 380 379	BDRM BDRM BDRM	C C	8,000 8,000	9,000 9,000	5,750 5,750	4,650 4,650	5,300 5,300
HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3	4-28 4-2 4-31 4-32 4-33	375 376 380 379 381	BDRM BDRM	D C	8,000	9,000	5,750	4,650	5,300
HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3	4-28 4-2 4-31 4-32 4-33 4-34 4-35 4-36 4-37	375 376 380 379 381 382 394	BDRM BDRM BDRM BDRM BDRM BDRM BDRM	C C C	8,000 8,000 6,000 8,000 8,000	9,000 9,000 6,700 9,000 9,000	5,750 5,750 4,250 5,750 5,750	4,650 4,650 3,550 4,650 4,650	5,300 5,300 4,450 5,300 5,300
HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3	4-28 4-2 4-31 4-32 4-33 4-34 4-35 4-36 4-37 4-38	375 376 380 379 381 382 394	BDRM BDRM BDRM BDRM BDRM BDRM BDRM BDRM	C C B C	8,000 8,000 6,000 8,000	9,000 9,000 6,700 9,000	5,750 5,750 4,250 5,750 5,750 2,800	4,650 4,650 3,550 4,650 4,650 2,400	5,300 5,300 4,450 5,300 5,300 2,600
HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3 HP3	4-28 4-2 4-31 4-32 4-33 4-34 4-35 4-36 4-37 4-38 4-3	375 376 380 379 381 382 394	BDRM BDRM BDRM BDRM BDRM BDRM BDRM	C C C	8,000 8,000 6,000 8,000 8,000	9,000 9,000 6,700 9,000 9,000	5,750 5,750 4,250 5,750 5,750	4,650 4,650 3,550 4,650 4,650	5,300 5,300 4,450 5,300 5,300

		LE REFRIGERAN			CAPACITY		RECTED CAP	
TAG	RM #	ROOM NAME	HP S I ZE	COOLING	HEATING	COOLING TOTAL	COOLING SENSIBLE	HEATING MINIMUM
HP2 1-11		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 1-12 HP2 1-13		BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4.450
HP2 1-14		BDRM	D	12,000	13,500	8,700	6,700	7,950
HP2 1-15 HP2 1-16		BDRM BDRM	C B	8,000 6,000	9,000 6,700	5,750 4,250	4,650 3,550	5,300 4,450
HP2 1-17		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 1-18	263	BDRM	С	8,000	9,000	5,750	4,650	5,300
CU2 1-1 HP2 1-21	262	estimated CU total loads BDRM	С	8,000	9.000	41,450 5,750	33,750 4.650	40,800
HP2 1-21		BDRM	В	6,000	6,700	4,250	3,550	5,300 4,450
HP2 1-23		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 1-24 HP2 1-25		BDRM BDRM	B C	6,000 8,000	6,700 9,000	4,250 5,750	3,550 4,650	4,450 5,300
HP2 1-26	253	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP2 1-27		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 1-28 CU2 1-2	249	BDRM estimated CU total loads	D	12,000	13,500	8,700 44,450	6,700 35.950	7,950 42,500
HP2 1-31	251	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 1-32		BDRM BDRM	D C	12,000 8,000	13,500 9,000	8,700 5,750	6,700 4.650	7,950 5,300
HP2 1-33 HP2 1-34	256	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP2 1-35		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 1-36 HP2 1-37		BDRM BDRM	C	8,000 8,000	9,000	5,750 5,750	4,650 4,650	5,300 5,300
HP2 1-37 HP2 1-38		BDRM	A	4,000	4,500	2.800	2,400	2,600
CU2 1-3		estimated CU total loads				44,500	35,900	41,500
HP2 2-11		BDRM	B	6,000	6,700	4,250	3,550	4,450
HP2 2-12 HP2 2-13		BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP2 2-14	243	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP2 2-15		BDRM	C	8,000 6,000	9,000 6,700	5,750	4,650	5,300
HP2 2-16 HP2 2-17		BDRM BDRM	B B	6,000	6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP2 2-18		BDRM	C	8,000	9,000	5,750	4,650	5,300
CU2 2-1 HP2 2-21	220	estimated CU total loads BDRM	С	8.000	9.000	41,450 5.750	33,750 4,650	40,800 5.300
HP2 2-21		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 2-23	200	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 2-24 HP2 2-25		BDRM BDRM	B C	6,000	6,700 9,000	4,250	3,550 4.650	4,450
HP2 2-26		BDRM	C	8,000	9,000	5,750 5,750	4,650	5,300 5,300
HP2 2-27		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 2-28 CU2 2-2	225	BDRM estimated CU total loads	D	12,000	13,500	8,700 44,450	6,700 35.950	7,950 42.500
HP2 2-31	227	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 2-32		BDRM	D	12,000	13,500	8,700	6,700	7,950
HP2 2-33 HP2 2-34		BDRM BDRM	C	8,000 8,000	9,000	5,750 5,750	4,650 4,650	5,300 5,300
HP2 2-35		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 2-36		BDRM	C	8,000	9,000	5,750	4,650	5,300
HP2 2-37 HP2 2-38		BDRM BDRM	C A	8,000 4,000	9,000 4,500	5,750 2.800	4,650 2,400	5,300 2,600
CU2 2-3		estimated CU total loads		1,000	1,000	44,500	35,900	41,500
HP2 3-11	222	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 3-12 HP2 3-13		BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP2 3-14	219	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP2 3-15 HP2 3-16		BDRM BDRM	C B	8,000 6,000	9,000 6,700	5,750 4,250	4,650 3,550	5,300 4,450
HP2 3-17		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 3-18	215	BDRM	С	8,000	9,000	5,750	4,650	5,300
CU2 3-1 HP2 3-21	21.4	estimated CU total loads BDRM	С	8,000	9.000	41,450 5,750	33,750 4.650	40,800 5,300
HP2 3-22		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 3-23		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 3-24		BDRM BDRM	B C	6,000 8.000	6,700 9,000	4,250 5.750	3,550 4,650	4,450 5,300
HP2 3-25 HP2 3-26		BDRM	C	8,000	9,000	5,750 5,750	4,650	5,300 5,300
HP2 3-27	202	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 3-28 CU2 3-2	201	BDRM estimated CLI total loads	D	12,000	13,500	8,700 44.450	6,700 35,950	7,950 42,500
HP2 3-31		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 3-32	204	BDRM	D	12,000	13,500	8,700	6,700	7,950
HP2 3-33 HP2 3-34		BDRM BDRM	C	8,000	9,000	5,750 5.750	4,650 4.650	5,300 5.300
HP2 3-35	209	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 3-36	210	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 3-37 HP2 3-38		BDRM BDRM	C A	8,000 4,000	9,000 4,500	5,750 2,800	4,650 2,400	5,300 2,600
CU2 3-3		estimated CU total loads				44,500	35,900	41,500
HP2 4-11		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 4-12 HP2 4-13		BDRM BDRM	B B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP2 4-16	289	BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 4-17		BDRM	В	6,000	6,700	4,250	3,550	4,450 5,300
HP2 4-18 CU2 4-1	287	BDRM estimated CU total loads	С	8,000	9,000	5,750 28,500	4,650 23,500	5,300 28,400
HP2 4-21		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 4-22		BDRM	В	6,000	6,700	4,250	3,550	4,450
HP2 4-23 HP2 4-24		BDRM BDRM	B	6,000	6,700 6,700	4,250 4,250	3,550 3,550	4,450 4,450
HP2 4-25	277	BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 4-26		BDRM	С	8,000	9,000	5,750	4,650	5,300
HP2 4-27 HP2 4-28		BDRM BDRM	D D	8,000 12,000	9,000 13,500	5,750 8,700	4,650 6.700	5,300 7,950
CU2 4-28	213	estimated CU total loads	-	12,000	10,000	44,450	35,950	42,500
HP2 4-31		BDRM	С	8,000	9,000	5,750	4,650	5,300
		BDRM BDRM	D C	12,000 8.000	13,500 9.000	8,700 5,750	6,700 4.650	7,950 5,300
HP2 4-32		BDRM	C	8,000	9,000	5,750	4,650	5,300
HP2 4-32 HP2 4-33 HP2 4-34			В	6,000	6,700	4,250	3,550	4,450
HP2 4-33 HP2 4-34 HP2 4-35	281	BDRM						
HP2 4-33 HP2 4-34 HP2 4-35 HP2 4-36	281 282	BDRM	C	8,000	9,000	5,750	4,650	5,300
HP2 4-33 HP2 4-34 HP2 4-35	281 282 294					5,750 5,750 2,800		

	RM		HP	NOMINAL	CAPACITY	COR	RECTED CAPA	ACITY
TAG	#	ROOM NAME	SIZE	COOLING	HEATING	COOLING TOTAL	COOLING SENSIBLE	HEATING MINIMUN
HP0 1-11	011	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP0 1-12	010	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP0 1-13	009	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP0 1-14	008	BDRM	D	12,000	13,500	5,750	6,700	7,950
HP0 1-15	007	BDRM	С	8,000	9,000	4,250	4,650	5,300
HP0 1-16	006	BDRM	В	6,000	6,700	2,800	3,550	4,450
CU0 1-1		estimated CU total loads				21,200	25,550	31,050
HP0 1-21	005	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP0 1-22	004	BDRM	С	8,000	9,000	4,250	4,650	5,300
HP0 1-23	003	BDRM	D	12,000	13,500	5,750	6,700	7,950
HP0 1-24	002	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP0 1-25	001	BDRM	В	6,000	6,700	2,800	3,550	4,450
CU0 1-2		estimated CU total loads				18,400	22,000	26,600
HP1 1-11	112	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP1 1-12	111	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP1 1-13	110	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP1 1-14	109	BDRM	D	12,000	13,500	5,750	6,700	7,950
HP1 1-15	108	BDRM	С	8,000	9,000	4,250	4,650	5,300
HP1 1-16	107	BDRM	В	6.000	6,700	2.800	3,550	4,450
CU1 1-1		estimated CU total loads				21,200	25,550	31,050
HP1 1-21	106	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP1 1-22	105	BDRM	С	8,000	9,000	4,250	4,650	5,300
HP1 1-23	104	BDRM	D	12,000	13,500	5,750	6,700	7,950
HP1 1-24	103	BDRM	В	6.000	6.700	2.800	3.550	4,450
HP1 1-25	102	BDRM	В	6,000	6,700	2,800	3,550	4,450
HP1 1-26	101	BDRM	В	6,000	6,700	2,800	3,550	4,450
CU1 1-2		estimated CU total loads			i	21,200	25,550	31,050
	1403		Е	5,500	6,300	8,700	5,345	5,275
HP1 4-12	1405	APARTMENT KITCHEN	F	11,000	12,300	5,345	8,225	10,350
HP1 4-13		APARTMENT	E	5,500	6,300	8,700	5,345	5,275
CU1 4-1		estimated CU total loads			· ·	22,745	18,915	20,900
HP1 4-21	115	HEALTH SERVICES	С	8.000	9,000	4.250	4.650	5,300
HP1 4-22	114	HEALTH SERVICES	C	8,000	9,000	4,250	4,650	5,300
HP1 4-23		HEALTH SERVICES	D	12.000	13.500	5.750	6.700	7.950
HP1 4 - 24		HEALTH SERVICES	C	8.000	9.000	4.250	4.650	5,300
HP1 4-25		HEALTH SERVICES	C	8.000	9.000	4,250	4,650	5,300
CU1 4-2		estimated CU total loads		2,500	2,500	22,750	25,300	29,150

CURTIS HALL RENOVATIONS Maine Maritime Academy, Curtis Hall 1 Pleasant Street, Castine, Maine 04421

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is not permitted without written permission of CHA Architecture.

No. Date Description

NOT FOR CONSTRUCTION

Revision Schedule

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE MECHANICAL SCHEDULES

SHEET

M602

	VARIABLE REFRIGERANT FLOW (VRF) - INDOOR UNIT PERFORMANCE SCHEDULE																	
HP	NOMINA	AL BTUH	COF	RRECTED B	TUH	RL/RG	COND.	PEAK FAN	ELECTRIC	CAL RE	QUIRE	MENTS		DIN	/IENSIC	NS	TRANE MODEL	MEIGLIT
	COOLING	HEATING		COOLING SENSIBLE			PIPE SIZE (IN)	AIRFLOW (CFM)	V / PH / HZ	MCA	MFS	DISC. BY	TYPE	W (IN)	D (IN)	H (IN)		(LB)
Α	4,000	4,500	2,800	2,400	2,600	1/4 / 1/2	5/8" ID	191	208/1/60	0,24	15						TPKFYP004LM140A	
В	6,000	6,700	4,250	3,550	4,450	1/4 / 1/2	5/8" ID	191	208/1/60	0,24	15						TPKFYP006LM140A	
С	8,000	9,000	5,750	4,650	5,300	1/4 / 1/2	5/8" [D	237	208/1/60	0.24	15	DIV 26	WALL MNTD	30-7/16	9-11/32	11-25/	TPKFYP008LM140A	25
D	12,000	13,500	8,700	6,700	7,950	1/4 / 1/2	5/8" I D	297	208/1/60	0.24	15	DIV 26	WALL MNTD	30-7/16	9-11/32	11-25/	TPKFYP012LM140A	25
E	5,500	6,300	5,345	5,345	5,275	1/4 / 3/8	5/8" I D	390	208/1/60	N/A	N/A	DIV 26	WALL MNTD	30-7/16	9-11/32	11-25/	NTXWST06B112AA	23
F	11,000	12,300	10,750	8,225	10,350	1/4 / 3/8	5/8" ID	390	208/1/60	N/A	N/A	DIV 26	WALL MNTD	30-7/16	9-11/32	11-25/	NTXWST12B112AA	23

HP size assigned here, see VRF Indoor Unit Performance Schedule for HP performances.

NOTES

1. Nominal cooling capacities are based on indoor col EAT of 80/57°F (DBWB), outdoor of 95°F (DB)

2. Nominal heating capacities are based on indoor col EAT of 70°F (DB), outdoor of 43°F (WB)

3. See outdoor unit schedule for outdoor ambient conditions, connected capacity, and other factors associated with corrected capacities

4. See specifications for indication of required indoor unit rende controllers, system controllers, and integration devices,

5. Cooling and heating corrected capacities based on full demand,

6. HP size her are assigned to spaces on NFR indoor Unit Size Schedule,

7. HP sizes E & F are part of a Multi-Zone unit and powered from CU.

AIR SEPARATION & EXPANSION TANK SCHEDULE								
SYSTEM	HWS/R LOOP	GWS/R LOOP	DHW					
AIR-DIRT SEPARATOR	AS-H	AS-G						
MANUFACTURER	TACO	TACO						
MODEL	4905AD	49025AD						
TYPE	AIR & DIRT	AIR & DIRT						
FLOW RATE, GPM	280	65						
NLET/OUTLET	5"	2-1/2"						
BLADDER-TYPE EXPANSION TANK	ET-H1 & H2	ET-G	ET-D					
MANUFACTURER	TACO	TACO	TACO					
MODEL	CA-1100	CA-450	PAX10					
SYSTEM HEIGHT, FT	60	60						
STATIC PRESSURE AT TANK, PSI.	26.0	26.0						
PSI REQ'D, AT HIGHEST SYS POINT	5	5						
TANK PRE-CHARGE PRESSURE	31.0	31,0	40,0					
TANK DIAMETER	30	20	12"					
TANK LENGTH	85.25	77.5	12"					
ACCEPTANCE VOLUME	291	119	1.7					
WATERLOGGED WEIGHT (LBS.)	3250	1375	63					
ASME PRESSURE RATING	125	125	150					

DUCT SIZE (Ø IN.)	CFM RANGE
4"	0 ≤ CFM ≤ 30
5"	31 ≤ CFM ≤ 60
6"	61 ≤ CFM ≤ 100
7"	101 ≤ CFM ≤ 150
8"	151 ≤ CFM ≤ 215
9"	216 ≤ CFM ≤ 285
10"	286 ≤ CFM ≤ 385
12"	385 ≤ CFM ≤ 620
14"	621 ≤ CFM ≤ 950
16"	951 ≤ CFM ≤ 1330
18"	1331 ≤ CFM ≤ 1810

HYDRONIC PIPE SIZE	RUNOUT SCHEDULI
PIPE SIZE	MAX GPM
1/2*	1
3/4"	3
1"	6
1-1/4"	11
1-1/2"	18
2*	38
2-1/2"	65
3"	100
4*	230
5*	410
6"	700

			REGISTERS - GRILLES	- DIFFUSI	ERS (RGD)	SCHED	ULE			
TAG	MFR.	MODEL	ТҮРЕ	NECK SIZE	FACE SIZE	MAX CFM	MAX TOTAL P.D. (IN.W.C.)	MAX NC LEVEL	BLOW	NOTES
S-1	PRICE	520	STEEL DOUBLE DEFL. SUPPLY	6" X 6"	7.75" X 7.75"	40	0.10"	20	ADJUSTABLE	4"Ø DUCT RUNOUT
S-2	PRICE	520	STEEL DOUBLE DEFL. SUPPLY	6" X 6"	7.75" X 7.75"	130	0.10"	20	ADJUSTABLE	6"Ø DUCT RUNOUT
S-3	PRICE	520	STEEL DOUBLE DEFL, SUPPLY	8" X 6"	9.75" X 7.75"	180	0,10"	20	ADJUSTABLE	8"Ø DUCT RUNOUT
S-4	PRICE	520	STEEL DOUBLE DEFL. SUPPLY	10" X 6"	11.75" X 7.75"	240	0,10"	20	ADJUSTABLE	10"Ø DUCT RUNOUT
S-5	PRICE	520D	STEEL DOUBLE DEFL. SUPPLY W/DAMPER	6" X 6"	7.75" X 7.75"	40	0.10"	20	ADJUSTABLE	
S-6	PRICE	520D	STEEL DOUBLE DEFL. SUPPLY W/DAMPER	6" X 6"	7.75" X 7.75"	130	0.10"	20	ADJUSTABLE	
S-7	PRICE	520D	STEEL DOUBLE DEFL. SUPPLY W/DAMPER	8" X 6"	9.75" X 7.75"	180	0.10"	20	ADJUSTABLE	
S-8	PRICE	520D	STEEL DOUBLE DEFL, SUPPLY W/DAMPER	12" X 4"	13.75" X 5.75"	180	0.10"	20	ADJUSTABLE	
S-9	PRICE	520D	STEEL DOUBLE DEFL, SUPPLY W/DAMPER	10" X 6"	11.75" X 7.75"	240	0,10"	20	ADJUSTABLE	
S-10	PRICE	SCDA	SQ. CEILING SUPPLY DIFFUSER, ADJUSTABLE, 3-CONE	6" D I A	12" X12"	100	0,06"	18	4-WAY	
S-11	PRICE	SCDA	SQ. CEILING SUPPLY DIFFUSER, ADJUSTABLE, 4-CONE	6" D I A	24" X 24"	100	0.06"	16	4-WAY	
S-12	PRICE	SCDA	SQ. CEILING SUPPLY DIFFUSER, ADJUSTABLE, 4-CONE	8" D I A	24" X 24"	240	0.07"	17	4-WAY	
R-1	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES	6" X 6"	7.75" X 7.75"	40	0.05"	20		4"Ø DUCT RUNOUT
R-2	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES	8" X 8"	9.75" X 9.75"	130	0.05"	20		6"Ø DUCT RUNOUT
R-3	PRICE	530	STEEL RETURN, 3/4" SPACING, 45 DEG VANES	10" X 10"	11.75" X 11.75"	220	0,05"	20		8"Ø DUCT RUNOUT
R-4	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES	12" X 12"	13.75" X 13.75"	360	0.05"	20		10"Ø DUCT RUNOUT
R-5	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	6" X 6"	7.75" X 7.75"	40	0.05"	20		
R-6	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	8" X 8"	9.75" X 9.75"	130	0.05"	20		
R-7	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	16" X 4"	17.75" X 5.75"	150	0.05"	20		
R-8	PRICE		STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	10" X 10"	11.75" X 11.75"	220	0,05"	20		
R-9	PRICE	530D	STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	12" X 8"	13,75" X 9,75"	240	0,05"	20		
R-10	PRICE	530D	STEEL RETURN, 3/4" SPACING, 45 DEG VANES, W/DAMPER	16" X 10"	17.75" X 11.75"	360	0.05"	20		
R-11	PRICE	530	STEEL RETURN, 3/4" SPACING, 45 DEG VANES	22" X 22"	23.75" X 23.75"	1,000	0.05"	20		

					Variabl	E REFRIGER	RANT FL	_OW (VF	RF) - OU	JTDOOF	R UNIT PEI	RFOR	MANC	E SCI	IEDULI					
	NOVANIAL	NOM I N/	L BTUH	CORRECT	TED BTUH	MAXIMUM	COOLIN	NG EFF.	HEATIN	IG EFF.	ELEC1	TR I CAL	REQU	REMEN	ITS	DII	MENSIO	NS	TRANE MODEL	MEIOL
CU S I ZE	NOMINAL TONNAGE	COOLING	HEAT I NG	COOLING TOTAL	HEATING MINIMUM	CONNECTED CAPACITY	EER	SEER	COP	HSPF	V / PH / HZ	MCA	RFS	МОСР	DISC. BY	H (IN)	W (IN)	D (IN)	TRANE MODEL NUMBER	WEIGH (LB)
A	3	36,000	36,000	33,300	34,250	130%	13.80	20.65	3.85	12.10	208/1/60	36	40	40	D I V 26	52-11/16	41-11/32	13	NTXMSH36A142AA	278
В	4	48,000	54,000	43,450	40,000	130%	12,20	19.75	3,65	11,50	208/1/60	36	40	40	DIV 26	52-11/16	41-11/32	13	NTXMSH36A142AA	278
С	2	22,000	25,000	21,500	20,950	100%	19,00	19,00	0.00	10,00	208/1/60	31	40	40	DIV 26	41-9/32	37-13/32	13	NTXMPH24A132AA	189
D																				
2. Nomin 3. Efficiei 4. Provid 5. Outdoo 6. CU siz 7. All unit	nal heating cap ncy values for de added field o or design cond	acities are bas EER, IEER, C charge in addi litions: 86F Su signed to spac temp heating	ed on indoor OP are based ion to factory mmer, -11F V es on VRF Ou (H2i Hyper-He	coil EAT of 70° I on AHRI 1230 charge as need Vinter utdoor Unit Size eat) units	F (DB), outdoo 0 test method fi ded based upo e Schedule.	outdoor of 95°F (Di r of 43°F (WB) or mixture of ducted n final as-built pipin	l & non-duct	ted indoor ur	nits.											

				QTY HP	NOMINAL	CAPACITY	CORRECTE	D CAPACIT
TAG	UNIT LOCATION	AREAS SERVED	SIZE	ON SYSTEM	COOLING	HEATING	COOLING TOTAL	HEATING MINIMUM
CU0 1-1	GRADE	INT FLR - PH 1 - DORMS	A	6	36,000	36,000	33,300	34,250
CU0 1-2	GRADE	INT FLR - PH 1 - DORMS	A	5	36,000	36,000	33,300	34,250
CU1 1-1	GRADE	1st FLR - PH 1 - DORMS	A	6	36,000	36,000	33,300	34,250
CU1 1-2	GRADE	1st FLR - PH 1 - DORMS	A	6	36,000	36,000	33,300	34,250
CU1 4-1	GRADE	1st FLR - PH 4 - APARTMENT	С	3	22,000	25,000	21,500	20,950
CU1 4-2	GRADE	1st FLR - PH 4 - HEALTH SERVICES	A	5	36,000	36,000	33,300	34,250
		SYSTEMS LISTED AB	OVE TH	S LINE ARE	BID ALTERNA	TE #3		
CU2 1-1	ROOF	2nd FLR - PH 1 - DORMS	В	8	48,000	54,000	43,450	40,000
CU2 1-2	ROOF	2nd FLR - PH 1 - DORMS	В	8	48,000	54,000	43,450	40,000
CU2 1-3	ROOF	2nd FLR - PH 1 - DORMS	В	8	48.000	54.000	43.450	40.000
CU2 2-1	ROOF	2nd FLR - PH 2 - DORMS	В	8	48.000	54.000	43,450	40,000
CU2 2-2	ROOF	2nd FLR - PH 2 - DORMS	В	8	48.000	54,000	43,450	40,000
CU2 2-3	ROOF	2nd FLR - PH 2 - DORMS	В	8	48.000	54.000	43.450	40.000
CU2 3-1	ROOF	2nd FLR - PH 3 - DORMS	В	8	48,000	54,000	43,450	40,000
CU2 3-2	ROOF	2nd FLR - PH 3 - DORMS	В	8	48.000	54,000	43.450	40.000
CU2 3-3	ROOF	2nd FLR - PH 3 - DORMS	В	8	48.000	54,000	43,450	40,000
CU2 4-1	ROOF	2nd FLR - PH 4 - DORMS	A	6	36,000	36,000	33 300	34 250
CU2 4-2	ROOF	2nd FLR - PH 4 - DORMS	В	8	48.000	54,000	43.450	40,000
CU2 4-2	ROOF	2nd FLR - PH 4 - DORMS	В	8	48,000	54,000	43,450	40,000
CU2 4-3	ROOF	211d FLR - PH 4 - DORNIS	В	•	46,000	54,000	43,430	40,000
CU3 1-1	ROOF	3rd FLR - PH 1 - DORMS	В	8	48.000	54.000	43.450	40.000
CU3 1-2	ROOF	3rd FLR - PH 1 - DORMS	В	8	48.000	54.000	43.450	40,000
CU3 1-3	ROOF	3rd FLR - PH 1 - DORMS	В	8	48.000	54,000	43,450	40,000
CU3 2-1	ROOF	3rd FLR - PH 2 - DORMS	В	8	48,000	54,000	43,450	40,000
CU3 2-2	ROOF	3rd FLR - PH 2 - DORMS	В	8	48,000	54,000	43,450	40,000
CU3 2-3	ROOF	3rd FLR - PH 2 - DORMS	В	8	48.000	54,000	43,450	40,000
CU3 3-1	ROOF	3rd FLR - PH 3 - DORMS	В	8	48.000	54,000	43,450	40,000
CU3 3-1	ROOF	3rd FLR - PH 3 - DORMS	B	8	48,000	54,000	43,450	40,000
CU3 3-3	ROOF	3rd FLR - PH 3 - DORMS	В	8	48,000	54,000	43,450	40,000
CU3 3-3	ROOF	3rd FLR - PH 4 - DORMS	A	6		36,000	33,300	34,250
	ROOF		B	8	36,000			
CU3 4-2 CU3 4-3	ROOF	3rd FLR - PH 4 - DORMS 3rd FLR - PH 4 - DORMS	В	8	48,000	54,000 54,000	43,450 43,450	40,000
CU3 4-3	ROOF	3rd FLR = PH 4 = DORMS	В	8	48,000	54,000	43,450	40,000
CU4 1-1	ROOF	4th FLR - PH 1 - DORMS	В	8	48.000	54.000	43.450	40.000
CU4 1-2	ROOF	4th FLR - PH 1 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 1-3	ROOF	4th FLR - PH 1 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 1-3	ROOF	4th FLR - PH 2 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 2-1	ROOF	4th FLR - PH 2 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 2-2	ROOF	4th FLR - PH 2 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 3-1	ROOF	4th FLR - PH 3 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 3-2	ROOF	4th FLR - PH 3 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 3-3	ROOF	4th FLR - PH 3 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 4-1	ROOF	4th FLR - PH 4 - DORMS	A	6	36,000	36,000	33,300	34,250
CU4 4-2	ROOF	4th FLR - PH 4 - DORMS	В	8	48,000	54,000	43,450	40,000
CU4 4-3	ROOF	4th FLR - PH 4 - DORMS	В	8	48,000	54,000	43,450	40,000

GENERAL	TAG	MUA-1-21
	SERVES	LAUNDRY MUA, PHASE 2
	LOCATION	FIRST FLOOR (1)
	TYPE	BLOWER COIL UNIT
	MFR	TRANE
	MODEL	BCHE054
FILTER SECTION	FILTERS (OA)	MERV 8
SUPPLY AIR FAN	TYPE	ODP, BI
	AIRFLOW (cfm)	1,500
	ESP, in.wc.	1.0
	MOTOR TYPE	ECM - VARIABLE SPEED
	FAN HP	(1) 1HP
OVERALL DIMENSIONS	LENGTH	35.8"
	WIDTH	46.0"
	HEIGHT	18.0"
	OPERATING WEIGHT, lbs.	210
EATING COIL	HYDRONIC COIL TAG	INTEGRAL TO UNIT
	EAT, deg-F.	-10
	LAT, deg-F.	75
	TMBTUH	137,7
	MIN COIL AREA, sf.	3.7
	MAX AIR PD. in. wc.	0.1
	COIL FACE VELOCITY	406
	FLUID	40% P.G.
	EWT (F)	180
	LWT (F)	150
	FLOW RATE (GPM)	9.2
	WPD (FTHD)	3.0
LECTRICAL DATA	V-PH-HZ	208-3-60
	UNIT MCA	5.8
	MOPD / MOCP	15
	SMOKE DETECTORS	NONE

11/22/2023

TITLE MECHANICAL SCHEDULES

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is not permitted without written permission of CHA Architecture.

CURTIS HALL RENOVATIONS
Maine Maritime Academy, Curtis Hall
1 Pleasant Street, Castine, Maine 04421

No. Date Description

NOT FOR CONSTRUCTION

Revision Schedule

JOB NO. 076982

ISSUE

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

SHEET

M603

PROJECT NOTES INSTALLATION COORDINATION NOTES WIRING NOTES SYSTEM POWER WIRING NOTES ALL VIDEO PROJECTOR, CAMERA AND MONITOR POWER OUTLETS AND THEIR
ASSOCIATED COMPUTER POWER OUTLETS FEEDING THE VIDEO SOURCE ARE TO BE
CONNECTED TO THE SAME PHASE TO ELIMINATE THE POTENTIAL FOR VIDEO
INTERFERENCE BETWEEN VIDEO SOURCE AND EQUIPMENT. COORDINATE ALL POWER
WIENING FOR SYSTEM EQUIPMENT WITH THE SYSTEM INSTALLER PRIOR TO THE SCOPE OF WORK SHALL INCLUDE PROVIDING ALL WORK INDICATED UNLESS OTHERWISE SPECIFICALLY INDICATED AS EXISTING OR WORK BY OTHERS, AND COORDINATION WITH ALL TRADES SCOPE OF WORK AS INDICATED ON THE CONTRACT DOCUMENTS INCLUDING BOTH THE DRAWINGS AND THE SPECIFICATIONS, WHICH ARE COMPLIBENTARY, WORK REQUIREMENTS INDICATED IN ANY CONTRACT DOCUMENT SHALL BE CONSIDERED PART OF THE SCOPE OF WORK, UNLESS SPECIFICALLY INDICATED AS EXISTING OR WORK BY OTHERS. PRIOR TO ROUGH-IN OF ELECTRICAL PROVISIONS FOR OWNER FURNISHED EQUIPMENT AND EQUIPMENT PROVIDED BY OTHER TRADES, CORDENATE WITH THE GENERAL CONTRACTOR, AND WIRNING REQUIPMENTS, PROVIDE ALL NECESSARY EQUIPMENT, WARRING AND ACCESSORIES FOR A COMPLETE INSTALLATION, MAKE ALL FINAL CONNECTIONS AS REQUIRED, I.E. POWER, CONTROL, INTERLOCK, ETC. UNLESS OTHERWISE INDICATED ON PLANS OR IN SPECIFICATIONS, ALL CONDUCTORS, POWER DISTRIBUTION EQUIPMENT BUSSING AND TRANSFORMER WINDINGS SHALL BE FABRICATED OF 98% CONDUCTIVE COPPER MATERIAL. INTERFERENCE WIRING FOR SY INSTALLATION 2. WIRING IS INDICATED ON DRAWINGS ONLY FOR SPECIFIC ROUTES OR DISCONNECT, REMOVE, RELOCATE, AND RECONNECT ELECTRICAL CONDUIT, WIRING, DEVICES, BOXES, FIXTURES, EQUIPMENT, ETC., AS INDICATED AND AS REQUIRED TO FACILITATE THE WORK OF DIVISION 25 AND OTHER DIVISIONS, THESE DRAWINGS ARE NOT INTENDED TO INDICATE ALL ITEMS TO BE REMOVED. RECEPTACLE COLOR CODE NOTES IN GENERAL, WORK REQUIREMENTS ARE NOT INDICATED IN BOTH DOCUMENTS. WHERE DOCUMENTS CONFLICT WITHIN THEMSELVES OR WITH CODES AND REGULATIONS, PROVIDE THE HIGHER QUANTITY AND QUALITY AND FOLLOW THE STRICTER REQUIREMENTS. BRANCH CIRCUIT WIRING NOT SHOWN, CIRCUITING SHALL IN ACCORDANCE WITH APPLICABLE CODES AND STANDARD PRACTICE, PROVIDE A 20A, 1P CIRCUIT SHAESS OTHERWISE INDICATED OR NOTED, CONNECT NO MORE THAN SIX DUPLEX CONVENIENCE RECEPTACLE CIPCUIT UNLESS PER BRANCH CIRCUIT, CONNECTED LOAD ON LIGHTING CIRCUITS SHALL NOT EXCEED 12 AMPS. UNLESS OTHERWISE INDICATED PROVIDE 20A HEAVY DUTY GRADE RECEPTACLES WITH COLOR CODE AS FOLLOWS: ELECTRICAL EQUIPMENT, RACEWAYS AND OUTLETS MOUNTED TO AND OR INSTALLED IN OWNER FURNISHED FURNITURE SHALL BE COORDINATED WITH THE EQUIPMENT AND FURNITURE INSTALLERS AND THE GENERAL CONTRACTOR PRIOR TO ROUGH-IN. EXCEPT WHERE INDICATED OR REQUIRED OTHERWISE. ON GENERATOR POWER – RED ON UPS POWER – BLUE ISOLATED GROUND – ORANGE ON NORMAL POWER – IVORY OR AS SELECTED BY ARCHITECT WORK AT A MINIMUM SHALL BE IN ACCORDANCE WITH CISHA, HEPA STANDARDS, THE ELECTRICAL CODE AND THE LOCAL COVERNING AUTHORITIES. THE ORANINGS AND AUTHORITIES, DO NOT INSTALL WORK THAT DOES NOT MEET THE MINIMUM REQUIREMENTS. IF NECESSARY, REQUEST CLARIFICATION FROM ARCHITECT AND ENGINEER BEFORE PROCEEDING. NOTE: LL WIRING SHALL BE RUN CONCEALED UNLESS SPECIFIED OTHERWISE, XPOSED WIRING INCLUDING THAT WHICH IS INSTALLED ABOVE BUT IS ISBILE FROM BEIOW, PARTIALLY OR FULLY OPEN CELLION, SHALL BE ISTALLED IN CONDUIT OR RACEWAYS, REFER TO SPECIFICATIONS FOR CONSTILLE IN BURIOU LETTICAL SYMBOLS AND ABBREVIATIONS SHOWN OF THIS SHEET ARE FOR REFERENCE ONLY AND DO NOT NECESSARILY INDICATE THEIR INCORPORATION INTO THE DESIGN E LOCATION OF EQUIPMENT, OUTLETS, ETC. AS GIVEN ON THE DRAWINGS IS APPROXIMA SHALL BE UNDERSTOOD THAT THESE LOCATIONS ARE SUBJECT TO MODIFICATION AS MA FOUND NECSSARY OR DESIRABLE AT THE TIME OF INSTALLATION IN ORDER TO MEET OJECT REQUIREMENTS, SUCH CHANGES SHALL BE MADE WITHOUT EXTRA CHARGE, MOUNTING NOTES ACCEPTABLE WIRING METHODS. DO NOT SCALE THE DRAWINGS, REFER TO ARCHITECTURAL DRAWINGS AND EXISTING CONDITIONS FOR EXACT DIMENSIONS. ALL EQUIPMENT SHALL BE INSTALLED IN A NEAT AND PROFESSIONAL MANNER, RECTILINEAR TO BUILDING STRUCTURE. WIRING AND CONDUIT SHALL BE REQUIRED FOR ALL SWITCHES, AND OUTLETS INDICATED WITH CIRCUIT NUMBERS, PROVIDE W CONDUIT, 3#12 UNLESS OTHERWISE NINDICATED () PHASE, I NEUTRAL AND I GROUND), WIF AND CONDUIT SIZES ON HOME RUNS SHALL BE CONTINUOUS THROUGHOUT GROUT, REFER TO VOLTAGE DROP CHART ON SCHEDULE SHEET. ALTHOUGH ALL BRANCH CIRCUIT WIRE AND COMDUIT IS NOT SHOWN, IT IS THE INTENT OF THESE DOCUMENTS THAT A COMPLETE BRANCH CIRCUIT FOR THE STATE OF THESE DOCUMENTS THAT A COMPLETE BRANCH CIRCUIT FOR THE STATE OF THESE DOCUMENTS THAT A COMPLETE BRANCH CIRCUIT FOR THE STATE OF THESE DOCUMENTS THAT A COMPLETE BRANCH CIRCUIT FOR THE STATE OF THE IF EXACT LOCATION, MOUNTING OR RACEWAY ROUTING ARE NOT INDICATED OR ARE NOT CLEAR OR CONFLICT (LOCATION OR HEIGHT) COORDINATE WITH OTHER TRADES AND REQUEST CLARIFICATION PRIOR TO ROUGH-IN OR INSTALLATION. DRAWNINGS ARE DIAGRAMMATIC ONLY, EXACT LOCATION, MOUNTING HEIGHTS OR EQUIPMENT AND ROUTING OF RACEWAYS SHALL BE COORDINATED WITH THE EQUIPMENT REQUIREMENTS AND FIELD CONDITIONS. INSTALL ALL ELECTRICAL DEVICES (FIRE ALARM, SWITCHES, RECEPTACLES, WORK BOXES, JUNCTION BOXES, EXIT SIGNS, LUMINAIRES, ETC.) IN THE LOCATIONS IDENTIFIED OR DIMENSIONS ON THE ARCHITECTURAL PLANS, DETAILS, OR ELEVATIONS, ALL COMPONENTS SHOWN ON THE RISER DIAGRAMS OR DETAILS, BUT NOT ON THE PLAN OR VICE VERSA SHALL BE INCLUDED AS IF SHOWN ON BOTH. . IT IS THE INTENT OF THESE PLANS AND SPECIFICATIONS TO PROVIDE A WORKING INSTALLATION IN EVERY DETAIL AND ALL ITEMS REQUIRED FOR SUCH AN INSTALLATION SHALL BE PROVIDED WHETHER OR NOT SPECIFICALLY INDICATED OR MENTIONED. IF THE DEVICE LOCATION IS NOT SPECIFICALLY SHOWN ON ARCHITECTURAL DRAWINGS, FOLLOW THE GUIDELINES LISTED BELOW: IRING SYSTEM BE INSTALLED. WHERE LOADS ARE ADDED TO EXISTING BRANCH CIRCUITS, VERIFY THAT THE EXISTING CIRCUITS HAVE ADEQUATE CAPACITY TO SUPPORT THE ADDITIONAL LOAD WITHOUT EXCEEDING SPECIFIED MAXIMUM LOAD. RACEWAYS SHALL BE LIMITED TO SIX CURRENT CARRYING CONDUCTORS 4. INSTALL NEARBY DEVICES ON ONE COMMON VERTICAL CENTERLINE VISIT THE SITE TO DETERMINE PRE-EXISTING CONDITIONS AND WORK NECESSARY PRIOR TO SUBMISSION OF BID PRICE, SUBMIT ANY QUESTIONS REQUIRED TO CLARIFY SCOPE PRIOR TO BID. INCLUDE ALL REQUIRED WORK IN BID PRICE. PROJUMENTS STRALL BE LIMITED TO SIX CURRENT CARRYING CONDUCTORS (PHASE AND NEUTRALS), AND GROUNDING CONDUCTOR, PROVIDE A DEDICATED NEUTRAL CONDUCTOR FOR EACH SINGLE-PHASE RECEPTACLE OR LIGHTING GROULT, UNLESS OTHERWISE INDICATED OR IF AN OVERSIZED NEUTRAL IS SPECIFIED, CIRCUITS WITH SHARED NEUTRALS SHALL BE PROVIDED BYTH CIRCUIT BREAKERS THAT HAVE A COMMON TRIP (E.G. FURNITURE WHIPS) 5. INSTALL ADJACENT TO DEVICES LINED UP WITH A COMMON BOTTOM LINE. UNLESS OTHERWISE DIRECTED, PROVIDE ALL NEW POWER DISTRIBUTION EQUIPMENT WITH ALC RATINGS THAT MATCH OR EXCEED THE AIC RATING OF THE NEXT ACTIVE EXISTING UPSTEEMA OVER-CURRENT PROTECTIVE DEVICE SERVING THE PANEL WHEN SERVED LIRECTLY BY ITS SOURCE (E.G., NO TRANSFORMER) OR PROVIDE AIC RATING THAT EXCEEDS BY 10% THE MAXIMUM LET THROUGH FAULT CURRENT ((NDEE INFITTE PRIMARY BUSS) OF THE NEXT ACTIVE UPSTREAM TRANSFORMER (EXISTING OR NEW) SERVING THE RESPECTIVE PANEL. INSTALL DEVICES AT INDICATED HEIGHT AS APPLICABLE UNLESS OTHERWISE NOTED ALL MOUNTING HEIGHTS SHALL BE MEASURED FROM FINISHED FLOOR TO CENTERLINE OF DEVICE EXCEPT AS INDICATED BY NOTE 7. INCLUDE IN BID WHATEVER IS REQUIRED TO MEET SCHEDULE INCLUDING OVERTIME, EXPRESS SHIPPING, EXPORTING EQUIPMENT, ETC, PLAN FOR PROJECT AND SUBMIT SHOP DRAWNIG AND ORDER EQUIPMENT IN A TIMELY MANNER; EQUIPMENT SHALL BE BASED ON THE SPECIFIED EQUIPMENT. MARK ALL CONDUITS AND JUNCTION BOXES WITH PERMANENT MARKER INDICATING PANEL AND CIRCUIT NUMBER OF CONDUCTORS CONTAINED WITHIN, LABEL WHERE CONDUITS ENTER PANELS, WIJRE WAYS, PULL BOXES, ETC. LABEL EMPTY CONDUITS WITH SYSTEM (VOICE, DATA, SECURITY, ETC.) AND SOURCE OF CONDUIT. ON MASONRY WALLS LINE UP THE BOTTOM OF THE DEVICE WITH A MASONRY JOINT AS CLOSE TO THE INDICATED HEIGHT AS PRACTICAL. A AMPERE MC MICROPHONE ANY EQUIPMENT TO BE SUBSTITUTED SHALL BE IDENTIFIED AT THE TIME OF BID, REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS FOR SUBSTITUTIONS. AC ALTERNATING CURRENT MW MICROWAVE ALL NEW PANELS SHALL BE FULLY RATED FOR THE DESIGNATED AIC VALUE: PANELS UTILIZING 8. INSTALL DEVICES IN SAME AREA AT THE SAME HEIGHT. SERIES RATINGS WILL NOT BE ACCEPTABLE. NEW CIRCUIT BREAKERS PROVIDED IN EXISTING PANELS SHALL BE PROVIDED WITH AIC RATINGS THAT MATCH OR EXCEED THE HIGHEST RATED OVER-CURRENT PROTECTIVE DEVICE WITHIN THE RESPECTIVE EXISTING PANEL. ALL ELECTRICAL DEVICES, WHEN INSTALLED, SHALL BE PROTECTED FROM DAMAGE DURING CONSTRUCTION. COVER PLATES SHALL BE INSTALLED <u>AFTER</u> FINISH MATERIALS HAVE BEEN APPLIED. 9. MOUNT PANELS SIX FEET TO THE TOP OF THE PANEL OR ANNUNCIATOR/ FA GRAPHIC AFE ABOVE FINISHED FLOOR MLO MAIN LUG ONLY COORDINATE WITH OWNER TO DETERMINE WHICH RECEPTACLES AND ITEMS OF EQUIPMENT REQUIRE STANDBY GENERATOR POWER. MOUNT AT 8 FOOT TO BOTTOM FOR SIGNAGE, EMERGENCY LIGHTING, CLOCKS, SECURITY SENSORS, WALL MOUNTED OCCUPANCY SENSORS MODIFIED AS FOLLOWS 4" FROM TOP OF DEVICE TO CELLING AND 4" ABOVE DOOR FRAMES." AFG ABOVE FINISHED GRADE SUBMIT SHORT GROUT STUDY WITH FOWER DETRIBUTION EQUIPMENT SUBMITTALS FOR REVIEW AND APPROVAL. IN THE STUDY DEMONSTRATE THAT HE AR PARTING SELECTIONS ARE PROPERLY INTEGRATED AND COORDINATED WITH THE EXISTING AND NEW POWER DISTRIBUTION EQUIPMENT. COORIEMT HAT THE ARC RATING SELECTIONS HAVE INCORPORATED THE AVAILABLE FAULT DUTY VALUES OBTAINED FROM THE UTILITY COMPANY FOR THE PROJECTS ELECTRICAL SERVICE FOUNT OF COMMON COUPLING. ELECTRICAL WORK NOT SERVING STAIRWELLS SHALL NOT PASS THROUGH STAIR ENCLOSURE UNLESS AN APPROVED RATED SOFFIT IS PROVIDED TO MAINTAIN FIRE AND SMOKE RATING. AHU AIR HANDLING UNIT MTS MANUAL TRANSFER SWITCH 11. LOCATE CONTROL DEVISE AT LEAST 18" FROM AN INSIDE CORNER. AIC AMPERES INTERRUPTING CAPACITY MCP MOTOR CONTROL PANEL ATS AUTOMATIC TRANSFER SWITCH MDP MAIN DISTRIBUTION PANEL ALL RACEWAYS CROSSING EXPANSION JOINTS SHALL BE EQUIPPED WITH EXPANSION FITTINGS. 12. SUPPORT WORK FROM THE BUILDING STRUCTURE. . PROVIDE TRAINING TO OWNER ON ALL EQUIPMENT AND SYSTEMS INSTALLED I. SUBMIT OVER-CURRENT PROTECTIVE DEVICE COORDINATION STUDY, FOR ALL NEW POWER DISTRIBUTION EQUIPMENT, WITH THE POWER DISTRIBUTION EQUIPMENT SUBMITTALS FOR REVIEW AND APPROVAL, INCLUED THE NEXT ACTIVE EXISTING UPSTEAM OVER-CURRENT PROTECTIVE DEVICES, IN THE STUDY ANALYSIS, WHEN PROJECT IS WITHIN AN EXISTING FACILITY. 13. IN FINISHED AREAS ELECTRICAL WORK SHALL BE INSTALLED CONCEALED, RECESSEI INTO WALLS OR INSTALLED ABOVE HUNG CEILINGS UNLESS OTHERWISE INDICATED. TEMPORARY LIGHTING AND POWER SHALL BE PROVIDED AS REQUIRED BY OSHA, CODES AND LOCAL AUTHORITIES, REMOVE ALL TEMPORARY FACILITIES PROVIDED AT PROJECT COMPLETION. PROVIDE WATERTIGHT AND GAS TIGHT SEALS INSIDE AND OUTSIDE OF CONDUITS THAT PENETRATE THE BUILDING BELOW GRADE, O.Z. GEDNE APPROVED EQUAL, PROVIDE WEATHER TIGHT SEAL AT PENETRATIONS ABOVE GRADE. 14. DO NOT INSTALL OUTLETS BACK TO BACK, PROVIDE 24" SPACING IN FIRE RATED WALLS BAS BUILDING AUTOMATION SYSTEM N NEUTRAL 15, PROVIDE ELECTRICAL OUTLET PLATE GASKETS SEALS AT RECEPTACLES, SWITCHES AND OTHER ELECTRICAL BOXES ON EXTERIOR WALLS AND INTERIOR WALLS BETWEEN CONDITIONED SPACES. SUBMIT ARC FLASH REPORT, FOR ALL NEW POWER DISTRIBUTION EQUIPMENT, WITH POWER DISTRIBUTION EQUIPMENT SUBMITTALS FOR REVIEW AND APPROVAL. 12. PROVIDE NRTL LISTED SMOKE AND FIRE SEALS AT ALL PENETRATIONS THROUGH FLOORS OR FULL HEIGHT (FLOOR TO FLOOR) WALLS. NC NORMALLY CLOSED NEC NATIONAL ELECTRICAL CODE CAT CATALOG, CATEGORY NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION F4 ELECTRICAL GENERAL NOTES CATV CABLE TV PANELBOARD ~ FLUSH MOUNTED CB CIRCUIT BREAKER ■ PANELBOARD ~ SURFACE MOUNTED NFPA NATIONAL FIRE PROTECTION ASSOCIATION ☐ DISCONNECT SWITCH CCTV CLOSED CIRCUIT TELEVISION CM CIRCULAR MILS NIC NOT IN CONTRACT CABLE TRAY ✓ MOTOR OR FAN COMM COMMUNICATIONS NF NON-FUSED JUNCTION BOX, CEILING OR WALL MOUNTED, MAKE CONNECTION TO RESPECTIVE EQUIPMENT. COORDINATE EXACT TERMINATION POINT IN FIELD OR THROUGH APPROVED SUBMITTALS. HALL CU MECH CONDENSING UNIT NO NORMALLY OPEN \sim 0 CU COPPER NO., # NUMBER CUH CABINET UNIT HEATER NTS NOT TO SCALE TRANSFORMER ~ SEE TRANSFORMER SCHEDULE INDICATES DEDICATED CIRCUIT OR HOMERUN BACK TO RESPECTIVE PANEL - (2)#12×1()#13/20 UNO, REFER TO EQUIPMENT SCHEDULES AND PANELBOARD SCHEDULES FOR ADDITIONAL INFORMATION. DC DIRECT CURRENT OC ON CENTER ഗ DDC DIGITAL DIRECT CONTROL OCC OCCUPANCY OH OVERHEAD DN DOWN RT P DIVIDED POWER POLE FOR SYSTEM FURNITURE POWER AND DATA WIRING DW DISHWASHEI P POLE DWG DRAWING PA PUBLIC ADDRESS S PB PULLBOX EF EXHAUST FAN ELEV ELEVATOR PH. PHASE ATS AUTOMATIC TRANSFER SWITCH EMT ELECTRICAL METALLIC TUBING PIR PASSIVE INFRARED TRIPLE SWITCH FOR MANUAL TRANSFER FROM PERMANENT GENERATOR TO TEMPORARY ROLL-UP GENERATOR WITH CONNECTION (CAM-LOK) PROVISIONS FOR ROLL-UP UNIT (ESL OR EQUAL) EP EXPLOSION PROOF PNL PANELBOARD P/O PART OF ERU ENERGY RECOVERY UNIT PH IN-GRADE PULL HOLE, REFER TO PLANS FOR REQUIRED SIZE EWC ELECTRIC WATER COOLER PV PHOTOVOLTAIC FACP FIRE ALARM CONTROL PANEL PVC POLY-VINYL CHLORIDE \$M MOTOR RATED SWITCH WITH THERMAL OVERLOAD PROTECTION REC RECEPTACLE RECEPT AS AF In FUSED DISCONNECT SWITCH FLA FULL LOAD AMPS SINGLE RECEPTACLES REF REFRIGERATOR П NON-FUSED DISCONNECT SWITCH LIGHTING SWITCHES FWE FURNISHED WITH EQUIPMENT SPECIAL RECEPTACLE ~ REFER TO SPECIAL RECEPTACLE SCHEDULE FOR AMPACITY, NEMA CONFIGURATION, WIRE SIZE AND ADDITIONAL RELATED INFORMATION FOR ASSOCIATED LETTER MOTOR STARTER ~ NUMBER INDICATES NEMA SIZE RF RETURN FAN \$a LIGHT SWITCH, 20A,125/277V 00 🔀 COMBINATION MOTOR STARTER/FUSED DISCONNECT G, GND GROUND RGS RIGID GALVANIZED STEEL \$a MULTI-GANGED SWITCHES, GANG UNDER ONE PLATE, LETTER INDICATES SWITCHING METER AND CABINET OVERHEAD SPECIAL RECEPTACLE DROP ~ REFER TO SPECIAL RECEPTACLE SCHEDULE FOR AMPACITY, NEMA CONFIGURATION, WIRE SIZE AND ADDITIONAL RELATED INFORMATION FOR ASSOCIATED LETTER GFCI GROUND FAULT CIRCUIT RM ROOM JUNCTION BOX \$05 OCCUPANCY SENSOR SWITCHOCCUPANCY SENSOR SWITCH JUNCTION BOX ~ WALL MOUNTED GFP GROUND FAULT PROTECTION RMC RIGID METAL CONDUIT _ _ - _ JUNCTION BOX ~ FLUSH CEILING MOUNTED $_{\rm OSD}$ occupancy sensor switch with Dimming ~ coordinate dimming technology with load to be dimmed HID HIGH INTENSITY DISCHARGE RTU ROOFTOP UNIT P J JUNCTION BOX ~ PEDESTAL MOUNTED HOA HAND-OFF-AUTO SELECTOR SWITCH OCCUPANCY SENSOR, CEILING MOUNTED 1. PROVIDE MATCHING CORD AND PLUG FOR SINGLE RECEPTACLES TRANSFORMER ~ NUMBER INDICATES DESIGNATION SEE TRANSFORMER SCHEDULE T# $\ensuremath{\varphi_D}$ $\ensuremath{\text{DIMMER SWITCH}}$ ~ Coordinate dimming technology with load to be dimmed SF SUPPLY FAN 2. MOUNT EXTERIOR RECEPTACLES WITH CENTERLINE 24" AFG UNO HORSEPOWER FACE FIRE ALARM CONTROL PANEL, MOUNT WITH TOP OF PANEL NOT MORE THAN 72"AFF VARIABLE FREQUENCY DRIVE SPDT SINGLE POLE, DOUBLE THROW MOUNT RECEPTACLES WITH CENTERLINE 18" AFF UNO. (30") INDICATES DEVICE MOUNTING HEIGHT WHEN NOT MOUNTED AT 18". HVAC HEATING, VENTILATION AND COOLING UNIT TRANSIENT VOLTAGE SURGE SUPPRESSOR SQ SQUARE POWER SHUTOFF SWITCH ~ WALL MOUNTED 44" TO CENTER LINE ~ CONNECT TO CONTROL SHUNT TRIP COIL OF MAIN CIRCUIT BREAKER IN PARELBOARD SERVING AREA. PROVIDE CONTACTOR/RELAY INSTEAD OF THE SHUNT TRIP BREAKER WHERE INDICATED ON PLAN OS) DAYLIGHT HARVESTING SENSOR, CEILING MOUNTED INTRUSION DETECTION SYSTEM TEL TELEPHONE FIRE ALARM ANNUNCIATOR, MOUNT WITH TOP OF PANEL NOT MORE THAN 72"AFF, WIRED TO FACP NOTES: 1. MOUNT LIGHT SWITCHES WITH CENTERLINE 48" AFF, UNO 2. LOWER CASE LETTER AT SWITCH INDICATES SWITCH GROUP ISOLATED GROUND TVSS TRANSIENT VOLTAGE SURGE S SMOKE DETECTOR, WIRED TO FACE IMC INTERMEDIATE METAL CONDUIT
TYP TYPICAL CONDUIT TURNING UF SMOKE DETECTOR, "E" INDICATES CONNECTION FOR ELEVATOR RECALL, WIRED TO FACE EMERGENCY AND EXIT LIGHTING IR INFRARED —— CONDUIT TURNING DOWN HATCHING INDICATES FIXTURE CONNECTED TO CENTRAL INVERTER U.N.O. FIXTURES SHALL AUTOMATICALLY SWITCH ON AND BYPASS ANY CONTROLS ON UPON FIRE ALARM OR LOSS OF NORMAL POWER. UF UNDER FLOOR к кисо - - WIRING UNDERGROUND OR UNDERSLAB HEAT DETECTOR, "E" INDICATES CONNECTION FOR ELEVATOR RECALL, WIRED TO FACP UG UNDERGROUND KILO CIRCULAR MILS FLOOR AND CEILING DEVICES UH UNIT HEATER DUCT SMOKE DETECTOR, WIRED TO FACE II- GROUNDING SYSTEM KW KILOWATT OVERHEAD RECEPTACLE DROP, DOUBLE DUPLEX CR= CORD REEL UL UNDERWRITER'S LABORATOR MOTORIZED DOOR OPERATOR AND PUSH PADDLE -PROVIDE 11/2"C WITH PULLSTRING FROM MOTOR TO EACH PADDLE LOCATION. PROVIDE EMPTY SINGLE GANG BOX 44" AFF AT EACH PADDLE LOCATION. KVA KILO VOLT-AMPS MAGNETIC DOOR HOLDER, WIRED TO FACE UNO UNLESS NOTED OTHERWISE EXIT SIGN, CEILING MOUNTED, SHADING INDICATES FACE(S) ARROWHEAD INDICATES CHEVRON(S) REQUIRED, CONNECT TO UNSWITCHED PORTION OF AREA LIFE SAFETY LIGHTING LAN LOCAL AREA NETWORK RECEPTACLES REMOTE TEST/INDICATOR FOR DUCT SMOKES, MOUNT ON CEILING BENEATH UNIT, OR WALL MOUNT WHERE INDICATED ON PLANS RTS RTS UPS UNINTERRUPTIBLE POWER SUPPLY LIGHTING CONTACTOR ANCH CIRCUIT, U.N.O. н HAND DRYER, COORDINATE HEIGHT WITH ARCHITECTURAL PLANS DUPLEX RECEPTACLE ~ 20A, 125V, 2P, 3W, NEMA 5-20R EXIT SIGN, WALL MOUNTED, SHADING INDICATES FACE(S) MOUNT AT 7-6"AFF OR OVER DOOR, CONNECT TO UNSWITCHED PORTION OF AREA LIFE SAFETY LIGHTING BRANCH CIRCUIT, U.N.O. LF LINEAR FEET V VOLTS HVAC CONTROLS POWER - PROVIDE SINGLE GANG BOX ABOVE CEILING OR IN AREAS WITHOUT SUSPENDED CEILING, MOUNT AT UNDERSIDE OR DECK. DOUBLE DUPLEX RECEPTACLE ■ MANUAL PULL STATION, MOUNT 48" AFF HV LC LOADCENTER VFD VARIABLE FREQUENCY DRIVE DEH HORN/STROBE, WALL MOUNTED CANDELA AS NOTED ON PLANS, WIRED TO FACP. MOUNT 80" AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER. GFCI DUPLEX RECEPTACLE, MOUNT 44" AFF UNO LCP LIGHTING CONTROL PANEL VIF VERIFY IN FIELD EMERGENCY BATTERY LIGHTING UNIT WITH INTEGRAL HEADS DED— LOW FREQUENCY HORN/STROBE, WALL MOUNTED CANDELA AS NOTED ON PLANS, WIRED TO FACE, MOUNT BY AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER. FOR USE IN SLEEPING AREAS. A1/EX.XX — DETAIL NUMBER/ DRAWING NUMBER
PANEL & CKT # GFCI DOUBLE DUPLEX RECEPTACLE, MOUNT 44" AFF UNO LED LIGHT EMITTING DIODE W WATT WIRE AND CONNECT ALL RECEPTACLES AND DEVICES TO CIRCUIT INDICATED U.N.O. LTG LIGHTING HORN/STROBE, CEILING MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACP. MOUNT 80" AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER NPΦ GFCI RECEPTACLE IN WP ENCLOSURE ON ROOF TYPICAL FOR ALL FIXTURE TYPES: LTS LIGHTS WG WIREGUARD STROBE ONLY INDICATING APPLIANCE, CEILING MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACE, MOUNT 80' AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER. TECHNOLOGY DEVICES ~ REFER TO TECHNOLOGY SCHEDULE - INDICATES LUMINAIRE TYPE ON SCHEDULE EQ XX EQUIPMENT TAG ~ REFER TO ELECTRICAL SCHEDULE OF EQUIPMENT MAX MAXIMUM XFMR TRANSFORMER 2 R2 a 2 R1 a -- LOWER CASE LETTER INDICATES SWITCHING MCB MAIN CIRCUIT BREAKER STROBE ONLY INDICATING APPLIANCE, WALL MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACE, MOUNT 80' AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER. R1 2 🔾 a W1 2 **Q** a 1. MOUNT RECEPTACLES WITH CENTERLINE AT 18" AFF UNO MECHANICAL EQUIPMENT TAG ~ REFER TO ELECTRICAL SCHEDULE OF MECHANICAL EQUIPMENT MECHANICAL (E) EXISTING ITEM TO REMAIN 2. MOUNT EXTERIOR RECEPTACLES WITH CENTERLINE 24" AFG UNO C1 2| O |a MH MOUNTING HEIGHT (R) REMOVE ITEM AND DISPOSE OF PROPERLY (ER) RELOCATED ITEM AT NEW LOCATION (RL) REMOVE AND RELOCATE DEFE HORN/STROBE WITH PULL STATION DIRECTLY BELOW, MOUNT 80" AFF TO BOTTOM, OR 6" BELOW CEILING, WHICH EVER IS LOWER. $\langle \rangle$ EQUIPMENT TAG USED FOR EQUIPMENT IN CONCESSION C129 $\langle \cdot \rangle$ KITCHEN EQUIPMENT TAG ABBREVIATIONS POWER DISTRIBUTION RECEPTACLES LIGHTING A8 FIRE ALARM LEGEND A3 A6

<u>04101</u> <u>207-775-1059</u>

COPYRIGHT CHA Architecture

euse or reproduction tents of this docume permitted without w nission of CHA Arch

NOVATION Hall 0442 , Curtis I Maine 0 Academy, Castine, Ш $\overline{\mathbf{C}}$ Maine Maritime Pleasant Street

No. Date Descriptio Revision Schedule

> NOT FOR CONSTRUCTION

JOB NO. 076982


ISSUE

100% CONSTRUCTION

DOCUMENTS - ISSUED FOR BIDDING 1/22/2023

TITLE ELECTRICAL LEGEND

SHEET



RENOVATION

Hall 0442 , Curtis I Maine 0 HALL Maine Maritime / Pleasant Street, CURTIS

QUADRANT KEY PLAN

No. Date Descriptio Revision Schedule

NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE ELECTRICAL SITE DETAILS AND NOTES


JOB NO. 076982


ISSUE


11/22/2023

SHEET

ES0.1









Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

RENOVATIONS Academy, Curtis Hall Castine, Maine 0442 Maine Maritime A Pleasant Street,

CURTIS HALL

KEYNOTES- LIGHTING REMOVALS



No. Date Description Revision Schedule

> NOT FOR CONSTRUCTION

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 1 FIRST FLOOR LIGHTING REMOVALS & NEW PLANS

JOB NO. 076982

ISSUE

1/22/2023

TYPICAL DORM ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D6 ON SHEET E400.

TYPICAL LARGE DORM RESTROOM MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D4 ON SHEET E400.


4 TYPICAL LAUNDRY ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL X ON SHEET XX.

(5) TYPICAL SMALL STORAGE ROOM OR ELECTRICAL CLOSET- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED. REFER TO DETAIL X ON SHEET XX.

(6) CENTRAL INVERTER TO BE LOCATED IN THIS ROOM. THIS INVERTER SHALL SERVE ALL EMERGENCY LIGHTS ON THIS FLOOR WITHIN THE BOUNDARIES OF THIS PHASE.

TYPICAL SMALL RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL 05 ON SHEET E400,


KEYNOTES- NEW LIGHTING



Ν

SHEET

|EL101.1



49 DARTMOUTH STREI PORTLAND, MAINE 04101 207-775-1059

COPYRIGHT CHA Architecture Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

RENOVATIONS

Academy, Curtis Hall Castine, Maine 04421 **CURTIS HALL** Maine Maritime A Pleasant Street,

- UNLESS NOTED OTHERWISE, LIGHTING SHALL BE CONNECTED TO EXISTING CIRCUITING AND CONTROLS.
 IN STARWILLS, LIGHTING SHALL BE CONTINUOUSLY ON AT 50% OUTPUT AND RAISE TO 100% OUTPUT UPON ACTIVATION OF ANY OCCUPANCY SENSOR IN THE STARWILL.
 IN CORRIDORS, LIGHTING SHALL BE CONTINUOUSLY ON AT 50% OUTPUT AND RAISE TO 100% OUTPUT UPON ACTIVATION OF ANY OCCUPANCY SENSOR IN THE INDICATED SWITCH GROUP.

KEYNOTES- LIGHTING REMOVALS



QUADRANT KEY PLAN No. Date Description Revision Schedule

NOT FOR

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

JOB NO. 076982

ISSUE

1/22/2023

1 TYPICAL DORM ROOM. MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D6 ON SHEET E400.

(2) TYPICAL SMALL DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D3 ON SHEET E400.

TYPICAL LARGE DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D4 ON SHEET E400.

4 TYPICAL LAUNDRY ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL X ON SHEET XX.

(5) TYPICAL SMALL STORAGE ROOM OR ELECTRICAL CLOSET- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED. REFER TO DETAIL X ON SHEET XX.

(6) CENTRAL INVERTER TO BE LOCATED IN THIS ROOM, THIS INVERTER SHALL SERVE ALL EMERGENCY LIGHTS ON THIS FLOOR WITHIN THE BOUNDARIES OF THIS PHASE,

TYPICAL SMALL RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL 05 ON SHEET E400,


KEYNOTES- NEW LIGHTING

THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUP ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVELY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVELY UNDER CONSTRUCTION, SEE A2. MEPDOD FOR AS ERVICE TO OCCUPIED AREAS SHAN MAINTAIN SERVICE TO OCCUPIED AREAS, INTERRUPTIONS IN SERVICE TO OCCUPIED AREAS SHAN SEE STREET MEPDOD FOR ADDITIONAL BYFORMATION AND PRASHING MOTES.



TITLE
PHASE 1 SECOND
FLOOR LIGHTING
REMOVALS & NEW
PLANS Ν

SHEET EL101.2 TRUE NORTH



49 DARTMOUTH STRE
PORTLAND, MAINE
04101
207-775-1059

COPYRIGHT CHA Architecture

Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

RENOVATIONS Academy, Curtis Hall Castine, Maine 0442 **CURTIS HALL** Maine Maritime A Pleasant Street,

QUADRANT KEY PLAN No. Date Description Revision Schedule

NOT FOR

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

TITLE PHASE 1 THIRD FLOOR LIGHTING REMOVALS & NEW PLANS

JOB NO. 076982

ISSUE

1/22/2023

1 TYPICAL DORM ROOM. MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D6 ON SHEET E400.

(2) TYPICAL SMALL DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D3 ON SHEET E400.

(3) TYPICAL LARGE DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D4 ON SHEET E400.

KEYNOTES- LIGHTING REMOVALS

4 TYPICAL LAUNDRY ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL X ON SHEET XX.


(5) TYPICAL SMALL STORAGE ROOM OR ELECTRICAL CLOSET- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED. REFER TO DETAIL X ON SHEET XX.

(6) CENTRAL INVERTER TO BE LOCATED IN THIS ROOM, THIS INVERTER SHALL SERVE ALL EMERGENCY LIGHTS ON THIS FLOOR WITHIN THE BOUNDARIES OF THIS PHASE,

TYPICAL SMALL RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL 05 ON SHEET E400,

KEYNOTES- NEW LIGHTING


THIS PROJECT IS SCHEDULED TO BE COMPLETED IN MULTIPLE PHASES, THE OWNER WILL OCCUP ALL PORTIONS OF THE BUILDING THAT ARE NOT ACTIVELY UNDER CONSTRUCTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN SERVICES TO ALL PARTS OF THE BUILDING NOT ACTIVELY UNDER CONSTRUCTION, SEE A2. MEPDOD FOR AS ERVICE TO OCCUPIED AREAS SHAN MAINTAIN SERVICE TO OCCUPIED AREAS, INTERRUPTIONS IN SERVICE TO OCCUPIED AREAS SHAN SEE STREET MEPDOD FOR ADDITIONAL BYFORMATION AND PRASHING MOTES.



Ν

SHEET

EL101.3



Reuse or reproduction of the contents of this document is no permitted without written permission of CHA Architecture

RENOVATIONS Academy, Curtis Hall Castine, Maine 0442

CURTIS HALL

Maine Maritime A Pleasant Street, (

KEYNOTES- LIGHTING REMOVALS

- UNLESS NOTED OTHERWISE, LIGHTING SHALL BE CONNECTED TO EXISTING CIRCUITING AND CONTROLS.
 IN STARWILLS, LIGHTING SHALL BE CONTINUOUSLY ON AT 50% OUTPUT AND RAISE TO 100% OUTPUT UPON ACTIVATION OF ANY OCCUPANCY SENSOR IN THE STARWILL.
 IN CORRIDORS, LIGHTING SHALL BE CONTINUOUSLY ON AT 50% OUTPUT AND RAISE TO 100% OUTPUT UPON ACTIVATION OF ANY OCCUPANCY SENSOR IN THE INDICATED SWITCH GROUP.



No. Date Description Revision Schedule

NOT FOR

100% CONSTRUCTION DOCUMENTS - ISSUED FOR BIDDING

JOB NO. 076982

ISSUE

1/22/2023

1 TYPICAL DORM ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D6 ON SHEET E400.

(2) TYPICAL SMALL DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D3 ON SHEET E400.

TYPICAL LARGE DORM RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL D4 ON SHEET E400.

4 TYPICAL LAUNDRY ROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL X ON SHEET XX.

(5) TYPICAL SMALL STORAGE ROOM OR ELECTRICAL CLOSET- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED. REFER TO DETAIL X ON SHEET XX.

(6) CENTRAL INVERTER TO BE LOCATED IN THIS ROOM, THIS INVERTER SHALL SERVE ALL EMERGENCY LIGHTS ON THIS FLOOR WITHIN THE BOUNDARIES OF THIS PHASE,

TYPICAL SMALL RESTROOM- MOUNT NEW FIXTURES IN SAME PLACE AS EXISTING FIXTURES BEING REMOVED, REFER TO DETAIL 05 ON SHEET E400,

KEYNOTES- NEW LIGHTING



Ν TRUE NORTH

SHEET

EL101.4

TITLE
PHASE 1 FOURTH
FLOOR LIGHTING
REMOVALS & NEW
PLANS

