

To: Prospective Bidders

From:

WBRC Inc.

PO Box 1428

44 Central Street

Bangor, ME 04402

(207) 947-4511

www.wbrcinc.com

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated August 27, 2024, as noted below. Acknowledge receipt of the Addendum on the submitted Bidding Documents. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of the following:

- Clarifications/Answers to Questions

CLARIFICATIONS/ANSWERS TO QUESTIONS:

1. PermaTrak's drawings state that railings and connection are by others. Please confirm the contractor is expected to provide design on the handrails.
"By Others" designation on PermaTrak drawings indicate limit of information provided on drawings. Contractor is responsible for construction of handrails and connecting handrails to footbridge. Performance-based design is required by the contractor for handrail and handrail connection to footbridge. Refer to specification section 05 73 11 "Aluminum Railings and Accessories" which provides performance and submittal requirements for the hand rails as well as PT04 on the PermTrak drawings for connection details between the handrail and the concrete footbridge.
2. PermaTrak's drawings state helical piers are to be designed by others. Please confirm the contractor is expected to provide design on the helical piles.
"By Others" designation on PermaTrak drawings indicate limit of information provided on drawings. Contractor is responsible for construction of helical piers and associated earthwork and appurtenances. Performance-based design is required for helical piers. Refer to the submittal requirements on sheet Helical Notes prepared by PermaTrak.

END OF ADDENDUM