



ADDENDUM NO. 1 – August 29, 2024

**RE: BUILDING #260 AASF ROOF REPAIR PROJECT
BANGOR EAST TRAINING SITE
92 Hayes Street
Bangor, ME 04401**

**DFE PN 23R24-404-ABC
GALE JN 842980**

FROM: Gale Associates, Inc.
5 Moulton Street
Portland, ME 04101

TO: Rob Palmer
Department of Defense, Veterans and Emergency Management (DVEM)
Military Bureau, Joint Headquarters, Maine National Guard
194 Winthrop Street, Building #7, Camp Keyes
Augusta, Maine 04333-0033
Email: robert.w.palmer.nfg@army.mil

The following Request for Information (RFI) items were received by Gale from prospective bidders and shall be incorporated into the Addendum to be prepared and issued by DVEM. The RFI's are attached.

QUESTIONS

ITEM 1. Bid Time Extension

Question: Was wondering if it is possible to get deadline extension as will need more time?

Clarification: There will be no extension of the bid deadline. Refer to Section 00 11 13 Notice to Contractors and 00 21 13 Instructions to Bidders

ITEM 2. Roof Access Door to Roof D1

Question: Are we removing and replacing with new door on area D-1 and D-2 (G105 photo 21)?

Clarification: There is only one (1) door leading onto Roof D1 which shall be removed and replaced and is shown in Photo 21 on Drawing G105.

ITEM 3. Roof Drains

Question: One more question, are we reusing the drains or replacing with new?

Clarification: There are no drains that are to be reused. All drains on all roof areas, including any secondary drains shall be removed and replaced.

END OF ADDENDUM ONE