

A.E. Hodsdon Engineers
10 Common Street
Waterville, Maine 04901

Hallowell Boating Facility Renovations
for the Department of Agriculture
Conservation & Forestry
Augusta, Maine

Addendum No. 3
August 22, 2019

The following are clarifications to the Contract Document.

A. CONTRACT DOCUMENTS:

1. **MEASUREMENT AND PAYMENT, ITEM 7 – 4' DIA. CONCRETE CATCH BASINS AND STORM DRAIN PIPING.** There will only be one catch basin not three.
2. **MEASUREMENT AND PAYMENT, ITEM 9 – BITUMINOUS CURBING.** Measurement for this item shall be lump sum. Delete plan quantity.
3. **SECTION 0283 - LOAM AND SEED, Page 0283-2, 0283.05 CONSTRUCTION METHODS,** Paragraph 1. Loam shall be rolled and the lime, fertilizer and seed shall be placed by hydroseeding only, not hand placed.

B. PLANS:

1. **SHEET NO. 1 – SITE PLAN.** Replace the 45-S Armor Flex with 55 Armor Flex by Contech.
2. **SHEET NO. 1 – SITE PLAN. NOTE:** Since hydroseeding is being applied, there is no need to mulch the seeded areas.
3. **SHEET NO. 2 – DETAILS, TYPICAL RIP-RAP DETAIL.** Replace Mirafi 500X geotextile with a nonwoven geotextile with a minimum grab tensile strength of 200 lbs, a trapezoid tear strength of 75 lbs and CBR puncture strength of 700 lbs. Acceptable product shall be L & M Supply, LM 1,000 NT, US Fabrics US 250 NW or approved equal.
4. **SHEET NO. 3 – RAMP.** Replace Mirafi 500X geotextile with a nonwoven geotextile with a minimum grab tensile strength of 200 lbs, a trapezoid tear strength of 75 lbs and CBR puncture strength of 700 lbs. Acceptable product shall be L & M Supply, LM 1,000 NT, US Fabrics US 250 NW or approved equal.

End of Addendum No. 3