


**Maine State Police Troop F Barracks
Roof Upgrades
Houlton, Maine**

Addendum #1



**ISSUE DATE:
10/23/18**

Maine State Police Troop F Barracks Roof Upgrades Houlton, Maine

THE FOLLOWING INFORMATION SHALL BE CONSIDERED TO BE A PART OF THE PROJECT. THE ATTACHED INFORMATION SHALL EITHER SUPPLEMENT, AMEND, OR REPLACE THE INFORMATION SHOWN ON THE DRAWINGS; BE SURE TO ACKNOWLEDGE RECEIPT OF THIS DOCUMENT ON THE BID FORM.

The following items/questions have been asked or commented on:

- 1. Roofing System: *Clarification:*** Roofing system shall be a fully adhered roofing system not a self-adhered roofing system.
- 2. Builders Risk Insurance: *Clarification:*** Builders Risk Insurance shall be provided by the Owner.
- 3. Brick Repointing: *Change:*** Mortar joint repointing shall occur up to and including the second row of brown accent brick above the roof line.

- END OF ADDENDUM #1-