

To: Prospective Bidders

From:
WBRC ARCHITECTS ENGINEERS
44 Central Street
Bangor, ME 04401-5116
(207) 947-4511
www.wbrcae.com

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated January 11, 2019, as noted below. Acknowledge receipt of the Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of the following:

- Clarifications
- Specification Changes
- Drawing Changes
- Sheet AE101

CLARIFICATIONS:

1. Wage rate determination: The contractor is responsible to contact the Maine Department of Labor Bureau of Labor Standards to clarify the occupation title for the type of work being performed by workers employed on the project.
2. New fire alarm devices shall be compatible with existing Notifier system.

SPECIFICATION CHANGES:

3. Section 12 36 61, Simulated Stone Countertops, Par. 2.1.A, DELETE in its entirety and REPLACE with:
“A. Solid Surface Material: Homogeneous solid sheets of filled plastic resin complying with ANSI SS1.
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Bradley Terreon OmniDeck.
 - b. Corian Solid Surface with integral bowl.”

DRAWING CHANGES:

4. Sheet AE101, Removals Plans and Floor Plans, DELETE sheet and REPLACE with attached sheet.

END OF ADDENDUM

