



NOTICE TO CONTRACTORS - ADDENDUM #2

May 22, 2019

PROJECT:

Gymnasium Maintenance Project
Project No. BREM 2954
NMCC, 33 Edgemont Drive
Presque Isle, Maine

GENERAL CONTRACTORS:

- 1) Rick Nadeau, A&L Construction, P.O. Box 1613, Presque Isle, Maine
- 2) Steve McHatten, PNM Construction, 104 Edgemont Drive, Presque Isle, Maine

SPECIFICATIONS:

SECTION 12 66 13

Telescopic Bleachers

1. Items not required and **to be deleted** from project include:

PART 2- PRODUCTS

2.01A - MANUFACTURED PRODUCTS

A. SEATING SYSTEM:

DELETE:

2.01A.1.g *MAXAM Dolly System*

2.01A.3 *Miscellaneous Product Accessories: operating handles and ventilating grills*

2.08A *Portable Hydraulic Dollies*

2.09A *Access Panels*, 2.09K *Rear Panel*, 2.09S *Transitional Top Steps*, and 2.09T *Cross Aisles*

ADD/CHANGE:

- 1.01.A.3 Summary- Front row to be manufactured and located with the correct row spacing to accept seat backs at a later date.

PLANS:

1. Door Schedule Sheet 4 reference to "Select white birch veneer, mineral core 90 min. fire rated entrance doors" refers to new doors. "Firelite 90 min. rated glazing" refers to new glazing not reuse existing.