

Lincoln/Haney Engineering Associates, Inc.

Structural Engineering Consultants

Michael A. Cunningham, P.E., LEED AP
Thad Gabryszewski, P.E., S.E.

ADDENDUM #1

DATE: November 26, 2019

PROJECT: Structural Improvements and Re-roofing at Quick/Platz Hall at Maine Maritime Academy
Castine, Maine

OWNER: State of Maine
Bureau of Real Estate Management
4th Floor, Cross State Office Building, 111 Sewall Street
77 State House Station
Augusta, ME 04333-0077

BID DATE: December 3, 2019

The contract documents dated November 5, 2019 are modified in accordance with this addendum as follows:

DESCRIPTION	<u>Relating to Specifications</u> 1. Section 00 11 13, Notice to Contractors: Revise the bid date to December 10, 2019 <u>Responses to Contractor Questions</u> 1. Question: Can bid be submitted electronically? Response: No. The state is not prepared to accept electronic bids at this time. 2. What is the live load capacity of the attic floor? Response: The attic floor has a live load capacity of 40 psf.
ATTACHMENTS	Specifications section 00 11 13 and Pre-Bid Meeting Attendee List

ENGINEER: By:	Lincoln/Haney Engineering Associates, Inc. Michael A. Cunningham, P.E., LEED AP
--------------------------------	--