



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017

DEPARTMENT ORDER

Maine Maritime Academy
Hancock County
Castine, Maine
A-78-71-Q-R/A

Departmental
Findings of Fact and Order
Air Emission License
Renewal and Amendment

FINDINGS OF FACT

After review of the air emission license renewal application, staff investigation reports, and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 Maine Revised Statutes (M.R.S.) § 344 and § 590, the Maine Department of Environmental Protection (Department) finds the following facts:

I. REGISTRATION

A. Introduction

Maine Maritime Academy (MMA) has applied to renew their Air Emission License for the operation of emission sources associated with their educational facility.

The equipment addressed in this license is located at 1 Pleasant St., Castine, Maine.

MMA has requested to install an additional generator at Curtis Hall designated Generator #1B, and replace Generator #4A, located at Platz Hall, with a new unit (Generator #4B) that was purchased in 2018 but never installed. Additionally, MMA has requested to remove the Engine Test Cell.

B. Emission Equipment

The following equipment is addressed in this air emission license:

Boilers

Equipment	Max. Capacity (MMBtu/hr)	Maximum Firing Rate	Fuel Type	Date of Manuf.	Date of Install.	Stack #
Dismukes Boiler #1	1.3	12.2	Distillate Fuel	2011	2011	3
Dismukes Boiler #2	1.3	12.2	Distillate Fuel	2011	2011	
Student Union #1	2.8	29.5	Distillate Fuel	2004	2004	6
Student Union #2	2.8	29.5	Distillate Fuel	2004	2004	
Library Boiler #1A	1.8	16.0	Distillate Fuel	2013	2013	7
Library Boiler #2A	1.8	16.0	Distillate Fuel	2013	2013	
Andrews Boiler #1	4.2	36.2	Distillate Fuel	2015	2016	4
Andrews Boiler #2	3.5	30.0	Distillate Fuel	2014	2014	5
Curtis Boiler #1A	3.4	28.0	Distillate Fuel	2014	2015	1

Equipment	Max. Capacity (MMBtu/hr)	Maximum Firing Rate	Fuel Type	Date of Manuf.	Date of Install.	Stack #
Curtis Boiler #2A	3.4	28.0	Distillate Fuel	2014	2014	2
Curtis Boiler #3A	3.4	28.0	Distillate Fuel	2014	2014	

MMA also has several small boilers, water heaters, and unit heaters not listed in the table above. These are considered insignificant emissions units because they are each rated below 1.0 MMBtu/hr, the heat input capacity level at or above which would require their inclusion in the license; therefore, these small boilers, water heaters, and unit heaters are not addressed further in this license.

Stationary Engines

Equipment	Max. Input Capacity (MMBtu/hr)	Rated Output Capacity (kW)	Fuel Type	Firing Rate (gal/hr)	Date of Manuf.	Date of Install.
Generator #1A (Curtis)	1.7	175	Distillate Fuel	12.3	1973	1973
Generator #1B * (Curtis)	4.8	500	Distillate Fuel	35.7	2025	2025
Generator #2A (Dock)	0.8	80	Distillate Fuel	5.6	1998	1998
Generator #3A (Smith Alexander)	0.6	300	Distillate Fuel	4.6	2018	2018
Generator #4B * (Library)	0.8	36	Propane	4.6	2018	2025
Generator #5A (Leavitt) Propane	1.5	100	Propane	16.9	2007	2008
Generator #6A (ABS)	1.6	150	Distillate Fuel	11.7	2014	2014
Generator #7A (Alfond)	1.0	65	Distillate Fuel	7.3	1995	2005
Engine Test Cell**	Variable	Variable	Variable	Variable	Variable	Variable
Generator #4A **	0.8	65	Propane	8.0	1995	2005

* This equipment is new

** This equipment has been removed

MMA may operate small stationary engines smaller than 0.5 MMBtu/hr. These engines are considered insignificant activities and are not required to be included in this license. However, they are still subject to applicable State and Federal regulations. More information regarding requirements for small stationary engines is available on the Department's website at the link below.

<http://www.maine.gov/dep/air/publications/docs/SmallRICEGuidance.pdf>

Additionally, MMA may operate portable engines used for maintenance or emergency-only purposes. These engines are considered insignificant activities and are not required to be included in this license. However, they may still be subject to applicable State and Federal regulations.

C. Definitions

Distillate Fuel means the following:

- Fuel oil that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials (ASTM) in ASTM D396;
- Diesel fuel oil numbers 1 or 2, as defined in ASTM D975;
- Kerosene, as defined in ASTM D3699;
- Biodiesel, as defined in ASTM D6751; or
- Biodiesel blends, as defined in ASTM D7467.

Records or Logs mean either hardcopy or electronic records.

D. Application Classification

All rules, regulations, or statutes referenced in this air emission license refer to the amended version in effect as of the date this license was issued.

MMA has applied to renew currently licensed emission units as well as amend their license as addressed in Section I(A) above.

The modification of a minor source is considered a major or minor modification based on whether or not expected emission increases exceed the “Significant Emissions” levels as defined in the Department’s *Definitions Regulation*, 06-096 Code of Maine Rules (C.M.R.) ch. 100. The emission increases are determined by subtracting the current licensed annual emissions preceding the modification from the maximum future licensed annual emissions, as follows:

Pollutant	Current License (tpy)	Future License (tpy)	Net Change (tpy)	Significant Emission Levels
PM	13.3	4.3	-9.0	100
PM ₁₀	13.3	4.3	-9.0	100
PM _{2.5}	13.3	4.3	-9.0	100
SO ₂	70.2	0.2	-70.0	100
NO _x	56.6	7.3	-49.3	100
CO	16.7	2.2	-14.5	100
VOC	3.3	0.3	-3.0	100

Therefore, this license is considered to be both a renewal and a minor modification and has been processed through *Major and Minor Source Air Emission License Regulations*, 06-096 Code of Maine Rules C.M.R. ch. 115.

E. Facility Classification

With the operating hours restriction on the emergency generators and the distillate fuel limit on the boilers, the facility is licensed as follows:

- As a synthetic minor source of air emissions for criteria pollutants, because MMA is subject to license restrictions that keep facility emissions below major source thresholds for NO_x; and
- As an area source of hazardous air pollutants (HAP), because the licensed emissions are below the major source thresholds for HAP.

II. BEST PRACTICAL TREATMENT (BPT)

A. Introduction

In order to receive a license, the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in *Definitions Regulation*, 06-096 C.M.R. ch. 100. Separate control requirement categories exist for new and existing equipment.

BPT for new sources and modifications requires a demonstration that emissions are receiving Best Available Control Technology (BACT), as defined in *Definitions Regulation*, 06-096 C.M.R. ch. 100. BACT is a top-down approach to selecting air emission controls considering economic, environmental, and energy impacts.

BPT for existing emissions equipment means that method which controls or reduces emissions to the lowest possible level considering:

- the existing state of technology;
- the effectiveness of available alternatives for reducing emissions from the source being considered; and
- the economic feasibility for the type of establishment involved.

B. Boilers

MMA operates 11 boilers for heat at buildings throughout the campus. Dismukes Boilers #1 and #2 are each rated at 1.3 MMBtu/hr and exhaust through a common stack designated Stack #3. Student Union Boilers #1 and #2 are each rated at 2.8 MMBtu/hr and exhaust through a common stack designated Stack #6. Library Boilers #1A and #2A are each rated at 1.8 MMBtu/hr and exhaust through a common stack designated Stack #7. Andrews Boilers #1 and #2 are rated at 4.2 and 3.5 MMBtu/hr, respectively, and exhaust through Stacks #4 and #5. Curtis Boiler #1A is rated at 3.4 MMBtu/hr and exhausts through

Stack #1. Curtis Boilers #2A and #3A are each rated at 3.4 MMBtu/hr and exhaust through a common stack designated Stack #2.

All of the above boilers fire distillate fuel exclusively. With limited exceptions, no person shall import, distribute, or offer for sale any distillate fuel with a sulfur content greater than 0.0015% by weight (15 ppm) pursuant to 38 M.R.S. § 603-A(2)(A)(3). Therefore, the distillate fuel purchased or otherwise obtained for use in the above boilers shall not exceed 0.0015% by weight (15 ppm).

1. BPT Findings

The BPT emission limits for the boilers were based on the following:

- PM/PM₁₀/PM_{2.5} – 0.12 lb/MMBtu based on 06-096 C.M.R. ch. 115, BPT for Dismukes Boilers #1 and #2, Andrews Boiler #1, and Student Union Boilers #1 and #2.
0.08 lb/MMBtu based on 06-096 C.M.R. ch. 115, BPT for Curtis Boilers #1A, #2A, and #3A, Andrews Boiler #2, and Library Boilers #1 and #2.
- SO₂ – based on firing distillate fuel with a maximum sulfur content of 0.0015% by weight
- NO_x – 20 lb/1,000 gal based on AP-42 Table 1.3-1 dated 5/10
- CO – 5 lb/1,000 gal based on AP-42 Table 1.3-1 dated 5/10
- VOC – 0.34 lb/1,000 gal based on AP-42 Table 1.3-3 dated 5/10
- Visible Emissions – 06-096 C.M.R. ch. 115, BPT

The BPT emission limits for Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A are the following:

Unit	Pollutant	lb/MMBtu
Andrews Boiler #1	PM	0.08
Andrews Boiler #2	PM	0.08
Curtis Boiler #1A	PM	0.08
Curtis Boiler #2A	PM	0.08
Curtis Boiler #3A	PM	0.08

Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	PM _{2.5} (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Dismukes Boiler #1	0.16	0.16	0.16	0.01	0.25	0.07	0.01
Dismukes Boiler #2	0.16	0.16	0.16	0.01	0.25	0.07	0.01
Student Union #1	0.34	0.34	0.34	0.01	0.59	0.15	0.02
Student Union #2	0.34	0.34	0.34	0.01	0.59	0.15	0.02
Library Boiler #1A	0.15	0.15	0.15	0.01	0.32	0.08	0.01

Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	PM _{2.5} (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Library Boiler #2A	0.15	0.15	0.15	0.01	0.32	0.08	0.01
Andrews Boiler #1	0.51	0.51	0.51	0.01	0.73	0.19	0.02
Andrews Boiler #2	0.28	0.28	0.28	0.01	0.60	0.15	0.02
Curtis Boiler #1A	0.28	0.28	0.28	0.01	0.56	0.14	0.01
Curtis Boiler #2A	0.28	0.28	0.28	0.01	0.56	0.14	0.01
Curtis Boiler #3A	0.28	0.28	0.28	0.01	0.56	0.14	0.01

Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A combined shall be limited to 500,000 gallons of distillate fuel use on a calendar year total basis.

2. Visible Emissions

Visible emissions from any stack venting Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A shall not exceed 20% opacity on a six-minute block average basis.

3. Periodic Monitoring

Periodic monitoring for Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A shall include recordkeeping to document fuel use both on a monthly and calendar year total basis. Documentation shall include the type of fuel used and sulfur content of the fuel.

4. New Source Performance Standards (NSPS): 40 C.F.R. Part 60, Subpart Dc

Due to their size, Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A are not subject to *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units* 40 C.F.R. Part 60, Subpart Dc for units greater than 10 MMBtu/hr manufactured after June 9, 1989. [40 C.F.R. § 60.40c]

5. National Emission Standards for Hazardous Air Pollutants (NESHAP): 40 C.F.R. Part 63, Subpart JJJJJ

Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A are subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources*, 40 C.F.R. Part 63, Subpart JJJJJ. The units are considered existing oil boilers. [40 C.F.R. §§ 63.11193 and 63.11195]

Applicable federal 40 C.F.R. Part 63, Subpart JJJJJ requirements include the following. Additional rule information can be found on the following website: <https://www.epa.gov/stationary-sources-air-pollution/compliance-industrial-commercial-and-institutional-area-source>.

a. Compliance Dates, Notifications, and Work Practice Requirements

(1) Boiler Tune-Up Program

(i) A boiler tune-up program shall be implemented. [40 C.F.R. § 63.11223]

(ii) Tune-ups shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

Boiler Category	Tune-Up Frequency
Oil fired boilers with a heat input capacity of ≤ 5 MMBtu/hr	Every 5 years

[40 C.F.R. § 63.11223(a) and Table 2]

(iii)The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted, not to exceed 72 months from the previous inspection. [40 C.F.R. § 63.11223(b)(1)]
2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 C.F.R. § 63.11223(b)(2)]
3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted, not to exceed 72 months from the previous inspection. [40 C.F.R. § 63.11223(b)(3)]
4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 C.F.R. § 63.11223(b)(4)]
5. Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 C.F.R. § 63.11223(b)(5)]
6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 C.F.R. § 63.11223(b)(7)]

(iv) Tune-Up Report: A tune-up report shall be maintained onsite and submitted to the Department and/or EPA upon request. The report shall contain the following information:

1. The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;
2. A description of any corrective actions taken as part of the tune-up of the boiler; and
3. The types and amounts of fuels used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.
[40 C.F.R. § 63.11223(b)(6)]

(2) Compliance Report

For every five-year compliance period, MMA shall prepare a compliance report by March 1st of the following year to document the information below for the five-year period. The report shall be maintained by the source and submitted to the Department and/or to the EPA upon request. The report must include the items contained in §§ 63.11225(b)(1) and (2), including the following:
[40 C.F.R. § 63.11225(b)]

- (i) Company name and address;
- (ii) A statement of whether the source has complied with all the relevant requirements of this Subpart;
- (iii) A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- (iv) The following certifications, as applicable:
 1. "This facility complies with the requirements in 40 C.F.R. § 63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
 2. "No secondary materials that are solid waste were combusted in any affected unit."
 3. "This facility complies with the requirement in §§ 63.11214(d) and 63.11223(g) to minimize the boiler's time spent during startup and shutdown and to conduct startups and shutdowns according to the manufacturer's recommended procedures or procedures specified for a boiler of similar design if manufacturer's recommended procedures are not available."

b. Recordkeeping

- (1) Records shall be maintained consistent with the requirements of 40 C.F.R. Part 63, Subpart JJJJJ including the following [40 C.F.R. § 63.11225(c)]:
 - (i) Copies of notifications and reports with supporting compliance documentation;
 - (ii) Identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned;
 - (iii) Records of the occurrence and duration of each malfunction of each applicable boiler; and
 - (iv) Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore the malfunctioning boiler.
- (2) Records shall be in a form suitable and readily available for expeditious review. Each record must be kept for 5 years following the date of each recorded action. Each record must be kept on-site or be accessible from a central location by computer or other means that instantly provides access at the site for at least 2 years after the date of each recorded action. The records may be maintained off-site for the remaining 3 years. [40 C.F.R. § 63.11225(d)] Note: Standard Condition (8) of this license requires all records be retained for six years; therefore, the five-year record retention requirement of Subpart JJJJJ shall be streamlined to the more stringent six-year requirement.

C. Generators

MMA operates eight emergency generators. Also with this air emission license, a new unit designated Generator #1B will be added, and Generator #4A will be replaced with a new unit designated Generator #4B which was purchased by MMA in 2018 and not installed previously. Generators #1A, #1B, #2A, #3A, #4B, #5A, #6A, and #7A are generator sets with each gen set consisting of an engine and an electrical generator. The emergency generators have engines rated at 1.7, 4.8, 0.8, 0.6, 0.8, 1.5, 1.6, and 1.0 MMBtu/hr, respectively. Generators #1A, #1B, #2A, #3A, #6A, and #7A fire distillate fuel, and Generators #4B and #5A both fire propane. The emergency generators were manufactured in 1973, 2025, 1998, 2018, 2018, 2007, 2014, and 1995, respectively.

1. BPT and BACT Findings

The BPT emission limits for Generators #1A, #2A, #3A, #5A, #6A, and #7A are based on the following:

Distillate Fuel

PM/PM ₁₀ /PM _{2.5}	–	0.12 lb/MMBtu from 06-096 C.M.R. ch. 115, BPT
SO ₂	–	Combustion of distillate fuel with a maximum sulfur content not to exceed 15 ppm (0.0015% sulfur by weight)
NO _x	–	4.41 lb/MMBtu from AP-42 Table 3.3-1 dated 10/96
CO	–	0.95 lb/MMBtu from AP-42 Table 3.3-1 dated 10/96
VOC	–	0.35 lb/MMBtu from AP-42 Table 3.3-1 dated 10/96
Visible Emissions	–	06-096 C.M.R. ch. 101

Propane

PM/PM ₁₀ /PM _{2.5}	–	0.05 lb/MMBtu from 06-096 C.M.R. ch. 115, BPT
SO ₂	–	0.000588 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
NO _x	–	2.27 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
CO	–	3.51 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
VOC	–	0.0296 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
Visible Emissions	–	06-096 C.M.R. ch. 101

The BACT emission limits for Generators #1B and #4B are based on the following:

Distillate Fuel

PM/PM ₁₀ /PM _{2.5}	–	0.12 lb/MMBtu from 06-096 C.M.R. ch. 103 for Generator #1B and 06-096 C.M.R. ch. 115, BACT for Generator #4B
SO ₂	–	Combustion of distillate fuel with a maximum sulfur content not to exceed 15 ppm (0.0015% sulfur by weight)
NO _x	–	3.2 lb/MMBtu from AP-42 Table 3.4-1 dated 10/96
CO	–	0.85 lb/MMBtu from AP-42 Table 3.4-1 dated 10/96
VOC	–	0.09 lb/MMBtu from AP-42 Table 3.4-1 dated 10/96
Visible Emissions	–	06-096 C.M.R. ch. 101

Propane

PM/PM ₁₀ /PM _{2.5}	–	0.05 lb/MMBtu from 06-096 C.M.R. ch. 115, BACT
SO ₂	–	0.000588 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
NO _x	–	2.27 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
CO	–	3.51 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
VOC	–	0.0296 lb/MMBtu from AP-42 Table 3.2-3 dated 10/24
Visible Emissions	–	06-096 C.M.R. ch. 101

The BPT and BACT emission limits for the generators are the following:

Unit	Pollutant	lb/MMBtu
Generator #1B	PM	0.12

Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	PM _{2.5} (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Generator #1A	0.21	0.21	0.21	0.01	7.5	1.62	0.60
Generator #1B	0.58	0.58	0.58	0.01	15.36	4.08	0.44
Generator #2A	0.10	0.10	0.10	0.01	3.53	0.76	0.28
Generator #3A	0.08	0.08	0.08	0.01	2.65	0.57	0.21
Generator #4B	0.04	0.04	0.04	0.01	1.82	2.81	0.03
Generator #5A	0.08	0.08	0.08	0.01	3.41	5.27	0.05
Generator #6A	0.20	0.20	0.20	0.01	7.06	1.52	0.56
Generator #7A	0.12	0.12	0.12	0.01	4.41	0.95	0.35

Visible emissions from Generators #1A, #2A, and #7A shall each not exceed 20% opacity on a six-minute block average basis except for periods of startup during which time MMA shall either meet the normal operating visible emissions standard or the following work practice standards and alternative visible emissions standard.

- The duration of the startup shall not exceed 30 minutes per event;
- Visible emissions shall not exceed 50% opacity on a six-minute block average basis; and
- MMA shall keep records of the date, time, and duration of each startup.

Use of the work practice standards and alternative visible emissions standard in lieu of the normal operating standard is limited to no more than once per day.

Note: This does not limit the engine to one startup per day. It only limits the use of the alternative emission standard to once per day.

Visible emissions from Generators #1B, #3A, #4B, #5A, and #6A shall each not exceed 20% opacity on a six-minute block average basis.

Generators #1A, #2A, and #7A shall each be limited to 100 hours of operation per calendar year, excluding operating hours during emergency situations. There is no limit on emergency operation. Each emergency generator shall be equipped with a non-resettable hour-meter to record operating time. To demonstrate compliance with the operating hours limit, MMA shall keep records of the total hours of operation and the hours of emergency operation for each unit.

Emergency generators are only to be operated for maintenance purposes and for situations arising from sudden and reasonably unforeseeable events beyond the control of the source. Emergency generators are not to be used for prime power when reliable

offsite power is available; nor to operate or to be contractually obligated to be available in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity.

2. Chapter 169

Generators #1A, #2A, #3A, #5A, #6A, and #7A were installed prior to the effective date of *Stationary Generators*, 06-096 C.M.R. ch. 169 and are therefore exempt from this rule pursuant to section 1.

Stationary Generators, 06-096 C.M.R. ch. 169 (Chapter 169), is applicable to Generators #1B and #4B. They are emergency generators powered by engines with a rated output of less than 1,000 brake horsepower (747 kW). Chapter 169 identifies emission standards for generator engines subject to this chapter and stack height requirements for certain generator engines subject to this chapter.

a. Chapter 169 Emission Standards Requirements

For Generators #1B and #4B, MMA shall comply with the emission standards for emergency generators by complying with the applicable standards contained in 40 C.F.R. Part 60, Subpart IIII and JJJJ. [06-096 C.M.R. ch. 169, § 4(B)(1)]

b. Chapter 169 Stack Height Requirements

Chapter 169 identifies stack height requirements for any stack used to exhaust a generator engine or combination of generator engines with a combined rated output equal to or greater than 1,000 brake horsepower (747 kW). Individual generator engines with a maximum power capacity of less than 300 kW are not included in the assessment of the combined generator power capacity exhausted through a common stack. [06-096 C.M.R. ch. 169, § 6]

There are no stack height requirements in Chapter 169 applicable to Generators #1B and #4B because each exhausts through its own stack and their rated output is less than 1,000 brake horsepower (747 kilowatts) each.
[06-096 C.M.R. ch. 169, § 6]

3. New Source Performance Standards (NSPS) 40 C.F.R. Part 60, Subpart IIII

Due to the dates of manufacture, Generators #1A, #2A, and #7A are not subject to the NSPS *Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (CI ICE)*, 40 C.F.R. Part 60, Subpart IIII since the units were manufactured prior to April 1, 2006. [40 C.F.R. § 60.4200]

40 C.F.R. Part 60, Subpart IIII is applicable to Generators #1B, #3A and #6A since the units were ordered after July 11, 2005, and manufactured after April 1, 2006.
[40 C.F.R. § 60.4200]

By meeting the requirements of 40 C.F.R. Part 60, Subpart IIII, the units also meet the requirements found in the *National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*, 40 C.F.R. Part 63, Subpart ZZZZ. [40 C.F.R. § 63.6590(c)]

A summary of the currently applicable federal 40 C.F.R. Part 60, Subpart IIII requirements are listed below.

a. Emergency Engine Designation and Operating Criteria

Under 40 C.F.R. Part 60, Subpart IIII, a stationary reciprocating internal combustion engine (ICE) is considered an **emergency** stationary ICE (emergency engine) as long as the engine is operated in accordance with the following criteria. Operation of an engine outside of the criteria specified below may cause the engine to no longer be considered an emergency engine under 40 C.F.R. Part 60, Subpart IIII, resulting in the engine being subject to requirements applicable to **non-emergency** engines.

(1) Emergency Situation Operation (On-Site)

There is no operating time limit on the use of an emergency engine to provide electrical power or mechanical work during an emergency situation. Examples of use of an emergency engine during emergency situations include the following:

- Use of an engine to produce power for critical networks or equipment (including power supplied to portions of a facility) because of failure or interruption of electric power from the local utility (or the normal power source, if the facility runs on its own power production);
- Use of an engine to mitigate an on-site disaster;
- Use of an engine to pump water in the case of fire, flood, natural disaster, or severe weather conditions; and
- Similar instances.

(2) Non-Emergency Situation Operation

An emergency engine may be operated up to a maximum of 100 hours per calendar year for maintenance checks, readiness testing, and other non-emergency situations as described below.

- (i) An emergency engine may be operated for a maximum of 100 hours per calendar year for maintenance checks and readiness testing, provided that the tests are recommended by federal, state, or local government; the

manufacturer; the vendor; the regional transmission organization or equivalent balancing authority and transmission operator; or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE more than 100 hours per calendar year.

- (ii) An emergency engine may be operated for up to 50 hours per calendar year for other non-emergency situations. **However, these operating hours are counted as part of the 100 hours per calendar year operating limit described in paragraph (2) and (2) (i) above.**

The 50 hours per calendar year operating limit for other non-emergency situations cannot be used for peak shaving, demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

[40 C.F.R. §§ 60.4211(f) and 60.4219]

b. 40 C.F.R. Part 60, Subpart IIII Requirements

(1) Manufacturer Certification Requirement

The engines shall be certified by the manufacturer as meeting the emission standards for new nonroad compression ignition engines found in 40 C.F.R. § 60.4202. [40 C.F.R. § 60.4205(b)]

(2) Ultra-Low Sulfur Fuel Requirement

The fuel fired in the engines shall not exceed 15 ppm sulfur (0.0015% sulfur). [40 C.F.R. § 60.4207(b)]

(3) Non-Resettable Hour Meter Requirement

A non-resettable hour meter shall be installed and operated on each engine. [40 C.F.R. § 60.4209(a)]

(4) Operation and Maintenance Requirements

The engines shall be operated and maintained according to the manufacturer's emission-related written instructions. MMA may only change those emission-related settings that are permitted by the manufacturer. [40 C.F.R. § 60.4211(a)]

MMA shall have available for review by the Department a copy of the manufacturer's emission-related written instructions for engine operation and maintenance. [06-096 C.M.R. ch. 115, BPT]

(5) Annual Time Limit for Maintenance and Testing

As emergency engines, the units shall each be limited to 100 hours/year for maintenance checks and readiness testing. Up to 50 hours/year of the 100 hours/year may be used in non-emergency situations (this does not include peak shaving, demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity). [40 C.F.R. § 60.4211(f)]

(6) Initial Notification Requirement

No initial notification is required under 40 C.F.R. Part 60, Subpart IIII for emergency engines. [40 C.F.R. § 60.4214(b)]

(7) Recordkeeping

MMA shall keep records that include the hours of operation of each engine recorded through the non-resettable hour meter. Documentation shall include the number of hours each unit operated for emergency purposes, the number of hours each unit operated for non-emergency purposes, and the reason each engine was in operation during each time.
[40 C.F.R. § 60.4214(b)]

4. New Source Performance Standard 40 C.F.R. Part 60, Subpart JJJJ

Standards of Performance for Spark Ignition Internal Combustion Engines, 40 C.F.R. Part 60, Subpart JJJJ is applicable to Generators #4B and #5A since the units were ordered after June 12, 2006, and manufactured after January 1, 2009. [40 C.F.R. § 60.4230] By meeting the requirements of 40 C.F.R. Part 60, Subpart JJJJ, the units also meet the requirements found in the *National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*, 40 C.F.R. Part 63, Subpart ZZZZ. [40 C.F.R. § 63.6590(c)]

A summary of the currently applicable federal 40 C.F.R. Part 60, Subpart JJJJ requirements is listed below.

a. Emergency Engine Designation and Operating Criteria

Under 40 C.F.R. Part 60, Subpart JJJJ, a stationary reciprocating internal combustion engine (ICE) is considered an emergency stationary ICE (emergency engine) as long as the engine is operated in accordance with the following criteria. Operation of an engine outside of the criteria specified below may cause the engine to no longer be considered an emergency engine under 40 C.F.R. Part 60, Subpart JJJJ, resulting in the engine being subject to requirements applicable to non-emergency engines.

(1) Emergency Situation Operation (On-Site)

There is no operating time limit on the use of an emergency engine to provide electrical power or mechanical work during an emergency situation. Examples of use of an emergency engine during emergency situations include the following:

- Use of an engine to produce power for critical networks or equipment (including power supplied to portions of a facility) because of failure or interruption of electric power from the local utility (or the normal power source, if the facility runs on its own power production);
- Use of an engine to mitigate an on-site disaster;
- Use of an engine to pump water in the case of fire, flood, natural disaster, or severe weather conditions; and
- Similar instances.

(2) Non-Emergency Situation Operation

An emergency engine may be operated up to a maximum of 100 hours per calendar year for maintenance checks, readiness testing, and other non-emergency situations as described below.

- (i) An emergency engine may be operated for a maximum of 100 hours per calendar year for maintenance checks and readiness testing, provided that the tests are recommended by federal, state, or local government; the manufacturer; the vendor; the regional transmission organization or equivalent balancing authority and transmission operator; or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE more than 100 hours per calendar year.
- (ii) An emergency engine may be operated for up to 50 hours per calendar year for other non-emergency situations. **However, these operating hours are counted as part of the 100 hours per calendar year operating limit described in paragraph (2) and (2) (i) above.**

The 50 hours per calendar year operating limit for other non-emergency situations cannot be used for peak shaving, demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

b. 40 C.F.R. Part 60, Subpart JJJJ Requirements

(1) Manufacturer Certification Requirement

The engines shall be certified by the manufacturer as meeting the emission standards for new nonroad spark ignition engines found in 40 C.F.R. Part 60, Subpart JJJJ, Table 1. [40 C.F.R. § 60.4233]

(2) Non-Resettable Hour Meter Requirement

A non-resettable hour meter shall be installed and operated on each engine. [40 C.F.R. § 60.4237]

(3) Operation and Maintenance Requirement

The engines shall be operated and maintained according to the manufacturer's written instructions or procedures developed by MMA that are approved by the engine manufacturer. MMA may only change those settings that are permitted by the manufacturer. [40 C.F.R. § 60.4243]

MMA shall have available for review by the Department a copy of the manufacturer's written instructions or procedures developed by MMA that are approved by the engine manufacturer for engine operation and maintenance. [06-096 C.M.R. ch. 115, BPT]

(4) Annual Time Limit for Maintenance and Testing

As emergency engines, the units shall each be limited to 100 hours/year for maintenance and testing. The emergency engines may operate up to 50 hours per year in non-emergency situations, but those 50 hours are included in the 100 hours total allowed for maintenance and testing. The 50 hours for non-emergency use cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity. [40 C.F.R. § 60.4243(d)]

(5) Recordkeeping

MMA shall keep records that include maintenance conducted on the engines and the hours of operation of each engine recorded through the non-resettable hour meter. Documentation shall include the number of hours each unit operated for emergency purposes, the number of hours each unit operated for non-emergency purposes, and the reason each engine was in operation during each time. [40 C.F.R. § 60.4245(b)]

5. National Emission Standards for Hazardous Air Pollutants (NESHAP):
40 C.F.R. Part 63, Subpart ZZZZ

National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, 40 C.F.R. Part 63, Subpart ZZZZ is not applicable to Generators #1A, #2A, and #7A. The units are considered existing, emergency, stationary, reciprocating internal combustion engines at an area HAP source. However, they are considered exempt from the requirements of 40 C.F.R. Part 63, Subpart ZZZZ since they are categorized as institutional emergency engines and they do not operate or are not contractually obligated to be available in a demand response program, during a period of deviation from standard voltage or frequency, or for supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in 40 C.F.R. § 63.6640(f)(4)(ii).

Operation of any emergency engine in a demand response program, during a period of deviation from standard voltage or frequency, or for supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in 40 C.F.R. § 63.6640(f)(4)(ii), would cause the engine to be subject to 40 C.F.R. Part 63, Subpart ZZZZ and require compliance with all applicable requirements.

D. General Process Emissions

Visible emissions from any general process source shall not exceed 20% opacity on a six-minute block average basis.

E. Fugitive Emissions

MMA shall not cause emissions of any fugitive dust during any period of construction, reconstruction, or operation without taking reasonable precautions. Such reasonable precautions shall be included in the facility's continuing program of best management practices for suppression of fugitive particulate matter. See 06-096 C.M.R. ch. 101, § 4(C) for a list of potential reasonable precautions.

MMA shall not cause or allow visible emissions within 20 feet of ground level, measured as any level of opacity and not including water vapor, beyond the legal boundary of the property on which such emissions occur. Compliance with this standard shall be determined pursuant to 40 C.F.R. Part 60, Appendix A, Method 22.

F. Emission Statements

With the removal of the Engine Test Cell, maximum licensed emissions will be below the applicability threshold of *Emission Statements*, 06-096 C.M.R. ch. 137 (Ch. 137); therefore, MMA will no longer be subject to this rule upon issuance of this license renewal and amendment. In order to maintain compliance with reporting requirements of Ch. 137,

MMA shall maintain the following records for the period of calendar year 2025 during which MMA was still subject to Ch. 137:

1. The amount of distillate fuel fired in the boilers (each) on a monthly basis;
2. The emissions calculations for the Engine Test Cell on a monthly basis; and
3. Hours each generator was operating on a monthly basis.

G. Annual Emissions

The table below provides an estimate of facility-wide annual emissions for the purposes of calculating the facility's annual air license fee and establishing the facility's potential to emit (PTE). Only licensed equipment is included, i.e., emissions from insignificant activities are excluded. Similarly, unquantifiable fugitive particulate matter emissions are not included except when required by state or federal regulations. Maximum potential emissions were calculated based on the following assumptions:

- Firing 500,000 gal/yr distillate fuel in the boilers;
- Operating the generators for 100 hrs/yr each of non-emergency operation;

This information does not represent a comprehensive list of license restrictions or permissions. That information is provided in the Order section of this license.

Total Licensed Annual Emissions for the Facility
Tons/year
(used to calculate the annual license fee)

	PM	PM ₁₀	PM _{2.5}	SO ₂	NO _x	CO	VOC
Boilers	4.2	4.2	4.2	0.1	5.0	1.3	0.1
Generators	0.1	0.1	0.1	0.1	2.3	0.9	0.2
Total TPY	4.3	4.3	4.3	0.2	7.3	2.2	0.3

Pollutant	Tons/year
Single HAP	7.9
Total HAP	19.9

III. AMBIENT AIR QUALITY ANALYSIS

The level of ambient air quality impact modeling required for a minor source is determined by the Department on a case-by-case basis. In accordance with 06-096 C.M.R. ch. 115, an ambient air quality impact analysis is not required for a minor source if the total licensed annual emissions of any pollutant released do not exceed the following levels and there are no extenuating circumstances:

Pollutant	Tons/Year
PM ₁₀	25
PM _{2.5}	15
SO ₂	50
NO _x	50
CO	250

The total licensed annual emissions for the facility are below the emission levels contained in the table above and there are no extenuating circumstances; therefore, an ambient air quality impact analysis is not required as part of this license.

This determination is based on information provided by the applicant regarding the expected construction and operation of the proposed and licensed emission units. If the Department determines that any parameter (e.g., stack size, configuration, flow rate, emission rates, nearby structures, etc.) deviates from what was included in the application, the Department may require MMA to submit additional information and may require an ambient air quality impact analysis at that time.

ORDER

Based on the above Findings and subject to conditions listed below, the Department concludes that the emissions from this source:

- will receive Best Practical Treatment,
- will not violate applicable emission standards, and
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-78-71-Q-R/A subject to the following conditions.

Severability. The invalidity or unenforceability of any provision of this License or part thereof shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S. § 347-C).

- (2) The licensee shall acquire a new or amended air emission license prior to beginning actual construction of a modification, unless specifically provided for in Chapter 115.
[06-096 C.M.R. ch. 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen (18) months after receipt of such approval or if construction is discontinued for a period of eighteen (18) months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 C.M.R. ch. 115]
- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction, reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 C.M.R. ch. 115]
- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S. § 353-A. [06-096 C.M.R. ch. 115] Payment of the annual air emission license fee for MMA is due by the end of August of each year.
[38 M.R.S. § 353-A(3)]
- (6) The license does not convey any property rights of any sort, or any exclusive privilege.
[06-096 C.M.R. ch. 115]
- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 C.M.R. ch. 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six (6) years. The records shall be submitted to the Department upon written request.
[06-096 C.M.R. ch. 115]
- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license.
[06-096 C.M.R. ch. 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license.
[06-096 C.M.R. ch. 115]

- (11) In accordance with the Department's air emission compliance test protocol and 40 C.F.R. Part 60 or other method approved or required by the Department, the licensee shall:
- A. Perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:
 - 1. Within sixty (60) calendar days of receipt of a notification to test from the Department or EPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
 - 2. Pursuant to any other requirement of this license to perform stack testing.
 - B. Install or make provisions to install test ports that meet the criteria of 40 C.F.R. Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and
 - C. Submit a written report to the Department within thirty (30) days from the date of test completion.
[06-096 C.M.R. ch. 115]
- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. Within thirty (30) days following receipt of the written test report by the Department, or another alternative timeframe approved by the Department, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 C.F.R. Part 60 or other method approved or required by the Department; and
 - B. The days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
 - C. The licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.
[06-096 C.M.R. ch. 115]

- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the EPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or license requirement. [06-096 C.M.R. ch. 115]
- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emissions and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two (2) days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 C.M.R. ch. 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status. [06-096 C.M.R. ch. 115]
- (16) The licensee shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard (38 M.R.S. § 605). [06-096 C.M.R. ch. 115]

SPECIFIC CONDITIONS

(17) Boilers

A. Fuel

- 1. Total fuel use for Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A combined shall not exceed 500,000 gal/yr of distillate fuel, based on a calendar year total basis. [06-096 C.M.R. ch. 115, BPT]
- 2. The facility shall not purchase or otherwise obtain distillate fuel with a maximum sulfur content that exceeds 0.0015% by weight (15 ppm). [06-096 C.M.R. ch. 115, BPT]
- 3. Compliance shall be demonstrated by fuel records showing the quantity, type, and percent sulfur of the fuel delivered. Records of annual fuel use shall be kept on a monthly and calendar year basis. Fuel sulfur content compliance shall be demonstrated by fuel delivery receipts from the supplier, a statement from the supplier that the fuel delivered meets Maine's fuel sulfur content standards, certificate of analysis, or testing of fuel in the tank on-site. [06-096 C.M.R. ch. 115, BPT]

B. Emissions shall not exceed the following:

Emission Unit	Pollutant	lb/MMBtu	Origin and Authority
Andrews Boiler #1	PM	0.08	06-096 C.M.R. ch. 115, BPT
Andrews Boiler #2	PM	0.08	06-096 C.M.R. ch. 115, BPT
Curtis Boiler #1A	PM	0.08	06-096 C.M.R. ch. 115, BPT
Curtis Boiler #2A	PM	0.08	06-096 C.M.R. ch. 115, BPT
Curtis Boiler #3A	PM	0.08	06-096 C.M.R. ch. 115, BPT

C. Emissions shall not exceed the following [06-096 C.M.R. ch. 115, BPT]:

Emission Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	PM _{2.5} (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Dismukes Boiler #1	0.16	0.16	0.16	0.01	0.25	0.07	0.01
Dismukes Boiler #2	0.16	0.16	0.16	0.01	0.25	0.07	0.01
Student Union #1	0.34	0.34	0.34	0.01	0.59	0.15	0.02
Student Union #2	0.34	0.34	0.34	0.01	0.59	0.15	0.02
Library Boiler #1A	0.15	0.15	0.15	0.01	0.32	0.08	0.01
Library Boiler #2A	0.15	0.15	0.15	0.01	0.32	0.08	0.01
Andrews Boiler #1	0.51	0.51	0.51	0.01	0.73	0.19	0.02
Andrews Boiler #2	0.28	0.28	0.28	0.01	0.60	0.15	0.02
Curtis Boiler #1A	0.28	0.28	0.28	0.01	0.56	0.14	0.01
Curtis Boiler #2A	0.28	0.28	0.28	0.01	0.56	0.14	0.01
Curtis Boiler #3A	0.28	0.28	0.28	0.01	0.56	0.14	0.01

D. Visible emissions from any stack venting Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A shall not exceed 20% opacity on a six-minute block average basis. [06-096 C.M.R. ch. 115, BPT]

E. MMA shall comply with all requirements of 40 C.F.R. Part 63, Subpart JJJJJ applicable to Dismukes Boilers #1 and #2, Student Union Boilers #1 and #2, Library Boilers #1A and #2A, Andrews Boilers #1 and #2, and Curtis Boilers #1A, #2A, and #3A including, but not limited to, the following:
[incorporated under 06-096 C.M.R. ch. 115, BPT]

1. The facility shall implement a boiler tune-up program. [40 C.F.R. § 63.11223]

a. Each tune-up shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

Boiler Category	Tune-Up Frequency
Oil fired boilers with a heat input capacity of ≤ 5 MMBtu/hr	Every 5 years

[40 C.F.R. § 63.11223(a) and Table 2]

- b. The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:
- (1) As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted, not to exceed 72 months from the previous inspection. [40 C.F.R. § 63.11223(b)(1)]
 - (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 C.F.R. § 63.11223(b)(2)]
 - (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted, not to exceed 72 months from the previous inspection. [40 C.F.R. § 63.11223(b)(3)]
 - (4) Optimize total emissions of CO, consistent with manufacturer's specifications. [40 C.F.R. § 63.11223(b)(4)]
 - (5) Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 C.F.R. § 63.11223(b)(5)]
 - (6) If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 C.F.R. § 63.11223(b)(7)]
- c. Tune-Up Report: A tune-up report shall be maintained onsite and submitted to the Department and EPA upon request. The report shall contain the following information:
- (1) The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;
 - (2) A description of any corrective actions taken as part of the tune-up of the boiler; and
 - (3) The types and amounts of fuels used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit. [40 C.F.R. § 63.11223(b)(6)]
- d. After conducting the initial boiler tune-up, a Notification of Compliance Status shall be submitted to EPA. [40 C.F.R. § 63.11225(a)(4) and 40 C.F.R. § 63.11214(b)]

2. Compliance Report

For every five-year compliance period, MMA shall prepare a compliance report shall be prepared by March 1st of the following year to document the information below for the five-year period. The report shall be maintained by the source and submitted to the Department and/or to the EPA upon request. The report must include the items contained in §§ 63.11225(b)(1) and (2), including the following: [40 C.F.R. § 63.11225(b)]

- a. Company name and address;
- b. A statement of whether the source has complied with all the relevant requirements of this Subpart;
- c. A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- d. The following certifications, as applicable:
 - (1) "This facility complies with the requirements in 40 C.F.R. § 63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
 - (2) "No secondary materials that are solid waste were combusted in any affected unit."
 - (3) "This facility complies with the requirement in §§ 63.11214(d) and 63.11223(g) to minimize the boiler's time spent during startup and shutdown and to conduct startups and shutdowns according to the manufacturer's recommended procedures or procedures specified for a boiler of similar design if manufacturer's recommended procedures are not available."

3. Recordkeeping

- a. Records shall be maintained consistent with the requirements of 40 C.F.R. Part 63, Subpart JJJJJJ including the following [40 C.F.R. § 63.11225(c)]:
 - (1) Copies of notifications and reports with supporting compliance documentation;
 - (2) Identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned;
 - (3) Records of the occurrence and duration of each malfunction of each applicable boiler; and
 - (4) Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore the malfunctioning boiler.

- b. Records shall be in a form suitable and readily available for expeditious review. Each record must be kept for 5 years following the date of each recorded action. Each record must be kept on-site or be accessible from a central location by computer or other means that instantly provides access at the site for at least 2 years after the date of each recorded action. The records may be maintained off-site for the remaining 3 years. [40 C.F.R. § 63.11225(d)] Note: Standard Condition (8) of this license requires all records be retained for six years; therefore, the five-year record retention requirement of Subpart JJJJJ shall be streamlined to the more stringent six-year requirement.

(18) **Generators**

- A. Generators #1A, #2A, and #7A shall each be limited to 100 hours of operation per calendar year, excluding operating hours during emergency situations. [06-096 C.M.R. ch. 115, BPT]
- B. MMA shall keep records that include maintenance conducted on Generators #1A, #2A, and #7A and the hours of operation of each engine recorded through the non-resettable hour meter. Documentation shall include the number of hours each unit operated for emergency purposes, the number of hours each unit operated for non-emergency purposes, and the reason the engine was in operation during each time. [06-096 C.M.R. ch. 115, BPT]
- C. The fuel sulfur content for Generators #1A, #1B, #2A, #3A, #4B, #5A, #6A, and #7A shall be limited to 0.0015% sulfur by weight. Compliance shall be demonstrated by fuel delivery receipts from the supplier, fuel supplier certification, certificate of analysis, or testing of the fuel in the tank on-site. [06-096 C.M.R. ch. 115, BPT and BACT]
- D. Emissions shall not exceed the following:

Unit	Pollutant	lb/MMBtu	Origin and Authority
Generator #1B	PM	0.12	06-096 C.M.R. ch. 103, § (2)(B)(1)(a)

- E. Emissions shall not exceed the following [06-096 C.M.R. ch. 115, BPT and BACT]:

Unit	PM (lb/hr)	PM ₁₀ (lb/hr)	PM _{2.5} (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Generator #1A	0.21	0.21	0.21	0.01	7.5	1.62	0.60
Generator #1B	0.58	0.58	0.58	0.01	15.36	4.08	0.44
Generator #2A	0.10	0.10	0.10	0.01	3.53	0.76	0.28
Generator #3A	0.08	0.08	0.08	0.01	2.65	0.57	0.21
Generator #4B	0.04	0.04	0.04	0.01	1.82	2.81	0.03
Generator #5A	0.08	0.08	0.08	0.01	3.41	5.27	0.05
Generator #6A	0.20	0.20	0.20	0.01	7.06	1.52	0.56
Generator #7A	0.12	0.12	0.12	0.01	4.41	0.95	0.35

F. Visible Emissions

Visible emissions from Generators #1A, #2A, and #7A shall each not exceed 20% opacity on a six-minute block average basis except for periods of startup during which time MMA shall either meet the normal operating visible emissions standard or the following work practice standards and alternative visible emissions standard.

1. The duration of the startup shall not exceed 30 minutes per event;
2. Visible emissions shall not exceed 50% opacity on a six-minute block average basis; and
3. MMA shall keep records of the date, time, and duration of each startup.

Use of the work practice standards and alternative visible emissions standard in lieu of the normal operating standard is limited to no more than once per day.

Note: This does not limit the engine to one startup per day. It only limits the use of the alternative emission standard to once per day.
[06-096 C.M.R. ch. 101, § 4(A)(4)]

Visible emissions from Generators #1B #3A, #4B, #5A, and #6A shall each not exceed 20% opacity on a six-minute block average basis. [06-096 C.M.R. ch. 101, § 4(A)(4)]

- G. Emergency generators and/or fire pumps are only to be operated for maintenance purposes and for situations arising from sudden and reasonably unforeseeable events beyond the control of the source. Emergency generators and/or fire pumps are not to be used for prime power when reliable offsite power is available; nor to operate or to be contractually obligated to be available in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity.
- H. MMA shall keep records of all maintenance conducted on the engines associated with Generators #3A and #6A. [06-096 C.M.R. ch. 115, BPT]
- I. Generators #1B, #3A and #6A shall meet the applicable requirements of 40 C.F.R. Part 60, Subpart IIII, including the following: [incorporated under 06-096 C.M.R. ch. 115, BPT]
1. Manufacturer Certification
The engines shall be certified by the manufacturer as meeting the emission standards for new nonroad compression ignition engines found in § 60.4202.
[40 C.F.R. § 60.4205(b)]

2. Ultra-Low Sulfur Fuel

The fuel fired in the engine shall not exceed 15 ppm sulfur (0.0015% sulfur). Compliance with the fuel sulfur content limit shall be demonstrated by fuel delivery receipts from the supplier, fuel supplier certification, certificate of analysis, or testing of the fuel in the tank on-site.

[40 C.F.R. § 60.4207(b) and 06-096 C.M.R. ch. 115, BPT]

3. Non-Resettable Hour Meter

A non-resettable hour meter shall be installed and operated on each engine. [40 C.F.R. § 60.4209(a)]

4. Annual Time Limit for Maintenance and Testing

a. As emergency engines, the units shall each be limited to 100 hours/year for maintenance checks and readiness testing. Up to 50 hours/year of the 100 hours/year may be used in non-emergency situations (this does not include peak shaving, demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity). These limits are based on a calendar year. Compliance shall be demonstrated by records (electronic or written log) of all engine operating hours.

[40 C.F.R. § 60.4211(f) and 06-096 C.M.R. ch. 115, BPT]

b. MMA shall keep records that include the hours of operation of each engine recorded through the non-resettable hour meter. Documentation shall include the number of hours each unit operated for emergency purposes, the number of hours each unit operated for non-emergency purposes, and the reason each engine was in operation during each time. [40 C.F.R. § 60.4214(b)]

5. Operation and Maintenance

The engines shall be operated and maintained according to the manufacturer's emission-related written instructions. MMA may only change those emission-related settings that are permitted by the manufacturer. [40 C.F.R. § 60.4211(a)]

MMA shall have available for review by the Department a copy of the manufacturer's emission-related written instructions for engine operation and maintenance. [06-096 C.M.R. ch. 115, BPT]

- J. Generators #4B and #5A shall meet the applicable requirements of 40 C.F.R. Part 60, Subpart JJJJ, including the following:
[incorporated under 06-096 C.M.R. ch. 115, BPT]

1. Manufacturer Certification

The engine shall be certified by the manufacturer as meeting the emission standards for new nonroad spark ignition engines found in 40 C.F.R. Part 60, Subpart JJJJ, Table 1.

2. Non-Resettable Hour Meter

A non-resettable hour meter shall be installed and operated on each engine. [40 C.F.R. § 60.4237 and 06-096 C.M.R. ch. 115, BPT]

3. Annual Time Limit for Maintenance and Testing

a. As emergency engines, the units shall each be limited to 100 hours/year for maintenance checks and readiness testing. Up to 50 hours/year of the 100 hours/year may be used in non-emergency situations (this does not include peak shaving, demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity). The limits are based on a calendar year. Compliance shall be demonstrated by records (electronic or written log) of all engine operating hours.

[40 C.F.R. § 60.4243(d) and 06-096 C.M.R. ch. 115, BPT]

b. MMA shall keep records that include maintenance conducted on the engines and the hours of operation of each engine recorded through the non-resettable hour meter. Documentation shall include the number of hours each unit operated for emergency purposes, the number of hours each unit operated for non-emergency purposes, and the reason each engine was in operation during each time. [40 C.F.R. § 60.4245(b)]

4. Operation and Maintenance

Each engine shall be operated and maintained according to the manufacturer's written instructions or procedures developed by MMA that are approved by the engine manufacturer. MMA may only change those settings that are permitted by the manufacturer. [40 C.F.R. § 60.4243]

MMA shall have available for review by the Department a copy of the manufacturer's emission-related written instructions for engine operation and maintenance. [06-096 C.M.R. ch. 115, BPT]

(19) **General Process Sources**

Visible emissions from any general process source shall not exceed 20% opacity on a six-minute block average basis. [06-096 C.M.R. ch. 101, § 4(B)(4)]

(20) **Fugitive Emissions**

- A. MMA shall not cause emissions of any fugitive dust during any period of construction, reconstruction, or operation without taking reasonable precautions. Such reasonable precautions shall be included in the facility's continuing program of best management practices for suppression of fugitive particulate matter. See 06-096 C.M.R. ch. 101, § 4(C) for a list of potential reasonable precautions.
- B. MMA shall not cause or allow visible emissions within 20 feet of ground level, measured as any level of opacity and not including water vapor, beyond the legal boundary of the property on which such emissions occur. Compliance with this standard shall be determined pursuant to 40 C.F.R. Part 60, Appendix A, Method 22.

[06-096 C.M.R. ch. 101, § 4(C)]

(21) **Annual Emission Statements**

- A. In accordance with *Emission Statements*, 06-096 C.M.R. ch. 137, MMA shall report to the Department, in a format prescribed by the Department, the information necessary to accurately update the State's emission inventory for any emissions that took place before the issuance date of this air emission license. The emission statement shall be submitted as specified by the date in 06-096 C.M.R. ch. 137. After completion of inventory report for calendar year 2025, MMA will no longer be subject to this rule.
- B. MMA shall keep the following records in order to comply with 06-096 C.M.R. ch. 137 until the issuance date of this air emission license:
 - 1. The amount of distillate fuel fired in the boilers (each) on a monthly basis;
 - 2. The emissions calculations for the Engine Test Cell on a monthly basis; and
 - 3. Hours each generator was operating on a monthly basis.

[06-096 C.M.R. ch. 137]

- (22) If the Department determines that any parameter value pertaining to construction and operation of the emissions units, including but not limited to stack size, configuration, flow rate, emission rates, nearby structures, etc., deviates from what was submitted in the application or ambient air quality impact analysis for this air emission license, MMA may be required to submit additional information. Upon written request from the Department, MMA shall provide information necessary to demonstrate AAQS will not be exceeded, potentially including submission of an ambient air quality impact analysis or an application to amend this air emission license to resolve any deficiencies and ensure compliance with AAQS. Submission of this information is due within 60 days of the Department's written request unless otherwise stated in the Department's letter.
[06-096 C.M.R. ch. 115, § 2(O)]

DONE AND DATED IN AUGUSTA, MAINE THIS 4th DAY OF APRIL, 2025.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY:  for
MELANIE LOYZIM, COMMISSIONER

The term of this license shall be ten (10) years from the signature date above.

[Note: If a renewal application, determined as complete by the Department, is submitted prior to expiration of this license, then pursuant to Title 5 M.R.S. § 10002, all terms and conditions of the license shall remain in effect until the Department takes final action on the license renewal application.]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of applications: 7/2/24, 11/15/24, and 2/5/25

Date of application acceptance: 7/8/24, 11/15/24, and 2/5/25

This Order prepared by Chris Ham, Bureau of Air Quality.