




Pool Full - 3" SHORELINE Some wave action + damage
No repairs 3 hours in 66

UPSTREAM LABOT concrete slight surface deterioration

spalling in SW edges alignment on

SW Not within repairs later lowering

GATEWAY some surface wear @ WC

INLETS OK

FISHWAY OK

RABOT slight surface deterioration @ TWL range

some heavy + drag crushing + effluence

Security fences + signs damage to gate

CREST