



STATE OF MAINE
Department of Environmental Protection
Certification of Inerting or Purging of Removed
Underground Gasoline Tank



The completed form or its equivalent must be carried by the driver of the truck transporting this tank. The tank is subject to inspection by the Maine State Police. You should retain this form for your own records.

Facility Information

Facility Name:		Registration #:
Facility Address		Town
Owner Name	Owner Address	Owner Phone

Tank has been (complete for either inerting or purging, as appropriate):

Inerted in accordance with Sections 4.3.3 or 4.3.4 of American Petroleum Institute Recommended Practice 1604. Document oxygen monitoring in the table below.

Probe Placement	% Oxygen	Date	Time
Bottom of tank			
Middle of tank			
Top of tank			

NOTE: In order to be inert, all oxygen readings must be less than 6% oxygen.

Purged in accordance with Sections 4.3.5 of American Petroleum Institute Recommended Practice 1604. Document monitoring in the table below.

Probe Placement	% LEL	% Oxygen	Date	Time
Bottom of tank				
Middle of tank				
Top of tank				

NOTE: In order to be purged, all combustible gas indicator readings must be less than 10% LEL and all oxygen readings must be greater than 14% oxygen.

Certification

I hereby certify that the tank being transported with this form was inerted or purged to comply with 49 CFR §§ 172.101-102 and 06-096 C.M.R. ch. 691, Appendix J(5)(a-c).

Maine Certified Underground Tank Installer & ID #	Signature	Date
---	-----------	------