

MAPLE RIDGE MOBILE HOME PARK

2025 Consumer Confidence Report

General Information

Water System Contact Name: _____

Address: _____

City, State, Zip Code: _____

Telephone #: _____ Fax#: _____ Email: _____

Report Covering Calendar Year: Jan 1 - Dec 31, 2025

Upcoming Regularly Scheduled Meeting(s): _____

☐ No scheduled meetings at this time. Please contact for more information.**Source Water Information**

Description of Water Source: Wells: 2

Water Treatment & Filtration Information:**Source Water Assessment:**

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

Definitions:

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

Secondary Maximum Contaminant Level (SMCL): Non-mandatory water quality standards.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Units:

ppm = parts per million or milligrams per liter (mg/L). pCi/L = picocuries per liter (a measure of radioactivity).

ppb = parts per billion or micrograms per liter (µg/L). ppt = parts per trillion or nanograms per liter (ng/L)

MFL = million fibers per liter.

pos = positive samples.

Water Test Results

Contaminant	Date	Results	MCL	MCLG	Possible Sources of Contamination
-------------	------	---------	-----	------	-----------------------------------

Microbiological

COLIFORM (TCR) (9)	Dec 2025	4 pos	1 pos/mo or 5%	0 pos	Naturally present in the environment.
E COLI (2)	Dec 2025	1 pos	1 pos	0 pos	Human and animal fecal waste.

Inorganics

BARIUM	8/2/2024	0.0063 ppm	2 ppm	2 ppm	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits.
CHROMIUM	8/2/2024	5.4 ppb	100 ppb	100 ppb	Discharge from steel and pulp mills. Erosion of natural deposits.
NITRATE (6)	3/12/2025	2.77 ppm	10 ppm	10 ppm	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.

Synthetics

TOTAL PFAS (6 regulated) (7)	6/6/2025	7.76 ppt	20 ppt	0 ppt	Man-made chemicals in a wide variety of consumer products and industrial applications. Stain- and water-resistant fabrics, carpeting, non-stick cookware, cleaning products and paints, Class B Firefighting foam (AFFF) foam and industrial processes.
------------------------------	----------	----------	--------	-------	---

Radionuclides

COMBINED RADIUM (-226 & -228)	1/9/2025	0.9 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
RADIUM-228	8/4/2025	0.5 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
RADON (8)	5/21/2024	1093 pCi/l	4,000 pCi/l	4,000 pCi/l	Erosion of natural deposits.

Lead/Copper

COPPER 90TH% VALUE (5)	7/1/2024 - 12/31/2024	0.103 ppm Range (0.0063-0.116 ppm)	AL = 1.3 ppm	1.3 ppm	Corrosion of household plumbing systems.
Number of sampling sites exceeding the action level: 0					
LEAD 90TH% VALUE (5)	7/1/2024 - 12/31/2024	6.2 ppb Range (0-6.3 ppb)	AL = 15 ppb	0 ppb	Corrosion of household plumbing systems.
Number of sampling sites exceeding the action level: 0 Complete lead tap sampling data are available upon request					

Disinfectants and Disinfection Byproducts

DISTRIBUTION SYSTEM

TOTAL HALOACETIC ACIDS (HAA5) (10)	LRAA (2025)	0 ppb Range (0-0 ppb)	60 ppb	0 ppb	By-product of drinking water chlorination.
TOTAL TRIHALOMETHANE (TTHM) (10)	LRAA (2025)	0.5 ppb Range (0-2 ppb)	80 ppb	0 ppb	By-product of drinking water chlorination.

Chlorine Residual (Add chlorine residual information)

CHLORINE RESIDUAL	Range (____ - ____ ppm)	MRDL=4 ppm	MRDLG= 4 ppm	By-product of drinking water chlorination.
-------------------	-------------------------	------------	--------------	--

Notes:

- 1) Arsenic: While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Quarterly compliance is based on running annual average.
- 2) E. coli: E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- 3) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
- 4) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
- 5) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
- 6) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- 7) PFAS: The degree of risk depends on the level of chemicals and duration of exposure. Laboratory studies of animals exposed to high doses of PFAS have shown numerous negative effects such as issues with reproduction, growth and development, thyroid function, immune system, neurology, as well as injury to the liver. Research is still relatively new, and more needs to be done to fully assess exposure effects on the human body.
- 8) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- 9) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- 10) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on LRAA.
- 11) Turbidity: Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

All other regulated drinking water contaminants were below detection levels.

Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)

SODIUM	57.5 ppm	8/2/2024
ZINC	0.0058 ppm	8/2/2024
IRON	0.3 ppm	8/2/2024
CHLORIDE	141 ppm	8/2/2024
SULFATE	8 ppm	8/2/2024
MAGNESIUM	9.02 ppm	8/2/2024

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

Lead and Copper

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your public water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your public water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at: <http://www.epa.gov/safewater/lead>

Our public water system completed a Lead Service Line Inventory (LSLI) as required by the Revised Lead and Copper Rule. It is publicly accessible by either contacting your system via phone or email, picking up or viewing a copy at a physical address, or via the website link provided (must link directly to report). Our system is making the inventory available using this method: _____

Total Coliform Bacteria Level Assessments

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any issues that were found during these assessments.

A Level 1 Assessment is an investigation of the water system designed to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. During the past year, we triggered Level One assessment(s) that was/were escalated to a Level Two assessment (see below).

A Level 2 Assessment is a more detailed investigation of the water system designed to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred or why our water system continues to show total coliform bacteria on multiple occasions even after completing a Level 1 Assessment. During the past year, we were required to conduct 1 Level Two assessment(s). We completed 0 Level Two assessment(s). We were not required to take any corrective actions.

Violations

Violation Period	Violation Type
12/1/2025 - 12/31/2025	1A Violation - MCL, E. COLI, POS E COLI (RTCR) E. COLI
7/1/2025 - 2/25/2026	71 Violation - CCR REPORT CONSUMER CONFIDENCE RULE

E. coli MCL Acute Violation: In 2025, our water system tested positive and recheck sample(s) were positive for the presence of fecal coliform and/or E. coli bacteria. A "Boil Water Order" was immediately issued. Public notification was posted or distributed to all residents. To resolve this problem we _____. Fecal coliform and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. Germs in these wastes can cause diarrhea, cramps, nausea, headaches, or fatigue. Subsequent tests have been negative for fecal coliform and E. coli bacteria.

As a community public water system, we are required to provide a consumer confidence report (CCR) to our customers on an annual basis. The CCR provides customers with information regarding the source and quality of the drinking water supplied to them as well as information on any violations that occurred in that time period. In the specified time period, we failed to distribute an accurate and complete CCR to our customers, or corrections needed to be made and the report redistributed past the required deadline. To correct this issue, the CCR has been or will be distributed.

Waiver Information (to be included in the CCR for systems that were granted a waiver)

For the time period 2024-2026, our system was granted a 'Synthetic Organics Waiver.' This is a three year exemption from the monitoring/reporting requirements for the following industrial chemical(s): DIQUAT, ENDOTHALL. This waiver was granted due to the absence of these potential sources of contamination within a

half mile radius of the water source(s).

Please share this information with anyone who drinks this water (or their guardians), especially those who may not have received this report directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this report in a public place or distributing copies by hand, mail, email, or another method.

Maine Drinking Water Program

Consumer Confidence Report Certification Form

PWSID#: ME0095340 Water System Name: MAPLE RIDGE MOBILE HOME PARK

INSTRUCTIONS:

1. Distribute copies of your Consumer Confidence Report (CCR) to all users served by your public water system **by JULY 1ST**.
2. Use the checklists below to check off the methods you use to distribute your CCR. You **MUST** select **AT LEAST ONE** option from **EACH** of the two lists below. If applicable, attach additional information to this form as indicated.
3. Complete the certification section below and submit this form with a copy of your CCR to the Maine Drinking Water Program (DWP) **by July 10th**.

Primary Method of Distribution - you **MUST** use **at least one** of these methods:

CHECK IF USED	Direct Delivery Method - reach each customer	ADDITIONAL INFO
☐	Mail hard copy	
☐	Hand deliver	
☐	Mail notice that CCR is available on website Note: MUST include a direct URL (CCR must open when URL is clicked)	Provide URL: Attach copy of notice (i.e. bill)
☐	Email the direct URL	Attach copy of email
☐	Email the CCR as a file attachment	Attach copy of email
☐	Email CCR in message	Attach copy of message

AND

Secondary Method of Distribution - you **MUST** use **at least one** of these methods:

CHECK IF USED	Good Faith Effort - reach non-bill-paying consumers	ADDITIONAL INFO
☐	Do a postal patron mailing with service area	Provide zip codes used in mailing
☐	Deliver multiple copies to single bill addresses serving several people- i.e. apartment buildings, businesses, large private employers	Provide list of business/facilities receiving copies
☐	Posting on internet at URL	URL: _____
☐	Post the CCR in public places	Provide a list of where posted
☐	Publication of CCR in local newspaper	Provide copy of newspaper notice
☐	Advertising availability of CCR in news media	Provide copy of announcement
☐	Deliver to community organizations	Provide list of facilities
☐	Availability of paper copy	Provide method of sharing info
☐	Population less than 500	Only if you provided 100% distribution to all consumers by your 1 st method

Date CCR Distribution Completed: _____

Certification of Distribution and Accuracy of Consumer Confidence Report

I certify that the information in the attached CCR contains all data and required language found in the Fillable CCR provided by the DWP and that the CCR was distributed by the methods noted above.

Licensed designated operator: _____
Please print

Signature: _____ **Date:** _____ (must be after date of distribution)

Email a copy of CCR, completed certification & accompanying documents to DWPMOR@maine.gov or mail to:
ME DWP, 11 State House Station, 286 Water Street, Augusta, ME 04333-0011