

Janet T. Mills
Governor

Sara Gagné-Holmes
Commissioner



Maine Department of Health and Human Services
Maine Center for Disease Control and Prevention
11 State House Station
286 Water Street
Augusta, Maine 04333-0011
Tel; (207) 287-8016; Fax (207) 287-2887
TTY: Dial 711 (Maine Relay)

April 8, 2025

Mark Schaefer, Government Affairs Specialist
Orenco Systems, Inc.
814 Airway Ave.
Sutherlin, OR 97479

Subject: Product Registration, Orenco Systems, Inc., M-Series tank M1000P/G and M1500 P/G

Dear Mr. Schaefer:

The Division of Environmental Health has completed a review of a registration application for the subject products. This information was submitted pursuant to Section (7).(HH) of the Subsurface Wastewater Disposal Rules for registration for use in Maine.

This letter amends the line of Orenco Systems products that were approved in my January 2025 letter to add the M-series tanks M1000P/G and M1500 P/G

Orenco Systems. Inc. Septic Tanks

Orenco's watertight M-series tanks are made from molded dicyclopentadiene (DCPD). These two tanks are 1,000-gallons and 1,500-gallon capacity. The M-series M1000P/G and M1500 P/G tanks comply with the uniform plumbing code, the international plumbing code and the IAPMO/ANSI Z1000-2019 standard.

On the basis of the information, the Division has determined that the Orenco Systems, Inc. product line is acceptable for use in the State of Maine, provided that the various products are installed, operated, and maintained in conformance with the manufacturer's directions and applicable sizing and installation requirements of the Maine Subsurface Wastewater Disposal Rules.

Because installation and owner maintenance has a significant effect on the working order of onsite sewage disposal systems, including their components, the Division makes no representation or guarantee as to the efficiency and/or operation of Orenco Systems, Inc. products. Further, registration of these products for use in the State of Maine does not represent Division preference or recommendation for this product over similar or competing products.

If you have any questions, please feel free to contact me at (207) 287-5695.

Sincerely,

A handwritten signature in black ink that reads "Alexander L. Pugh".

Alexander L. Pugh
Sr. Environmental Hydrogeologist
Subsurface Wastewater Unit
Drinking Water Program
286 Water Street, Augusta, ME 04333