

Janet T. Mills
Governor

Jeanne M. Lambrew, Ph.D.
Commissioner



Maine Department of Health and Human Services
Maine Center for Disease Control and Prevention
11 State House Station
286 Water Street
Augusta, Maine 04333-0011
Tel; (207) 287-8016; Fax (207) 287-9058
TTY: Dial 711 (Maine Relay)

March 9, 2021

Mr. Kaan Gencer
IMET Corporation
PO Box 470812
Cleveland, Ohio 44147

Dear Mr. Gencer,

The Division of Environmental Health (DEH) provided IMET Corporation with **Pilot Approval** for the Septic Rejuvenator, subsequently rebranded as the IMET Residential Septic Module (RSM), documented in letter correspondence to Dr. Zakriski dated 2/8/2008 after completion of a review of a registration application for the IMET product. This information was submitted pursuant to Section 1802 of the Maine State Plumbing Code, Subsurface Wastewater Disposal Rules (Rules), for code registration, for use in Maine. As part of that correspondence, **Approval** of the RSM was to be conditionally achieved pursuant to a specified pilot program including acceptable analytical results validating performance from actual product installations.

We understand that due to manpower challenges and geographic distance, IMET was unable to fully meet the specific pilot conditions. We do recognize that IMET has achieved NSF/ANSI Standard 40-2018 and NSF/ANSI Standard 245-2018 as evidenced by the Certificate of Conformity issued by the North American Testing, LLC certificate issued 5/20/2019. In addition, we have reviewed analytical performance data collected 9/5/2006 and 8/26/2019 from an RMS installation in Ohio (Chafe Residential Site) to support product functionality. Based on this evidence DEH grants **Approval** for the IMET Corporation Residential Septic Module for use in Maine.

Should you have any questions, please don't hesitate to call.

Sincerely,

A handwritten signature in black ink, appearing to read "TJ Brennan".

Thomas J. Brennan, C.G.
Senior Geologist

Ec: Dr. Zakriski, IMET