



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

November 18, 2024
Subject: Highway Reconstruction, Bridge
Rehabilitation & Lighting Replacement
State WIN: 012800.30, 022258.00 &
024363.00
Location: **South Portland**
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: What size utility poles will be required by cmp for the 910.301 utility work?

Response: Class 2 wood poles will be required for item 910.301.

Consider these changes and information prior to submitting your bid on **December 4, 2024.**

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer