



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

May 17, 2022
Subject: ADA Curb Ramp Improvements &
Trail Extension
State WINs: 013344.20 & 024811.00
Location: **Region 2**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: In the schedule of items: Item # 626.421, 24" diameter foundation. The unit is listed as lf. Is this correct, or should it be per each?

Response: Linear Feet is the correct unit of measurement. Please refer to MaineDOT Standard Specifications, March 2020 Edition, SECTION 626 – FOUNDATIONS, CONDUIT, AND JUNCTION BOXES FOR HIGHWAY SIGNING, LIGHTING AND SIGNALS.

Question: Due to the remote and various locations outlined in the contract documents, would the State allow for granite curb to be installed opposed to concrete slipform or bituminous curb?

Response: The items should be bid as shown in the bid documents. The Department will consider lower or no cost alternatives after the award of the project. The Contractor would have to submit a plan showing transitions from existing curb (concrete slipform or bituminous curb) to granite curb for approval.

Consider these changes and information prior to submitting your bid on **May 18, 2022**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer