



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

December 9, 2010
Subject: **Acton & Newfield**
Federal Project No: BR-1667(600)X
State Pin No: 016676.00
Amendment No. 2

Dear Sir/Ms:

The following questions have been received:

Question: Can the box culvert be designed to be post tensioned with bolts instead of cables?

Response: No. Strands are required.

Question: Can the dam be closed to control water flow from the lake?

Response: MaineDOT does not control the dam. It is controlled by the town of Newfield with input from the lake association, so coordination must be through them. Bruce Colwell is the contact from the town of Newfield. His phone number is (207)432-2060. It is our understanding that the dam is typically shut in early spring and not opened again until fall unless there is a heavy rain event.

Consider this information prior to submitting your bid on December 15, 2010.

Sincerely,

FOR
✓

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER