



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

July 8, 2011  
Subject: **Brunswick**  
Federal Project No: STP-1728(500)X  
State PIN: 017285.00  
**Amendment No. 1**

Dear Sir/Ms:

Make the following change to the Bid Document:

In the Plans Sheet Number 35 of 37, **ADD** the following note to "Dtl. 3: Granite Seating Block Detail" in pen and ink;

**"The granite blocks are 2' wide x 2' thick x 2'-3" tall with 3" embedded into the ground."**

The following question has been received:

**Question:** Item 525.19 Granite Seating Blocks – The detail on plan sheet 35 shows a height of 2'3" and a width of 2'0". What is the length (or third dimension) of these blocks?

**Response:** The granite blocks are 2' wide x 2' thick x 2'-3" tall with 3" embedded into the ground.

Consider this information prior to submitting your bid on July 20, 2011.

Sincerely,

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER