



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

May 24, 2011
Subject: **Caribou Salt Storage Building**
State Pin: 018120.10
Location: Caribou
Amendment No. 1

Dear Sir/Ms:

Make the following change to the Bid Documents:

In the Bid Book (page 9), NOTICE TO CONTRACTORS, **CHANGE** the bid opening date in the first sentence from "June 1, 2011" to read "**June 8, 2011**". Make this change in pen and ink.

The following question has been received:

Question: Are the bars epoxy coated? The title page calls the bars as grade 60 but section 03300 note 2.2D "all reinforcing steel shall be epoxy coated."

Response: All reinforcing steel shall be epoxy coated as per the note in specification section 03300.

Consider this change and information prior to submitting your bid on **June 8, 2011**.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer

For



PRINTED ON RECYCLED PAPER