



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

November 9, 2012
Subject: **Rockland**
Federal Project No: FBD-1834(200)
State WIN: 018342.00
Amendment No. 1

Dear Sir/Ms:

Make the following change to the Bid Document;

In the Bid Book (page 112) section "655.07 Maintenance" after "The following paragraphs are added:" **DELETE** the first sentence which begins; "The manufacturer and distributor of the ..." and **REPLACE** it with the following; "**The manufacturer and/or distributor, whichever entity will be responsible for servicing the Automated Parking System, shall be located within a 100-mile radius of the Rockland Ferry Terminal so as to provide on-site maintenance response within 3 hours of a service call.**" Make this change in pen and ink.

The following question has been received:

Question: Section 655.07 Maintenance states "the manufacturer and distributor ... shall be located within a 100 mile radius of Rockland Ferry Terminal." Is this correct? Should this read "manufacturer OR authorized distributor" only?

Response: Please see the above pen and ink change.

Consider this change and information prior to submitting your bid on November 28, 2012.

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER