



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

June 8, 2020
Subject: Wildlife Crossing Culvert
State WIN: 018754.00
Location: **Eliot**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Are contractors required to be prequalified with MDOT to be considered an eligible bidder?

Response: No, you do not need to be prequalified to bid on this project. However, you will need to demonstrate your ability to do this work scope to be awarded the contract.

Question: Line 0300 calls for a Type "D" field office, where would we find dimensions and specifications for this type of office?

Response: See page 75 of the Contract Bid Book, SPECIAL PROVISION – SECTION 639 – ENGINEERING FACILITIES – Type D Field Office. A Type D field office does not include physical office space but rather supplies bottled water, the use of a wireless broadband connection (such as a MiFi, Jetpack, Velocity, Nighthawk etc.) and a handicapped accessible portable toilet for exclusive use of the inspection staff.

Question: The existing pavement has rumble strip along centerline. Will the department be requiring this to be replaced in the new pavement, and if so how will this be paid?

Response: The Contractor will not be required to replace the centerline rumble strip.

Consider these changes and information prior to submitting your bid on **June 10, 2020**.

Sincerely,

A handwritten signature in black ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer