



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

May 7, 2018
Subject: Bicycle/Pedestrian Path
State WIN: 018858.00
Location: **Brewer**
Amendment No. 2

Dear Sir/Ms.:

The following question has been received:

Question: Proposal Line number 890, the "Special Work- Wi-Fi System" specifies in the Description that "This includes, but is not limited to, fiber optic cable, and conduit". We note that Proposal Line number 880 for the security camera system also has a similar requirement. This would suggest 2 Conduit runs. Is that what you are requiring, or may we accomplish the same by using one conduit shared by the two systems?

Response: The Wi-Fi System and Security System may be contained in the same conduit.

Consider these changes and information prior to submitting your bid on **May 9, 2018**.

Sincerely,

A handwritten signature in black ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER