



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

May 25, 2021
Subject: Sidewalk Construction
State WINs: 018880.00 & 019400.00
Location: **Camden & Rockport**
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: Is there any geotechnical information available to contractors?

Response: No geotechnical information was gathered.

Question: Is it fair to assume 603.55 Concrete Pipe Ties item is only for if the contractor elects RCP pipe for the option III items?

Response: This item was included for use installing the MH, at station 110+00 right, into the existing 30-inch RCP.

Question: With this schedule, it is assumed the contractor can start this year and work with a winter shutdown. Will paving/curb patching be allowed beyond the mainline seasonal deadlines?

Response: Yes, it is assumed the Contractor would start this year and complete the work early next year. All seasonal deadlines in the Standard Specifications still apply.

Consider these changes and information prior to submitting your bid on **June 2, 2021**.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer