



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Paul R. LePage  
GOVERNOR

David Bernhardt  
COMMISSIONER

December 13, 2018  
Subject: Intersection Improvements,  
Highway Rehabilitation & Roadside  
Improvements  
State WINs: 019002.00, 019107.00  
& 023775.02  
Location: **Arundel & Hollis**  
**Amendment No. 1**

Dear Sir/Ms.:

For your information and review:

An additional report is available for review by the Contractor. A project geotechnical report, "19107 Arundel Route 111 Passing Lane Geotechnical Data Report FINAL", dated April 16, 2016, prepared by Golder Associates, has been posted to the MaineDOT web.

The following question has been received:

**Question:** Regarding 48" special granite. What drawing is this item located on? Item is in the schedule of items for 19107.00 but does not appear to be shown on drawings.

**Response:** Item 609.1101 Special Granite Curb – 48" is intended to be used for two granite steps as detailed on WIN 19107.00 Sheet 71 of 79. Other requirements are specified in Special Provision 609 in the bid book.

Consider these changes and information prior to submitting your bid on **January 9, 2019**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER