



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

April 20, 2012
Subject: **Ellsworth Orland**
Federal Project No: AC-STP-1920(400)X &
AC-IB-1920(500)X
State PIN: 019204.00 & 019205.00
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: Item 203.242 Dirty Barrow, calls for 1200CY. The State just completed ditching and inslope work last year and no drop offs exist. Where does the State intend to use the Dirty barrow?

Response: As stated in the contract book, the Dirty Borrow will be used to back up the edge of pavement or as directed by the resident.

Question: Is it the Department's intent for item 204.41, Rehab Existing Shoulders to remove only 2 inches of pavement or all existing pavement?

Response: It is the Department's intent to remove all existing pavement in the areas listed as well as any additional areas as may be directed by the resident.

Consider this information prior to submitting your bid on April 25, 2012

Sincerely,

George Maddougall
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER