

Response: The required flow lines are no more than 1' deeper than the existing and in many cases within inches of existing. Most culverts have been lengthened. In all cases the slopes will be no steeper than they are now.

Question: HMA over trenches. Depth? Type?

Response: Page 2 of 2 of the construction notes paragraph 5 outlines the pavement requirements.

Consider these changes and information prior to submitting your bid on June 27, 2012.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer