



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

September 26, 2024
Subject: Highway Rehabilitation
State WIN: 020267.00
Location: Acton
Amendment No. 4

Dear Sir/Ms.:

The following questions have been received:

Question: Can you please clarify the type of rebar (black, epoxy coated, HDG, etc...) specified for the reinforcing of the Box Culvert?

Response: The type of reinforcing steel for the concrete box culvert shall be ASTM A615 Grade 60 uncoated black bar for reinforcing steel or ASTM A1064 for welded wire fabric.

Question: If the contractor chooses option 2, does the pavement that is to be delivered to the MDOT yard need to be processed or meet any size requirements?

Response: The pavement does not need to be processed or meet a size requirement. The contractor will be required to stockpile the pavement as directed by the Resident.

Consider these changes and information prior to submitting your bid on **October 2, 2024**.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer