



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

August 18, 2025
Subject: Moosehorn Bridge Replacemnt
State WIN: 021686.10
Location: **Charlotte**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: What type of reinforcing (rebar) is specified in the NEXT Beams (black, low chromium, etc...)?

Response: **All reinforcement in the NEXT Beams shall be plain steel (black).**

Consider these changes and information prior to submitting your bid on **August 27, 2025**

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer