



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

November 29, 2018
Subject: Bog Stream Bridge Replacement
State WIN: 021699.00
Location: **Northfield**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: Does any of the reinforcement in the NEXT Beams have to be Stainless, or is it all plain?

Response: The reinforcement in the NEXT beams is all plain steel.

Consider these changes and information prior to submitting your bid on **December 5, 2018**.

Sincerely,

A handwritten signature in blue ink that reads "George M. A. Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER